

J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

April 30, 2021

Mr. Christopher Milano
Levittown Union Free School District
Administration Building
850 Seamans Neck Road
Seaford, New York 11783

Re: **Lead Testing in School Drinking Water
2020 Compliance 10 NYCRR Subpart 67-4**

JCB#: **19-45328**

Dear Mr. Milano:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 15 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead Testing Results for Applicable Outlets

Attachment 2: Laboratory Analytical Reports

Attachment 3: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.


Anthony J. Lombardo

Anthony J. Lombardo


J.C. BRODERICK & ASSOCIATES, INC.

Attachment 1:

Lead Testing Results
for Applicable Outlets



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395



Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Levittown Union Free School District

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
---------------	----------	------------------	-------------	----------------------	-------------	--------------	------------------------------------

Abbey Lane School

LVT-1035	1002	Room 202	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1036	1002A	Room 202 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1	Result Below Action Level Continue O&M
LVT-1037	1001	Room 201	Classroom Faucet	Non-Potable	3/6/2021	2.2	Result Below Action Level Continue O&M
LVT-1038	1003	Room 204	Classroom Faucet	Non-Potable	3/6/2021	6.7	Result Below Action Level Continue O&M
LVT-1039	1004	Room 203	Classroom Faucet	Non-Potable	3/6/2021	3.6	Result Below Action Level Continue O&M
LVT-1040	1005	Room 206	Classroom Faucet	Non-Potable	3/6/2021	7.6	Result Below Action Level Continue O&M
LVT-1041	1006	Room 205	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1042	1007	Room 208	Classroom Faucet	Non-Potable	3/6/2021	7.8	Result Below Action Level Continue O&M
LVT-1043	1008	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1045	1008	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1047	1008	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1049	1008	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1052	1010	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1054	1010	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1056	1010	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.3	Result Below Action Level Continue O&M
LVT-1058	1010	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1060	1012	Room 210	Classroom Faucet	Non-Potable	3/6/2021	3.6	Result Below Action Level Continue O&M
LVT-1061	1013	Room 207	Classroom Faucet	Non-Potable	3/6/2021	7.3	Result Below Action Level Continue O&M
LVT-1062	1014	Room 212	Classroom Faucet	Non-Potable	3/6/2021	190	Placarded for Non-Drinking Use Until Remediated
LVT-1063	1016	Women's Room	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1065	1023	Corridor Between Rooms 201 And Kitchen	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1066	1017	Men's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1068	1022A	Room Across from Kitchen Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	14	Result Below Action Level Continue O&M
LVT-1070	1018	Kitchen Vestibule	Ice Machine	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1071	1020	Kitchen Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.7	Result Below Action Level Continue O&M
LVT-1073	1053	Bathroom By Main Entrance	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1075	1026	Room 302	Classroom Faucet	Non-Potable	3/6/2021	3.4	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1076	1026	Room 302	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1077	1026A	Room 302 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	430	Placarded for Non-Drinking Use Until Remediated
LVT-1079	1025	Room 301	Classroom Faucet	Non-Potable	3/6/2021	2.3	Result Below Action Level Continue O&M
LVT-1080	1025	Room 301	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1081	1025C	Room 301 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	2.1	Result Below Action Level Continue O&M
LVT-1083	1027	Room 303	Classroom Faucet	Non-Potable	3/6/2021	6.8	Result Below Action Level Continue O&M
LVT-1084	N/A New Construction	Corridor off 301-311	Water Cooler	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1085	N/A New Construction	Corridor off 301-311	Water Cooler	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1086	1028	Room 304	Classroom Faucet	Non-Potable	3/6/2021	8.4	Result Below Action Level Continue O&M
LVT-1087	1029	Room 305	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1088	1030	Room 306	Classroom Faucet	Non-Potable	3/6/2021	55	Placarded for Non-Drinking Use Until Remediated
LVT-1089	1031	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	7.5	Result Below Action Level Continue O&M
LVT-1091	1031	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.6	Result Below Action Level Continue O&M
LVT-1093	1031	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1095	1031	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	5.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1099	1033	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	2.8	Result Below Action Level Continue O&M
LVT-1101	1033	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	4.7	Result Below Action Level Continue O&M
LVT-1103	1033	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	17	Placarded for Non-Drinking Use Until Remediated
LVT-1105	1033	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	3.0	Result Below Action Level Continue O&M
LVT-1107	1035	Room 308	Classroom Faucet	Non-Potable	3/6/2021	6.8	Result Below Action Level Continue O&M
LVT-1108	1034	Room 307	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1109	1036	Room 310	Classroom Faucet	Non-Potable	3/6/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-1110	1039	Room 311	Classroom Faucet	Non-Potable	3/6/2021	14	Result Below Action Level Continue O&M
LVT-1111	1040	Room 314	Classroom Faucet	Non-Potable	3/6/2021	1.3	Result Below Action Level Continue O&M
LVT-1112	1041A	Nurse Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1113	1050	Corridor Between Rooms 301 & Storage 2	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1114	1047B	Principal Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1116	1058	All Purpose Room	Water Cooler	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1117	1058	All Purpose Room	Bottle Fill Station	Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1118	1058	All Purpose Room	Hand Wash Only	Non-Potable	3/6/2021	19	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1119	1021	Kitchen	Kitchen Non Potable	Non-Potable	3/6/2021	26	Placarded for Non-Drinking Use Until Remediated
LVT-1120	1021	Kitchen	Kitchen Faucet (Cold)	Potable	3/6/2021	3.1	Result Below Action Level Continue O&M
LVT-1121	1021	Kitchen	Kitchen Faucet (Cold)	Potable	3/6/2021	2.8	Result Below Action Level Continue O&M
LVT-1122	1021	Kitchen	Spray Nozzle	Non-Potable	3/6/2021	1.4	Result Below Action Level Continue O&M
LVT-1123	1021	Kitchen	Kitchen Faucet (Cold)	Potable	3/6/2021	2	Result Below Action Level Continue O&M
LVT-1124	1021	Kitchen	Spray Nozzle	Non-Potable	3/6/2021	1.2	Result Below Action Level Continue O&M
LVT-1125	1059	Library	Hand Wash Only	Non-Potable	3/6/2021	2.9	Result Below Action Level Continue O&M
LVT-1126	N/A New Construction	Room 401	Classroom Faucet	Non-Potable	3/6/2021	4.1	Result Below Action Level Continue O&M
LVT-1127	N/A New Construction	Room 401	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1130	N/A New Construction	Room 402	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1131	N/A New Construction	Room 402	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1132	N/A New Construction	Room 402 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1134	N/A New Construction	Room 403	Classroom Faucet	Non-Potable	3/6/2021	3.3	Result Below Action Level Continue O&M
LVT-1135	N/A New Construction	Room 403	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1136	N/A New Construction	Room 403 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1138	N/A New Construction	Room 404	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1139	N/A New Construction	Room 404	Hand Wash Only	Non-Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1140	N/A New Construction	Room 404 Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1142	1068	Room 406	Classroom Faucet	Non-Potable	3/6/2021	4.8	Result Below Action Level Continue O&M
LVT-1143	1065	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	2.5	Result Below Action Level Continue O&M
LVT-1145	1065	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.1	Result Below Action Level Continue O&M
LVT-1147	1065	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	2	Result Below Action Level Continue O&M
LVT-1149	1070	Corridor Between Rooms 405 And 410	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1153	1063	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	15	Result Below Action Level Continue O&M
LVT-1155	1063	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	2.5	Result Below Action Level Continue O&M
LVT-1157	1063	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	5.6	Result Below Action Level Continue O&M
LVT-1159	1063	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	5.6	Result Below Action Level Continue O&M
LVT-1162	1062	Faculty Room 409	Kitchen Faucet (Cold)	Potable	3/6/2021	1.6	Result Below Action Level Continue O&M
LVT-1163	1060	Room 411	Classroom Faucet	Non-Potable	3/6/2021	36	Placarded for Non-Drinking Use Until Remediated
LVT-1166	1072	Women's Faculty Bathroom 1	Bathroom Faucet	Non-Potable	3/6/2021	3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1168	1073	Women's Bathroom 2	Bathroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1170	1075	Music Room 515	Classroom Faucet	Non-Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1171	1075	Music Room 515	Spray Nozzle	Non-Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1172	1077	Art Room 511	Classroom Faucet	Non-Potable	3/6/2021	8.3	Result Below Action Level Continue O&M
LVT-1173	1077	Art Room 511	Classroom Faucet	Non-Potable	3/6/2021	28	Placarded for Non-Drinking Use Until Remediated
LVT-1174	1092	Corridor Between Rooms 501 & Music Room	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service
LVT-1175	1082	Room 508	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1176	1084	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	5.4	Result Below Action Level Continue O&M
LVT-1178	1084	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	6.8	Result Below Action Level Continue O&M
LVT-1180	1084	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.3	Result Below Action Level Continue O&M
LVT-1182	1084	Girl's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.1	Result Below Action Level Continue O&M
LVT-1188	1086	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	3.5	Result Below Action Level Continue O&M
LVT-1190	1086	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.5	Result Below Action Level Continue O&M
LVT-1192	1086	Boy's Bathroom	Bathroom Faucet	Non-Potable	3/6/2021	1.5	Result Below Action Level Continue O&M
LVT-1195	1092	Corridor Between Rooms 501 & Music Room	Water Fountain-No Chiller	Potable	3/6/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1196	1091	Room 501	Classroom Faucet	Non-Potable	3/6/2021	<3.0 ND	Result Below Action Level Continue O&M

B&G Bus Garage

LVT-1429	1000A	Locker Room Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1430	1000A	Locker Room Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1432	1000	Locker Room	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

B&G Office

LVT-1412	1003	Parts Storage Room	Ice Machine	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1415	1017	Break Room	Kitchen Faucet (Cold)	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1416	1019	Lobby	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1417	1019	Lobby	Bottle Fill Station	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1418	1018	Ladies Bathroom Entrance	Kitchen Faucet (Cold)	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1419	1018	Ladies Bathroom Entrance	Spray Nozzle	Non-Potable	3/4/2021	1.1	Result Below Action Level Continue O&M
LVT-1420	1018A	Ladies Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	1.3	Result Below Action Level Continue O&M
LVT-1421	1017C	Men's Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1422	1017C	Men's Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1423	1017C	Men's Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

B&G Transportation Offices

LVT-1437	1000A	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	3.0	Result Below Action Level Continue O&M
LVT-1438	1004	Kitchen	Kitchen Faucet (Cold)	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1439	2001	Womens Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	22	Placarded for Non-Drinking Use Until Remediated

Division Avenue High School

LVT-0227	2000A	Room 252 Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0231	2021A	Library 234 Magazine Room	Kitchen Faucet (Cold)	Potable	2/13/2021	1	Result Below Action Level Continue O&M
LVT-0233	2014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0235	2014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0237	2014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0239	2016	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0241	2016	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0243	2016	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0245	2016	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0295	2047A	Room 219 Kitchen	Kitchen Faucet (Cold)	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0301	2054	Room 212	Classroom Faucet	Non-Potable	2/13/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-0302	2058	Room 213	Classroom Faucet	Non-Potable	2/13/2021	98	Placarded for Non-Drinking Use Until Remediated
LVT-0303	2058	Room 213	Spray Nozzle	Non-Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0304	2063B	Room 207 Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-0307	1008	Room 107	Kitchen Faucet (Cold)	Potable	2/13/2021	1.6	Result Below Action Level Continue O&M
LVT-0308	1009	Corridor Room 101-107	Water Fountain-No Chiller	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0309	1008C1	English Chairperson Conference Room Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.6	Result Below Action Level Continue O&M
LVT-0311	2065	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	14	Result Below Action Level Continue O&M
LVT-0313	2065	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.6	Result Below Action Level Continue O&M
LVT-0315	2065	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	4.5	Result Below Action Level Continue O&M
LVT-0317	2065	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.8	Result Below Action Level Continue O&M
LVT-0319	2061A	Room 207A Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.5	Result Below Action Level Continue O&M
LVT-0321	2061A	Room 207A Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.7	Result Below Action Level Continue O&M
LVT-0323	2061A	Room 207A Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.2	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0325	1004A	Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.8	Result Below Action Level Continue O&M
LVT-0327	1004A	Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	6.1	Result Below Action Level Continue O&M
LVT-0329	1004A	Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	4.9	Result Below Action Level Continue O&M
LVT-0331	1005	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	1.9	Result Below Action Level Continue O&M
LVT-0333	1005	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0335	1005	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	4.2	Result Below Action Level Continue O&M
LVT-0337	1005	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	28	Placarded for Non-Drinking Use Until Remediated
LVT-0340	1030	Room 129	Classroom Faucet	Non-Potable	2/13/2021	56	Placarded for Non-Drinking Use Until Remediated
LVT-0341	1027	Room 125	Home Economics Faucet (Cold)	Potable	2/13/2021	2.2	Result Below Action Level Continue O&M
LVT-0342	1027	Room 125	Home Economics Faucet (Cold)	Potable	2/13/2021	28	Removed From Service, Pending Remediation
LVT-0343	1027	Room 125	Home Economics Faucet (Cold)	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0344	1027	Room 125	Home Economics Faucet (Cold)	Potable	2/13/2021	1.9	Result Below Action Level Continue O&M
LVT-0346	1033A	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	32	Placarded for Non-Drinking Use Until Remediated
LVT-0348	1033A	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	7.7	Result Below Action Level Continue O&M
LVT-0350	1033A	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	1.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0353	1035	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.2	Result Below Action Level Continue O&M
LVT-0354	1035	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.0	Result Below Action Level Continue O&M
LVT-0356	1035	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.7	Result Below Action Level Continue O&M
LVT-0358	1038	Room 133 Faculty	Kitchen Faucet (Cold)	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0359	1038	Room 133 Faculty	Water Fountain-No Chiller	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0360	1038A	Room 133 Faculty Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	13	Result Below Action Level Continue O&M
LVT-0362	1038A	Room 133 Faculty Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	5.1	Result Below Action Level Continue O&M
LVT-0364	1038A	Room 133 Faculty Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	7.2	Result Below Action Level Continue O&M
LVT-0366	1038A	Room 133 Faculty Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	6.5	Result Below Action Level Continue O&M
LVT-0368	1038B	Room 133 Faculty Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	4.2	Result Below Action Level Continue O&M
LVT-0369	1038B	Room 133 Faculty Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	46	Placarded for Non-Drinking Use Until Remediated
LVT-0371	1042	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0372	1043	Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0373	1046B2	Main Office Kitchen	Kitchen Faucet (Cold)	Potable	2/13/2021	17	Removed From Service, Pending Remediation
LVT-0374	1046D	Main Office Ladies Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	9.8	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0375	1046E	Main Office Men's Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	9.4	Result Below Action Level Continue O&M
LVT-0376	1046F2	Main Office Principal's Office Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	1.7	Result Below Action Level Continue O&M
LVT-0377	1049	Room 140 Health Office	Nurse's Office Sink	Potable	2/13/2021	6.5	Result Below Action Level Continue O&M
LVT-0379	1049D1	Room 140 Back File Room Ice Room	Ice Machine	Potable	2/13/2021	14	Result Below Action Level Continue O&M
LVT-0380	1051	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	720	Placarded for Non-Drinking Use Until Remediated
LVT-0382	1051	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	110	Placarded for Non-Drinking Use Until Remediated
LVT-0384	1051	Boys Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	390	Placarded for Non-Drinking Use Until Remediated
LVT-0389	1053	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.1	Result Below Action Level Continue O&M
LVT-0391	1053	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	1.4	Result Below Action Level Continue O&M
LVT-0393	1053	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	2.1	Result Below Action Level Continue O&M
LVT-0395	1053	Girls Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0397	1056	Room 146	Classroom Faucet	Non-Potable	2/13/2021	26	Placarded for Non-Drinking Use Until Remediated
LVT-0398	1057	Life Skills Room 150	Classroom Faucet	Non-Potable	2/13/2021	2.8	Result Below Action Level Continue O&M
LVT-0399	1057C	Life Skills Room 150 Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0401	1061	Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.6	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0402	1062	Room 151	Classroom Faucet	Non-Potable	2/13/2021	4.3	Result Below Action Level Continue O&M
LVT-0403	1064	Room 152	Home Economics Faucet (Cold)	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0404	1064	Room 152	Spray Nozzle	Non-Potable	2/13/2021	1.9	Result Below Action Level Continue O&M
LVT-0405	1064	Room 152	Home Economics Faucet (Cold)	Potable	2/13/2021	1.7	Result Below Action Level Continue O&M
LVT-0406	1064	Room 152	Spray Nozzle	Non-Potable	2/13/2021	43	Placarded for Non-Drinking Use Until Remediated
LVT-0407	1064	Room 152	Home Economics Faucet (Cold)	Potable	2/13/2021	4.5	Result Below Action Level Continue O&M
LVT-0408	1064C	Room 152 Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0410	1066	Room 155	Classroom Faucet	Non-Potable	2/13/2021	2.6	Result Below Action Level Continue O&M
LVT-0414	1048D2	Girls Locker Room 2 Shower Area	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0418	1095C	Room 318 File Storage	Hand Wash Only	Non-Potable	2/13/2021	10	Result Below Action Level Continue O&M
LVT-0420	1069	West Cafeteria (Renovated)	Water Cooler	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0421	1069	West Cafeteria (Renovated)	Bottle Fill Station	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0422	1071	East Cafeteria (Renovated)	Water Cooler	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0423	1071	East Cafeteria (Renovated)	Bottle Fill Station	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0425	1070	Kitchen (Reconstructed)	Kitchen Non Potable	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0426	1070	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0427	1070	Kitchen (Reconstructed)	Kitchen Non Potable	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0428	1070	Kitchen (Reconstructed)	Kitchen Non Potable	Non-Potable	2/13/2021	26	Placarded for Non-Drinking Use Until Remediated
LVT-0429	1070	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/13/2021	2	Result Below Action Level Continue O&M
LVT-0430	1070	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0431	1070	Kitchen (Reconstructed)	Spray Nozzle	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0433	1070A	Kitchen Office (Interior Wall Removed, Part of New Serving Line)	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0434	1070B	Kitchen Ladies Bathroom 1 (Renovated)	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0435	1073A	Custodial Lounge Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.3	Result Below Action Level Continue O&M
LVT-0442	1104	Room 313	Ice Machine	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0443	1104A	Room 313 Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	7.3	Result Below Action Level Continue O&M
LVT-0444	1109	Gym/Lobby Corridor	Water Cooler	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0445	1109	Gym/Lobby Corridor	Bottle Fill Station	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0446	1099B	Room 317 Gym Office Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	4.3	Result Below Action Level Continue O&M
LVT-0448	1096	Room 319 Robotics	Classroom Faucet	Non-Potable	2/13/2021	35	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0449	1096	Room 319 Robotics	Classroom Faucet	Non-Potable	2/13/2021	7.3	Result Below Action Level Continue O&M
LVT-0450	1086	Engineering Room 323	Classroom Faucet	Non-Potable	2/13/2021	25	Placarded for Non-Drinking Use Until Remediated
LVT-0451	1086	Engineering Room 323	Classroom Faucet	Non-Potable	2/13/2021	3	Result Below Action Level Continue O&M
LVT-0452	1083	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	3.8	Result Below Action Level Continue O&M
LVT-0454	1083	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	23	Placarded for Non-Drinking Use Until Remediated
LVT-0457	1081	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	150	Placarded for Non-Drinking Use Until Remediated
LVT-0459	1081	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/13/2021	23	Placarded for Non-Drinking Use Until Remediated
LVT-0461	1080	Graphics Room 326	Classroom Faucet	Non-Potable	2/13/2021	1.2	Result Below Action Level Continue O&M
LVT-0462	1080	Graphics Room 326	Classroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0463	1079	Fitness Center 325	Water Cooler	Potable	2/13/2021	OOS	Testing Required Prior to Return to Service
LVT-0464	1078A	Room 328 Dark Room	Spray Nozzle	Non-Potable	2/13/2021	25	Placarded for Non-Drinking Use Until Remediated
LVT-0465	1078A	Room 328 Dark Room	Spray Nozzle	Non-Potable	2/13/2021	23	Placarded for Non-Drinking Use Until Remediated
LVT-0466	1078A	Room 328 Dark Room	Classroom Faucet	Non-Potable	2/13/2021	140	Placarded for Non-Drinking Use Until Remediated
LVT-0467	1078A	Room 328 Dark Room	Classroom Faucet	Non-Potable	2/13/2021	13	Result Below Action Level Continue O&M
LVT-0468	1076	Print Shop	Classroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0469	1076	Print Shop	Classroom Faucet	Non-Potable	2/13/2021	1.6	Result Below Action Level Continue O&M
LVT-0470	1075	Room 329	Classroom Faucet	Non-Potable	2/13/2021	210	Placarded for Non-Drinking Use Until Remediated
LVT-0471	1075	Room 329	Classroom Faucet	Non-Potable	2/13/2021	4.5	Result Below Action Level Continue O&M
LVT-0472	1075	Room 329	Classroom Faucet	Non-Potable	2/13/2021	11	Result Below Action Level Continue O&M
LVT-0473	1075	Room 329	Spray Nozzle	Non-Potable	2/13/2021	210	Placarded for Non-Drinking Use Until Remediated
LVT-0474	1075	Room 329	Classroom Faucet	Non-Potable	2/13/2021	1.9	Result Below Action Level Continue O&M
LVT-0485	N/A New Construction	Concession Stand	Kitchen Faucet (Cold)	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2246	1104	Room 313	Hose Bib	Potable	2/13/2021	2.7	Result Below Action Level Continue O&M
LVT-2247	1104	Room 313	Bottle Fill Station	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2248	1104	Room 313	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2249	1104	Room 313	Bathroom Faucet	Non-Potable	2/13/2021	1.1	Result Below Action Level Continue O&M
LVT-2250	1104	Room 313	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2251	1104	Room 313	Bathroom Faucet	Non-Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2256	2029	Corridor Storage Room to Room 252	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2257	2031	Room 232	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2258	2056	Corridor Rooms 212 to 230	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2259	1037	Corridor Room 114-134	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2260	1044	Auditorium Lobby	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2261	1068	Corridor Boys Bathroom to Room 164	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2262	1066	Room 155	Spray Nozzle	Non-Potable	2/13/2021	56	Placarded for Non-Drinking Use Until Remediated
LVT-2263	1066	Room 155	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2264	1097	Corridor Rooms 319-324	Bottled Water Dispenser	Potable	2/13/2021	<3.0 ND	Result Below Action Level Continue O&M

East Broadway Elementary School

LVT-1451	1001	Room 97	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1452	1001	Room 97	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1453	1001A	Room 97 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1456	1004	Room 99	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1457	1004	Room 99	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1458	1004A	Room 99 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1460	1005	Room 100	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1461	1005	Room 100	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1462	1005B	Room 100 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1.5	Result Below Action Level Continue O&M
LVT-1464	1007	Room 101	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1465	1007A	Room 101 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1	Result Below Action Level Continue O&M
LVT-1467	1008	Room 102	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1468	1008A	Room 102 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1470	1009	Room 103	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1471	1009A	Room 103 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1.8	Result Below Action Level Continue O&M
LVT-1473	1010	Room 104	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1474	1010	Room 104	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1476	1020	Corridor Rooms 101 & 110	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1477	1011	Room 105	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1478	1011A	Room 105 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	5.0	Result Below Action Level Continue O&M
LVT-1480	1012A	Room 106 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	11	Result Below Action Level Continue O&M
LVT-1482	1013A	Room 107 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1484	1015	Room 107A	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1485	1014	Room 108	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1486	1014A	Room 108 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1488	1017A	Room 110 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1490	1036	Room 115	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1491	1037	Room 120	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1492	1035	Room 118	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1493	1038	Corridor Rooms 110 & 115	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1494	1034	Room 113	Classroom Faucet	Non-Potable	2/4/2021	1.2	Result Below Action Level Continue O&M
LVT-1495	1033	Room 116	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1496	1030	Room 114	Classroom Faucet	Non-Potable	2/4/2021	1.4	Result Below Action Level Continue O&M
LVT-1497	1029	Room 111	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1498	1028	Room 112	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1499	1027	Room 109	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1500	1026	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1502	1026	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1504	1026	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1506	1026	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1508	1025	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1510	1025	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1515	1040	Room 305 Art Room	Classroom Faucet	Non-Potable	2/4/2021	51	Placarded for Non-Drinking Use Until Remediated
LVT-1516	1040	Room 305 Art Room	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1517	1041	Room 306	Classroom Faucet	Non-Potable	2/4/2021	1.2	Result Below Action Level Continue O&M
LVT-1518	1041A	Room 306 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1.5	Result Below Action Level Continue O&M
LVT-1520	1043	Room 303 Faculty	Hand Wash Only	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1521	1045	Men's/Women's Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1522	1059	Corridor Between Gymnasium and Custodian by Room 305	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1523	1046	Women's Room	Bathroom Faucet	Non-Potable	2/4/2021	1.5	Result Below Action Level Continue O&M
LVT-1525	1046	Women's Room	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1526	1049A	Principal's Office Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1528	1055	Kitchen	Kitchen Service Area	Potable	2/4/2021	2.2	Result Below Action Level Continue O&M
LVT-1529	1055	Kitchen	Kitchen Faucet (Cold)	Potable	2/4/2021	2.9	Result Below Action Level Continue O&M
LVT-1530	1055	Kitchen	Kitchen Faucet (Cold)	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1531	1055	Kitchen	Kitchen Non Potable	Non-Potable	2/4/2021	1.1	Result Below Action Level Continue O&M
LVT-1532	1055	Kitchen	Kitchen Faucet (Cold)	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1533	1055	Kitchen	Kitchen Faucet (Cold)	Potable	2/4/2021	1.5	Result Below Action Level Continue O&M
LVT-1534	1050	Nurse Office	Hand Wash Only	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1535	1050A	Nurse Office Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1536	1051A	Custodial Office Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1538	1053	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1539	1053	Cafeteria	Bottle Fill Station	Potable	2/4/2021	1.2	Result Below Action Level Continue O&M
LVT-1540	1058C2A	Gym Classroom Office Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	2.1	Result Below Action Level Continue O&M
LVT-1542	1058C1A	Gym Classroom Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1547	1087	Room 221	Classroom Faucet	Non-Potable	2/4/2021	3.9	Result Below Action Level Continue O&M
LVT-1548	1086	Room 220	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1549	1085	Room 218	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1550	1084	Room 219	Classroom Faucet	Non-Potable	2/4/2021	11	Result Below Action Level Continue O&M
LVT-1551	1081	Room 217 A & B	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1552	1083	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1554	1083	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1555	1083	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1557	1080	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1559	1080	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1.3	Result Below Action Level Continue O&M
LVT-1561	1080	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1562	1088	Corridor Rooms 221 to 202	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1563	1061	Room 201	Classroom Faucet	Non-Potable	2/4/2021	2.3	Result Below Action Level Continue O&M
LVT-1564	1062	Room 202	Classroom Faucet	Non-Potable	2/4/2021	9.4	Result Below Action Level Continue O&M
LVT-1565	1062	Room 202	Water Fountain-No Chiller	Potable	4/19/2021	140	Outlet Permanently Removed
LVT-1566	1063	Room 203	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1567	1065	Room 205	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1568	1066	Room 206	Classroom Faucet	Non-Potable	2/4/2021	1.5	Result Below Action Level Continue O&M
LVT-1569	1066	Room 206	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1570	1069	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1572	1069	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1574	1069	Boys Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1576	1069	Boys Bathroom	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1578	1071	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1580	1071	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1582	1071	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	1.1	Result Below Action Level Continue O&M
LVT-1584	1071	Girls Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1594	1072	Room 207A	Classroom Faucet	Non-Potable	2/4/2021	2.4	Result Below Action Level Continue O&M
LVT-1595	1088	Corridor Rooms 221 to 202	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1596	1073	Room 209	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1597	1075	Room 211	Classroom Faucet	Non-Potable	2/4/2021	1.9	Result Below Action Level Continue O&M
LVT-1598	1076	Room 213	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1599	1002	Room 98	Classroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1600	1002	Room 98	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1601	1002B	Room 98 Bathroom	Bathroom Faucet	Non-Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2222	1015	Room 107A	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2223	1050	Nurse Office	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2224	1053	Cafeteria	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2225	1058C2	Gym Classroom Office	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2226	1022	Entrance Vestibule Adjacent to School Store	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2227	1089	Exit Vestibule By Library	Bottled Water Dispenser	Potable	2/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Gardiners Avenue Elementary School

LVT-1609	1001	Room 100	Classroom Faucet	Non-Potable	2/5/2021	1.6	Result Below Action Level Continue O&M
LVT-1610	1001	Room 100	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1611	1001A	Room 100 Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1613	1000	Room 101	Classroom Faucet	Non-Potable	2/5/2021	1.2	Result Below Action Level Continue O&M
LVT-1614	1000A	Room 101 Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1616	1000	Room 101	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1617	1018	Corridor Between Rooms 101 And 112	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1618	1004	Room 102 & Side Office	Classroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1619	1005	Room 103	Classroom Faucet	Non-Potable	2/5/2021	1	Result Below Action Level Continue O&M
LVT-1620	1006	Room 104	Classroom Faucet	Non-Potable	2/5/2021	3.0	Result Below Action Level Continue O&M
LVT-1621	1018	Corridor Between Rooms 101 And 112	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1622	1007	Room 105	Classroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1623	1008	Room 106	Classroom Faucet	Non-Potable	2/5/2021	3.0	Result Below Action Level Continue O&M
LVT-1624	1009	Room 107	Classroom Faucet	Non-Potable	2/5/2021	1.1	Result Below Action Level Continue O&M
LVT-1625	1010	Room 108	Classroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1626	1011	Boys Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1628	1011	Boys Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1633	1013	Girls Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1635	1013	Girls Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1637	1018	Corridor Between Rooms 101 And 112	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1638	1015	Room 109	Classroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1639	1017A	Room 112 Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	1.7	Result Below Action Level Continue O&M
LVT-1641	1024	Corridor & Exit By Gym	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1642	1020	Men's Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	2.3	Result Below Action Level Continue O&M
LVT-1644	1022	Women's Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1646	1025	Room 200	Classroom Faucet	Non-Potable	2/5/2021	31	Placarded for Non-Drinking Use Until Remediated
LVT-1647	1026	Room 201	Classroom Faucet	Non-Potable	2/5/2021	2	Result Below Action Level Continue O&M
LVT-1648	1041	Corridor Between Room 200 & Computer Room	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1649	1028	Room 202	Classroom Faucet	Non-Potable	2/5/2021	2	Result Below Action Level Continue O&M
LVT-1650	1029	Room 203	Classroom Faucet	Non-Potable	2/5/2021	1.5	Result Below Action Level Continue O&M
LVT-1651	1030	Room 204	Classroom Faucet	Non-Potable	2/5/2021	3.3	Result Below Action Level Continue O&M
LVT-1652	1031	Room 205	Classroom Faucet	Non-Potable	2/5/2021	1.7	Result Below Action Level Continue O&M
LVT-1653	1041	Corridor Between Room 200 & Computer Room	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1654	1032	Girls Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1655	1032	Girls Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1660	1035	Room 206	Classroom Faucet	Non-Potable	2/5/2021	1.5	Result Below Action Level Continue O&M
LVT-1661	1034	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	1	Result Below Action Level Continue O&M
LVT-1663	1034	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1664	1037A	Assistant Principal Room 200B Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	11	Result Below Action Level Continue O&M
LVT-1666	1038	Room 207	Classroom Faucet	Non-Potable	2/5/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-1667	1040	Computer Room 209	Classroom Faucet	Non-Potable	2/5/2021	12	Result Below Action Level Continue O&M
LVT-1668	1041	Corridor Between Room 200 & Computer Room	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1669	1039	Library	Hand Wash Only	Non-Potable	2/5/2021	37	Placarded for Non-Drinking Use Until Remediated
LVT-1670	1042A	Entrance Lobby Men's Room	Bathroom Faucet	Non-Potable	2/5/2021	4.9	Result Below Action Level Continue O&M
LVT-1672	1043	Cafeteria	Hand Wash Only	Non-Potable	2/5/2021	1.6	Result Below Action Level Continue O&M
LVT-1673	1043	Cafeteria	Water Cooler	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1674	1043	Cafeteria	Bottle Fill Station	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1675	1043D	Custodians Office	Hand Wash Only	Non-Potable	2/5/2021	15	Result Below Action Level Continue O&M
LVT-1676	1043C	Kitchen	Kitchen Service Area	Potable	2/5/2021	5.8	Result Below Action Level Continue O&M
LVT-1677	1043C	Kitchen	Kitchen Non Potable	Non-Potable	2/5/2021	2.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1678	1043C	Kitchen	Kitchen Faucet (Cold)	Potable	2/5/2021	3.4	Result Below Action Level Continue O&M
LVT-1679	1043C	Kitchen	Kitchen Faucet (Cold)	Potable	2/5/2021	4.2	Result Below Action Level Continue O&M
LVT-1683	1043C4	Kitchen Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1685	1042B	Entrance Lobby Ladies Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1687	1042C2	Principals Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	1.7	Result Below Action Level Continue O&M
LVT-1691	1046	Room 300	Classroom Faucet	Non-Potable	2/5/2021	6.3	Result Below Action Level Continue O&M
LVT-1692	1061	Corridor Between Vocal Music Room & Room 308	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1693	1047	Faculty Room 301	Kitchen Faucet (Cold)	Potable	2/5/2021	2.3	Result Below Action Level Continue O&M
LVT-1694	1048A	Chair Persons Office Room 300D Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	3.9	Result Below Action Level Continue O&M
LVT-1696	1049	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	1.5	Result Below Action Level Continue O&M
LVT-1698	1049	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	2.1	Result Below Action Level Continue O&M
LVT-1700	1049	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	12	Result Below Action Level Continue O&M
LVT-1705	1051	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	2.2	Result Below Action Level Continue O&M
LVT-1707	1051	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	1.3	Result Below Action Level Continue O&M
LVT-1709	1051	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	1	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1711	1052	Room 302	Classroom Faucet	Non-Potable	2/5/2021	4.0	Result Below Action Level Continue O&M
LVT-1712	1053	Room 303	Classroom Faucet	Non-Potable	2/5/2021	15	Result Below Action Level Continue O&M
LVT-1713	1054	Room 304	Classroom Faucet	Non-Potable	2/5/2021	4.8	Result Below Action Level Continue O&M
LVT-1714	1055	Room 305	Classroom Faucet	Non-Potable	2/5/2021	2.5	Result Below Action Level Continue O&M
LVT-1716	1058	Room 306	Classroom Faucet	Non-Potable	2/5/2021	70	Placarded for Non-Drinking Use Until Remediated
LVT-1717	1059	Room 307	Classroom Faucet	Non-Potable	2/5/2021	1.4	Result Below Action Level Continue O&M
LVT-1718	1060	Room 308	Classroom Faucet	Non-Potable	2/5/2021	3.0	Result Below Action Level Continue O&M
LVT-1719	1062A	Psychologist Office Room 400A Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	11	Result Below Action Level Continue O&M
LVT-1721	1086	Lobby Outside Gym	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1722	1064A	Physical Education Office Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	45	Placarded for Non-Drinking Use Until Remediated
LVT-1724	1065	Men's Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	3.6	Result Below Action Level Continue O&M
LVT-1726	1066	Ladies Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1728	1069	Room 400	Classroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1729	1070	Room 401	Classroom Faucet	Non-Potable	2/5/2021	11	Result Below Action Level Continue O&M
LVT-1730	1071	Room 402	Classroom Faucet	Non-Potable	2/5/2021	9.8	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1731	1072	Room 403	Classroom Faucet	Non-Potable	2/5/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-1732	1073	Room 404	Classroom Faucet	Non-Potable	2/5/2021	30	Placarded for Non-Drinking Use Until Remediated
LVT-1733	1074	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	2.7	Result Below Action Level Continue O&M
LVT-1735	1074	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	2.9	Result Below Action Level Continue O&M
LVT-1737	1074	Girls Bathroom	Bathroom Faucet	Non-Potable	2/5/2021	6.1	Result Below Action Level Continue O&M
LVT-1742	1076	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1744	1076	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1746	1076	Boys Room	Bathroom Faucet	Non-Potable	2/5/2021	9.3	Result Below Action Level Continue O&M
LVT-1748	1085	Corridor Between Rooms 400 & 409	Water Fountain-No Chiller	Potable	2/5/2021	OOS	Testing Required Prior to Return to Service
LVT-1749	1077	Room 405	Classroom Faucet	Non-Potable	2/5/2021	6.3	Result Below Action Level Continue O&M
LVT-1750	1078	Room 406	Classroom Faucet	Non-Potable	2/5/2021	57	Placarded for Non-Drinking Use Until Remediated
LVT-1751	1079	Room 407	Classroom Faucet	Non-Potable	2/5/2021	2.1	Result Below Action Level Continue O&M
LVT-1752	1080	Room 408	Classroom Faucet	Non-Potable	2/5/2021	5.1	Result Below Action Level Continue O&M
LVT-1753	1084	Room 409	Classroom Faucet	Non-Potable	2/5/2021	5.1	Result Below Action Level Continue O&M
LVT-1754	1083	Room 410	Classroom Faucet	Non-Potable	2/5/2021	4.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2228	1018	Corridor Near Boys Bathroom	Bottled Water Dispenser	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2229	1041	Corridor Near Room 203	Bottled Water Dispenser	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2230	1047	Faculty Room 301	Ice Machine	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2231	1061	Corridor Near Faculty Room	Bottled Water Dispenser	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2232	1085	Corridor Near Girls Bathroom	Bottled Water Dispenser	Potable	2/5/2021	<3.0 ND	Result Below Action Level Continue O&M

General Douglas MacArthur High School

LVT-0001	1001A	Room 100A Orchestra Storage Room	Hand Wash Only	Non-Potable	2/6/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-0002	1003	Room 103	Classroom Faucet	Non-Potable	2/6/2021	1.4	Result Below Action Level Continue O&M
LVT-0003	1003	Room 103	Classroom Faucet	Non-Potable	2/6/2021	2	Result Below Action Level Continue O&M
LVT-0004	1003	Room 103	Classroom Faucet	Non-Potable	2/6/2021	2.2	Result Below Action Level Continue O&M
LVT-0005	1004	Room 105	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0006	1004	Room 105	Classroom Faucet	Non-Potable	2/6/2021	1.5	Result Below Action Level Continue O&M
LVT-0007	1004	Room 105	Classroom Faucet	Non-Potable	2/6/2021	1.1	Result Below Action Level Continue O&M
LVT-0008	1008	Room 102	Classroom Faucet	Non-Potable	2/6/2021	1.1	Result Below Action Level Continue O&M
LVT-0009	1008	Room 102	Spray Nozzle	Non-Potable	2/6/2021	19	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0010	1008B	Film Darkroom	Hand Wash Only	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0011	1008C	Print Darkroom	Hand Wash Only	Non-Potable	2/6/2021	100	Placarded for Non-Drinking Use Until Remediated
LVT-0012	1012	Room 113A	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0013	1012	Room 113A	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0014	1014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0016	1014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	5.9	Result Below Action Level Continue O&M
LVT-0018	1014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	2.3	Result Below Action Level Continue O&M
LVT-0020	1014	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	2	Result Below Action Level Continue O&M
LVT-0021	1030	Corridor Rooms 100A to 124	Water Fountain-No Chiller	Potable	2/6/2021	1.5	Result Below Action Level Continue O&M
LVT-0024	1016	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	1.4	Result Below Action Level Continue O&M
LVT-0025	1016	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0027	1016	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	9.0	Result Below Action Level Continue O&M
LVT-0029	1016	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0031	1016	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0034	1032A1	Boys Locker Room Coach Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0036	1032E	Boys Locker Room Shower Wall Chase	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0038	1032E	Boys Locker Room Shower Wall Chase	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0040	1031	Gym Lobby/Corridor	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0041	1031	Gym Lobby/Corridor	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0042	N/A New Construction	New Gym Hall	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0043	N/A New Construction	New Gym Hall	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0044	N/A New Construction	New Gym Hall Closet	Ice Machine	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0045	1038B1	Girls Locker Room Bathroom in Office	Bathroom Faucet	Non-Potable	2/6/2021	48	Placarded for Non-Drinking Use Until Remediated
LVT-0047	1038D	Girls Locker Room Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0048	N/A New Construction	New Gym Locker Room Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0051	2036	Corridor Rooms 208 to Stairwell	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0052	2036	Corridor Rooms 208 to Stairwell	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0053	2009	Room 221	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0054	2009	Room 221	Spray Nozzle	Non-Potable	2/6/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-0055	2033	Cafeteria A	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0056	2033	Cafeteria A	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0066	2030	Girls Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0068	2030	Girls Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	68	Placarded for Non-Drinking Use Until Remediated
LVT-0070	2030	Girls Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	17	Placarded for Non-Drinking Use Until Remediated
LVT-0072	2030	Girls Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	33	Placarded for Non-Drinking Use Until Remediated
LVT-0074	2030	Girls Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-0077	2028	Boys Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	4.5	Result Below Action Level Continue O&M
LVT-0079	2028	Boys Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-0081	2028	Boys Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	36	Placarded for Non-Drinking Use Until Remediated
LVT-0083	2028	Boys Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0085	2036	Corridor Rooms 208 to Stairwell	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0088	2015	Room 211	Home Economics Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0089	2015	Room 211	Home Economics Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0090	2015	Room 211	Home Economics Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0091	2015	Room 211	Home Economics Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0092	2024	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0093	2024	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0094	2023	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0096	2044	Nurses Office	Nurse's Office Sink	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0097	2044B	Nurses Office Sick Room	Nurse's Office Sink	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0098	2044A1	Nurses Office Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0100	2014	Faculty Lounge 213	Water Cooler	Potable	2/6/2021	6.8	Result Below Action Level Continue O&M
LVT-0101	2014	Faculty Lounge 213	Kitchen Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0102	2014	Faculty Lounge 213	Kitchen Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0104	2036	Corridor Rooms 208 to Stairwell	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0105	2036	Corridor Rooms 208 to Stairwell	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0106	2043A1	Guidance Chair Office Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0108	2042	Women's Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0109	2045	Corridor From Nurses Office to Room 99	Water Fountain-No Chiller	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0110	2041	Men's Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0112	N/A New Construction	New Construction Room C4	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0113	N/A New Construction	New Construction Room C4	Classroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0114	N/A New Construction	New Construction Room C4	Classroom Faucet	Non-Potable	2/6/2021	5.4	Result Below Action Level Continue O&M
LVT-0115	N/A New Construction	New Construction Room C4	Classroom Faucet	Non-Potable	2/6/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-0116	N/A New Construction	New Construction Mens Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0118	N/A New Construction	New Construction Mens Lobby Hall	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0119	N/A New Construction	New Construction Mens Lobby Hall	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0120	N/A New Construction	New Construction Womens Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0122	2034A	Kitchen	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0123	2034A	Kitchen	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0124	2034	Kitchen (Reconstructed)	Kitchen Non Potable	Non-Potable	2/6/2021	1.7	Result Below Action Level Continue O&M
LVT-0125	2034	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0126	2034	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0127	2034	Kitchen (Reconstructed)	Kitchen Faucet (Cold)	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0128	2034	Kitchen (Reconstructed)	Kitchen Non Potable	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0136	N/A New Construction	New Construction Boys Locker Room Bathroom	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0140	3036	Corridor Rooms 300-322	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0180	3036	Corridor Rooms 300-322	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0197	3017	Women's Faculty Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0199	3017	Women's Faculty Room	Bathroom Faucet	Non-Potable	2/6/2021	1.3	Result Below Action Level Continue O&M
LVT-0201	3017	Women's Faculty Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0203	3017	Women's Faculty Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0205	3017	Women's Faculty Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0208	3036	Corridor Rooms 300-322	Bottle Fill Station	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0209	3019	Men's Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0211	3019	Men's Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0213	3019	Men's Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0215	3019	Men's Room	Bathroom Faucet	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0217	3021A2	Assistant Principals Office	Hand Wash Only	Non-Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0218	3036	Corridor Rooms 300-322	Water Fountain-No Chiller	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0220	N/A New Construction	Kitchen By Track	Kitchen Faucet (Cold)	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0226	N/A	By Baseball Field	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2233	1030	Corridor Rooms 100A to 124	Bottled Water Dispenser	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2234	2036	Corridor Rooms 208 to Stairwell	Bottled Water Dispenser	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2235	N/A New Construction	New Construction Hallway o/s Room C4	Bottled Water Dispenser	Potable	2/6/2021	<3.0 ND	Result Below Action Level Continue O&M

Jonas E. Salk Middle School

LVT-1221	0006	Shop Room B5	Classroom Faucet	Non-Potable	2/9/2021	3.4	Result Below Action Level Continue O&M
LVT-1224	0009	Weight Room	Ice Machine	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1225	0009	Weight Room	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1226	0009	Weight Room	Bottle Fill Station	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1231	0010C	Girls Locker Room Phys. Ed. Office	Bathroom Faucet	Non-Potable	2/9/2021	1.2	Result Below Action Level Continue O&M
LVT-1233	N/A New Construction	Corridor 133-132	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1234	N/A New Construction	Corridor 133-132	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1235	1000	Men's Faculty Bathroom (Across From Gym)	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1238	1002	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1240	1003	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1242	1003	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1244	1003	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1248	1007	Room 128/126	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1249	1018	Corridor Room 131 To 121	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1250	1007	Room 128/126	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1251	1007	Room 128/126	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1252	1007	Room 128/126	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1253	1007	Room 128/126	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1254	1012	Room 123	Kitchen Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1255	1014	Room 122	Home Economics Faucet (Cold)	Potable	2/9/2021	3.0	Result Below Action Level Continue O&M
LVT-1256	1014	Room 122	Home Economics Faucet (Cold)	Potable	2/9/2021	2.5	Result Below Action Level Continue O&M
LVT-1257	1014	Room 122	Home Economics Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1258	1014	Room 122	Home Economics Faucet (Cold)	Potable	2/9/2021	48	Removed From Service, Pending Remediation
LVT-1259	1013	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1261	1013	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1263	1018	Corridor Room 131 To 121	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1264	1015	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1266	1015	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1268	1023B	Nurses Office	Nurse's Office Sink	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1269	1023B2B	Nurses Office Cot Room Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1271	1024C1	Assistant Principal Office Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	3.3	Result Below Action Level Continue O&M
LVT-1273	1025A	Principals Office Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	2.6	Result Below Action Level Continue O&M
LVT-1274	1026A	Main Office Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1275	1042	Corridor Guidance To Room 109	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1276	1035	Room 107	Classroom Faucet	Non-Potable	2/9/2021	2.4	Result Below Action Level Continue O&M
LVT-1277	1035	Room 107	Classroom Faucet	Non-Potable	2/9/2021	2.6	Result Below Action Level Continue O&M
LVT-1278	1035	Room 107	Classroom Faucet	Non-Potable	2/9/2021	9.4	Result Below Action Level Continue O&M
LVT-1279	1042	Corridor Guidance To Room 109	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1280	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.2	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1281	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1283	1040	Room 109	Classroom Faucet	Non-Potable	2/9/2021	5.3	Result Below Action Level Continue O&M
LVT-1284	1040	Room 109	Classroom Faucet	Non-Potable	2/9/2021	3.4	Result Below Action Level Continue O&M
LVT-1285	1040	Room 109	Classroom Faucet	Non-Potable	2/9/2021	13	Result Below Action Level Continue O&M
LVT-1287	1039	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1289	1039	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1292	1043	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.9	Result Below Action Level Continue O&M
LVT-1293	1043	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1294	1049A1	Boiler Storage Room Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1296	1055	Corridor Boiler Room To Room 112	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1297	1051	Room 111	Classroom Faucet	Non-Potable	2/9/2021	4.3	Result Below Action Level Continue O&M
LVT-1298	1051	Room 111	Classroom Faucet	Non-Potable	2/9/2021	2.2	Result Below Action Level Continue O&M
LVT-1299	1051	Room 111	Classroom Faucet	Non-Potable	2/9/2021	4.0	Result Below Action Level Continue O&M
LVT-1300	1052	Room 112	Classroom Faucet	Non-Potable	2/9/2021	4.3	Result Below Action Level Continue O&M
LVT-1301	1052	Room 112	Classroom Faucet	Non-Potable	2/9/2021	5.5	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1302	1052	Room 112	Classroom Faucet	Non-Potable	2/9/2021	3.9	Result Below Action Level Continue O&M
LVT-1303	1056	Room 114	Classroom Faucet	Non-Potable	2/9/2021	2.9	Result Below Action Level Continue O&M
LVT-1304	1056	Room 114	Classroom Faucet	Non-Potable	2/9/2021	3.3	Result Below Action Level Continue O&M
LVT-1305	1056	Room 114	Classroom Faucet	Non-Potable	2/9/2021	2.9	Result Below Action Level Continue O&M
LVT-1306	1056	Room 114	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1307	1056	Room 114	Classroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1308	1052	Room 112	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1309	1057C	Room 116 Office 2	Hand Wash Only	Non-Potable	2/9/2021	12	Result Below Action Level Continue O&M
LVT-1311	1061	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.9	Result Below Action Level Continue O&M
LVT-1312	1061	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	2	Result Below Action Level Continue O&M
LVT-1313	1063	Green Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1314	1064	Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	1.3	Result Below Action Level Continue O&M
LVT-1315	1064	Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1316	1064	Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	1.2	Result Below Action Level Continue O&M
LVT-1317	1064	Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1318	1064	Kitchen	Kitchen Non Potable	Non-Potable	2/9/2021	1.1	Result Below Action Level Continue O&M
LVT-1319	1064	Kitchen	Spray Nozzle	Non-Potable	2/9/2021	11	Result Below Action Level Continue O&M
LVT-1320	1064	Kitchen	Kitchen Faucet (Cold)	Potable	2/9/2021	3.7	Result Below Action Level Continue O&M
LVT-1321	1064B	Kitchen Locker Room	Bathroom Faucet	Non-Potable	2/9/2021	1.6	Result Below Action Level Continue O&M
LVT-1323	1064F1	Kitchen Exit Vestibule Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	3.2	Result Below Action Level Continue O&M
LVT-1327	1065	Blue Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1328	1067	Boys Entrance Into Gym	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1333	2015	Corridor Room 203 To Room 210	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1351	2004A	Boys Room Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.9	Result Below Action Level Continue O&M
LVT-1360	2015	Corridor Room 203 To Room 210	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1361	2013	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1362	2013	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1363	2016	Faculty Room	Kitchen Faucet (Cold)	Potable	2/9/2021	3.9	Result Below Action Level Continue O&M
LVT-1364	2020A	Library Work Room	Kitchen Faucet (Cold)	Potable	2/9/2021	2.2	Result Below Action Level Continue O&M
LVT-1365	2025	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1367	2025	Men's Faculty Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1369	2040	Corridor Boys Bathroom To Room 221	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1370	2040	Corridor Boys Bathroom To Room 221	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1372	2039	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.9	Result Below Action Level Continue O&M
LVT-1374	2039	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1376	2039	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	2	Result Below Action Level Continue O&M
LVT-1378	2039	Boys Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.7	Result Below Action Level Continue O&M
LVT-1585	1067	Boys Entrance Into Gym	Bottle Fill Station	Potable	2/9/2021	2.8	Result Below Action Level Continue O&M
LVT-1586	2002	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	2	Result Below Action Level Continue O&M
LVT-1587	2002	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	2.6	Result Below Action Level Continue O&M
LVT-1589	2002	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.2	Result Below Action Level Continue O&M
LVT-1591	2002	Girls Bathroom	Bathroom Faucet	Non-Potable	2/9/2021	1.6	Result Below Action Level Continue O&M
LVT-2236	1023	Health Vestibule	Bottled Water Dispenser	Potable	2/9/2021	1.6	Result Below Action Level Continue O&M
LVT-2237	1044	Auditorium Lobby	Bottled Water Dispenser	Potable	2/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Laurel Lane School

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2064	1000B1	Room 101 Boys Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	10	Result Below Action Level Continue O&M
LVT-2066	1002A	Room 104 Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	8.5	Result Below Action Level Continue O&M
LVT-2068	1002	Room 104	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2069	1003	Room 105	Hand Wash Only	Non-Potable	2/10/2021	6.4	Result Below Action Level Continue O&M
LVT-2070	1007	Bathroom D	Bathroom Faucet	Non-Potable	2/10/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-2072	1007	Bathroom D	Bathroom Faucet	Non-Potable	2/10/2021	1.4	Result Below Action Level Continue O&M
LVT-2074	1005A	Principal's Office Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	6.5	Result Below Action Level Continue O&M
LVT-2075	1008	Small Kitchen	Kitchen Faucet (Cold)	Potable	2/10/2021	12	Result Below Action Level Continue O&M
LVT-2076	1016	Corridor (Server Room - Room 102)	Water Cooler	Potable	2/10/2021	30	Removed From Service, Pending Remediation
LVT-2077	1010	Bathroom E	Bathroom Faucet	Non-Potable	2/10/2021	14	Result Below Action Level Continue O&M
LVT-2080	1013	Kitchen	Kitchen Faucet (Cold)	Potable	2/10/2021	6.4	Result Below Action Level Continue O&M
LVT-2081	1013	Kitchen	Kitchen Faucet (Cold)	Potable	2/10/2021	10	Result Below Action Level Continue O&M
LVT-2082	1018	Visitor Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2083	1017	Room 108 Associate Executive Director Office	Kitchen Faucet (Cold)	Potable	2/10/2021	2.2	Result Below Action Level Continue O&M
LVT-2084	1025	Bathroom G	Bathroom Faucet	Non-Potable	2/10/2021	6.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2085	1027	Room 114 Nurse/Classroom 5	Classroom Faucet	Non-Potable	2/10/2021	3.7	Result Below Action Level Continue O&M
LVT-2086	1027A	Room 114/Classroom 5 Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	4.4	Result Below Action Level Continue O&M
LVT-2088	1033	Corridor (Gymnasium - Room 118)	Water Fountain-No Chiller	Potable	2/10/2021	120	Removed From Service, Pending Remediation
LVT-2089	1028A	Room 115/Exercise Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	23	Placarded for Non-Drinking Use Until Remediated
LVT-2091	1032	Room 118/Classroom 6	Classroom Faucet	Non-Potable	2/10/2021	9.6	Result Below Action Level Continue O&M
LVT-2092	1032A	Room 118/Classroom 6 Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	25	Placarded for Non-Drinking Use Until Remediated
LVT-2094	1031	Room 117/Clinic 2 / Room 8	Classroom Faucet	Non-Potable	2/10/2021	11	Result Below Action Level Continue O&M
LVT-2095	1031A	Room 117/Clinic 2 Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	71	Placarded for Non-Drinking Use Until Remediated
LVT-2097	1030	Room 116/Clinic 1	Classroom Faucet	Non-Potable	2/10/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-2098	1030A	Room 116/Clinic 1 Bathroom	Bathroom Faucet	Non-Potable	2/10/2021	3.8	Result Below Action Level Continue O&M
LVT-2238	1004	Room 106	Bottled Water Dispenser	Potable	2/10/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2239	1032	Room 118/Classroom 6	Bottled Water Dispenser	Potable	2/10/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2240	1033	Corridor (Gymnasium - Room 118)	Hand Wash Only	Non-Potable	2/10/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2241	1016	Corridor (Server Room - Room 102)	Hand Wash Only	Non-Potable	2/10/2021	1.3	Result Below Action Level Continue O&M

Lee Road Elementary School

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1920	1015	Room 1	Classroom Faucet	Non-Potable	2/11/2021	8.7	Result Below Action Level Continue O&M
LVT-1921	1015	Room 1	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1922	1015B	Room 1 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	2	Result Below Action Level Continue O&M
LVT-1924	1016	Corridor Between Rooms 1 & 10	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1925	1016	Corridor Between Rooms 1 & 10	Bottle Fill Station	Potable	2/11/2021	1.2	Result Below Action Level Continue O&M
LVT-1926	1013A	Storage Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1927	1013A	Storage Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.6	Result Below Action Level Continue O&M
LVT-1928	1012B1	Gym Office Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.4	Result Below Action Level Continue O&M
LVT-1929	1021	Room 22	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1930	1021	Room 22	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1931	1021A	Room 22 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.6	Result Below Action Level Continue O&M
LVT-1932	1019	Room 23	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1933	1019	Room 23	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1934	1019A	Room 23 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.3	Result Below Action Level Continue O&M
LVT-1935	1018	Art Room 24	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1936	1018	Art Room 24	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1937	1018A	Art Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	4.7	Result Below Action Level Continue O&M
LVT-1938	1020	Room 25	Classroom Faucet	Non-Potable	2/11/2021	1.3	Result Below Action Level Continue O&M
LVT-1939	1020	Room 25	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1940	1020A	Room 25 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.2	Result Below Action Level Continue O&M
LVT-1942	1008	Room 3	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1943	1008B	Room 3 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	5.0	Result Below Action Level Continue O&M
LVT-1945	1006	Room 5	Classroom Faucet	Non-Potable	2/11/2021	1.4	Result Below Action Level Continue O&M
LVT-1946	1006	Room 5	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1947	1006B	Room 5 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1	Result Below Action Level Continue O&M
LVT-1949	1004	Room 7	Classroom Faucet	Non-Potable	2/11/2021	2.6	Result Below Action Level Continue O&M
LVT-1950	1004	Room 7	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1951	1004B	Room 7 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.6	Result Below Action Level Continue O&M
LVT-1953	1002	Room 9	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1954	1002	Room 9	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1955	1002C	Room 9 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1957	1001	Room 10	Classroom Faucet	Non-Potable	2/11/2021	8.1	Result Below Action Level Continue O&M
LVT-1958	1001	Room 10	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1959	1001B	Room 10 Bathroom	Bathroom Faucet	Non-Potable	4/19/2021	1.6	Result Below Action Level Continue O&M
LVT-1961	1003	Room 8 Kindergarten	Classroom Faucet	Non-Potable	2/11/2021	2	Result Below Action Level Continue O&M
LVT-1962	1003	Room 8 Kindergarten	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1963	1003A	Room 8 Closet	Bathroom Faucet	Non-Potable	2/11/2021	1.1	Result Below Action Level Continue O&M
LVT-1965	1005	Room 6	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1966	1005	Room 6	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1967	1005B	Room 6 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	2.4	Result Below Action Level Continue O&M
LVT-1969	1007	Room 4	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1970	1007	Room 4	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1971	1007B	Room 4 Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.2	Result Below Action Level Continue O&M
LVT-1973	1011	Faculty Room	Kitchen Faucet (Cold)	Potable	2/11/2021	5.1	Result Below Action Level Continue O&M
LVT-1974	1026	Women's Room	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1976	1027	Men's Room	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1977	1030A	Cafeteria Girls Room	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1979	1030	Cafeteria	Hand Wash Only	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1980	1030	Cafeteria	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1981	1030	Cafeteria	Hand Wash Only	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1982	1030B	Cafeteria Boys Room	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1984	1033B2	Corridor Between Principal and Office Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	1.5	Result Below Action Level Continue O&M
LVT-1985	1034B	Nurses Office Bathroom	Bathroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1986	1031	Kitchen	Kitchen Faucet (Cold)	Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1987	1031	Kitchen	Spray Nozzle	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1988	1031	Kitchen	Kitchen Non Potable	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1992	2002	Fountain Vestibule	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1993	2002	Fountain Vestibule	Bottle Fill Station	Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1996	2008	Room 12	Classroom Faucet	Non-Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1997	2009	Room 11	Classroom Faucet	Non-Potable	2/11/2021	1.5	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1998	2010	Room 14	Classroom Faucet	Non-Potable	4/22/2021	OOS	Testing Required Before Return to Service
LVT-1999	2011	Room 13	Classroom Faucet	Non-Potable	2/11/2021	1.5	Result Below Action Level Continue O&M
LVT-2000	2011	Room 13	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2001	2012	Room 16	Classroom Faucet	Non-Potable	2/11/2021	2.1	Result Below Action Level Continue O&M
LVT-2002	2012	Room 16	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2003	2013	Room 15	Classroom Faucet	Non-Potable	2/11/2021	3.7	Result Below Action Level Continue O&M
LVT-2004	2013	Room 15	Water Fountain-No Chiller	Potable	2/11/2021	1.6	Result Below Action Level Continue O&M
LVT-2242	1016	Corridor Between Rooms 1 & 10	Bottled Water Dispenser	Potable	2/11/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2243	1016	Corridor Between Rooms 1 & 10	Bottled Water Dispenser	Potable	2/11/2021	1.2	Result Below Action Level Continue O&M

Levittown Memorial Education Center

LVT-1760	0005	Room 11	Spray Nozzle	Non-Potable	2/12/2021	15	Result Below Action Level Continue O&M
LVT-1761	0005	Room 11	Spray Nozzle	Non-Potable	2/12/2021	13	Result Below Action Level Continue O&M
LVT-1762	0005	Room 11	Spray Nozzle	Non-Potable	2/12/2021	14	Result Below Action Level Continue O&M
LVT-1763	0005	Room 11	Spray Nozzle	Non-Potable	2/12/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-1764	0005	Room 11	Spray Nozzle	Non-Potable	2/12/2021	3.6	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1765	0005	Room 11	Classroom Faucet	Non-Potable	2/12/2021	8.6	Result Below Action Level Continue O&M
LVT-1766	0006	Room 9	Classroom Faucet	Non-Potable	2/12/2021	75	Placarded for Non-Drinking Use Until Remediated
LVT-1767	0006	Room 9	Spray Nozzle	Non-Potable	2/12/2021	46	Placarded for Non-Drinking Use Until Remediated
LVT-1768	0007A	Room 7 Laundry Room 7A	Classroom Faucet	Non-Potable	2/12/2021	10	Result Below Action Level Continue O&M
LVT-1769	0007	Room 7	Spray Nozzle	Non-Potable	2/12/2021	8.6	Result Below Action Level Continue O&M
LVT-1770	0007	Room 7	Spray Nozzle	Non-Potable	2/12/2021	5.8	Result Below Action Level Continue O&M
LVT-1771	0007	Room 7	Spray Nozzle	Non-Potable	2/12/2021	12	Result Below Action Level Continue O&M
LVT-1772	0007	Room 7	Spray Nozzle	Non-Potable	2/12/2021	5.9	Result Below Action Level Continue O&M
LVT-1773	0007	Room 7	Spray Nozzle	Non-Potable	2/12/2021	10	Result Below Action Level Continue O&M
LVT-1775	0013	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	14	Result Below Action Level Continue O&M
LVT-1782	0018A	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	3.3	Result Below Action Level Continue O&M
LVT-1784	0019A	Men's Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	1.1	Result Below Action Level Continue O&M
LVT-1786	0020A	Room 5 Printing Room	Classroom Faucet	Non-Potable	2/12/2021	1100	Placarded for Non-Drinking Use Until Remediated
LVT-1787	0029	Corridor Room 5 to Custodial Area	Water Fountain-No Chiller	Potable	2/12/2021	62	Removed From Service, Pending Remediation
LVT-1788	0027	Room 1 (Garage/Auto Shop)	Classroom Faucet	Non-Potable	2/12/2021	110	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1789	0027	Room 1 (Garage/Auto Shop)	Classroom Faucet	Non-Potable	2/12/2021	49	Placarded for Non-Drinking Use Until Remediated
LVT-1790	0027	Room 1 (Garage/Auto Shop)	Water Fountain-No Chiller	Potable	2/12/2021	14	Result Below Action Level Continue O&M
LVT-1791	0029	Corridor Room 5 to Custodial Area	Water Cooler	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1792	0029	Corridor Room 5 to Custodial Area	Bottle Fill Station	Potable	2/12/2021	1	Result Below Action Level Continue O&M
LVT-1793	0028	Room 2 Nurse Office	Nurse's Office Sink	Potable	2/12/2021	3.5	Result Below Action Level Continue O&M
LVT-1796	0030	Custodial Corridor	Hand Wash Only	Non-Potable	2/12/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1799	1003A1A	Room 120 Office Bathroom Closet	Bathroom Faucet	Non-Potable	2/12/2021	40	Placarded for Non-Drinking Use Until Remediated
LVT-1800	1003B	Room 120 Storage/Old Bathroom	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1801	1003B	Room 120 Storage/Old Bathroom	Classroom Faucet	Non-Potable	2/12/2021	5.5	Result Below Action Level Continue O&M
LVT-1803	1003B	Room 120 Storage/Old Bathroom	Classroom Faucet	Non-Potable	2/12/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-1805	1003B	Room 120 Storage/Old Bathroom	Classroom Faucet	Non-Potable	2/12/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-1810	1010	Room 115	Classroom Faucet	Non-Potable	2/12/2021	27	Placarded for Non-Drinking Use Until Remediated
LVT-1811	1021	Room 101 Kitchen	Kitchen Faucet (Cold)	Potable	2/12/2021	54	Removed From Service, Pending Remediation
LVT-1812	1021	Room 101 Kitchen	Kitchen Faucet (Cold)	Potable	2/12/2021	110	Removed From Service, Pending Remediation
LVT-1813	1020	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	11	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1815	1020	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	34	Placarded for Non-Drinking Use Until Remediated
LVT-1820	1018	Men's Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	2.8	Result Below Action Level Continue O&M
LVT-1822	1018	Men's Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	4.4	Result Below Action Level Continue O&M
LVT-1824	1017	Room 100	Kitchen Faucet (Cold)	Potable	2/12/2021	4.7	Result Below Action Level Continue O&M
LVT-1825	1026	Corridor Rooms Ladies room To 111	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1826	1013	Room 108	Classroom Faucet	Non-Potable	2/12/2021	6.3	Result Below Action Level Continue O&M
LVT-1827	1011	Room 110	Classroom Faucet	Non-Potable	2/12/2021	1500	Placarded for Non-Drinking Use Until Remediated
LVT-1828	1011	Room 110	Spray Nozzle	Non-Potable	2/12/2021	410	Placarded for Non-Drinking Use Until Remediated
LVT-1829	1026	Corridor Rooms Ladies room To 111	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1830	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service
LVT-1832	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service
LVT-1834	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service
LVT-1836	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service
LVT-1838	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service
LVT-1840	1028	Culinary Boys Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Before Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1842	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	130	Placarded for Non-Drinking Use Until Remediated
LVT-1844	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	6.8	Result Below Action Level Continue O&M
LVT-1846	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	5.4	Result Below Action Level Continue O&M
LVT-1848	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	15	Result Below Action Level Continue O&M
LVT-1850	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	32	Placarded for Non-Drinking Use Until Remediated
LVT-1852	1029	Culinary Girls Dressing Room	Bathroom Faucet	Non-Potable	2/12/2021	50	Placarded for Non-Drinking Use Until Remediated
LVT-1854	1034	Fitness Room 206	Classroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1855	1034	Fitness Room 206	Spray Nozzle	Non-Potable	2/12/2021	5.1	Result Below Action Level Continue O&M
LVT-1856	1041	Corridor Outside Gymnasium	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1857	1036	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	17	Placarded for Non-Drinking Use Until Remediated
LVT-1859	1036	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	4.8	Result Below Action Level Continue O&M
LVT-1861	1036	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	3.7	Result Below Action Level Continue O&M
LVT-1863	1036	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	2.7	Result Below Action Level Continue O&M
LVT-1865	1036	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	7.7	Result Below Action Level Continue O&M
LVT-1866	1039D3	Room 209 Wood Shop Locker Room	Bathroom Faucet	Non-Potable	2/12/2021	42	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1868	1039D3	Room 209 Wood Shop Locker Room	Bathroom Faucet	Non-Potable	2/12/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-1869	1039D3	Room 209 Wood Shop Locker Room	Bathroom Faucet	Non-Potable	2/12/2021	30	Placarded for Non-Drinking Use Until Remediated
LVT-1870	1039D3	Room 209 Wood Shop Locker Room	Bathroom Faucet	Non-Potable	2/12/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-1872	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-1873	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1874	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	3.9	Result Below Action Level Continue O&M
LVT-1875	1037	Boys Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	36	Placarded for Non-Drinking Use Until Remediated
LVT-1876	1038	Men's Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	3.1	Result Below Action Level Continue O&M
LVT-1881	1055	Corridor Room 310 To 321	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1882	1065A	Room 301 Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	15	Result Below Action Level Continue O&M
LVT-1883	1070	Corridor Room 307 to Ladies Bathroom	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1891	1078	Men's Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-1892	1077	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	170	Placarded for Non-Drinking Use Until Remediated
LVT-1893	1092	Corridor Auditorium To Lobby	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1894	1073A	Room 422A	Hand Wash Only	Non-Potable	2/12/2021	5.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1895	1086A	Room 409 Kitchen/Conference	Kitchen Faucet (Cold)	Potable	2/12/2021	9.4	Result Below Action Level Continue O&M
LVT-1896	1089	Room 414	Bathroom Faucet	Non-Potable	2/12/2021	8.4	Result Below Action Level Continue O&M
LVT-1897	1090D2	Room 410 Assistant Superintendents Office Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	25	Placarded for Non-Drinking Use Until Remediated
LVT-1898	1094	Ladies Room	Bathroom Faucet	Non-Potable	2/12/2021	7.9	Result Below Action Level Continue O&M
LVT-1899	1095	Men's Room	Bathroom Faucet	Non-Potable	2/12/2021	3.7	Result Below Action Level Continue O&M
LVT-1900	1097	Room 401	Kitchen Non Potable	Non-Potable	2/12/2021	12	Result Below Action Level Continue O&M
LVT-1901	1097	Room 401	Ice Machine	Potable	2/12/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1902	1097	Room 401	Kitchen Faucet (Cold)	Potable	2/12/2021	230	Removed From Service, Pending Remediation
LVT-1903	1097	Room 401	Kitchen Faucet (Cold)	Potable	2/12/2021	32	Removed From Service, Pending Remediation
LVT-1904	1097	Room 401	Kitchen Faucet (Cold)	Potable	2/12/2021	470	Removed From Service, Pending Remediation
LVT-1905	1097	Room 401	Kitchen Faucet (Cold)	Potable	2/12/2021	98	Removed From Service, Pending Remediation
LVT-1906	1097	Room 401	Kitchen Faucet (Cold)	Potable	2/12/2021	17	Removed From Service, Pending Remediation
LVT-1907	1097	Room 401	Spray Nozzle	Non-Potable	2/12/2021	160	Placarded for Non-Drinking Use Until Remediated
LVT-1908	1097C	Room 401 Freezer Room Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	93	Placarded for Non-Drinking Use Until Remediated
LVT-1911	1098B1	Superintendent Office Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	3.7	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1912	1098A1	Superintendent Conference Room Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	41	Placarded for Non-Drinking Use Until Remediated
LVT-1913	1098A1	Superintendent Conference Room Bathroom	Kitchen Faucet (Cold)	Potable	2/12/2021	6.8	Result Below Action Level Continue O&M
LVT-1914	1099	Corridor Lobby To Room 401	Water Fountain-No Chiller	Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-1916	1027	Ladies Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	11	Result Below Action Level Continue O&M
LVT-1918	1040A1	Gym Office Bathroom	Bathroom Faucet	Non-Potable	2/12/2021	14	Result Below Action Level Continue O&M
LVT-2015	N/A	Exterior	Hand Wash Only	Non-Potable	2/12/2021	OOS	Testing Required Prior to Return to Service
LVT-2244	1026	Corridor Rooms Ladies room To 111	Bottled Water Dispenser	Potable	2/12/2021	1.3	Result Below Action Level Continue O&M
LVT-2245	1041	Corridor Outside Gymnasium	Bottled Water Dispenser	Potable	2/12/2021	1.1	Result Below Action Level Continue O&M

Little Red School House

LVT-1400	1002	3 Year Old Classroom	Classroom Faucet	Non-Potable	3/4/2021	2.2	Result Below Action Level Continue O&M
LVT-1401	1002A	3 Year Old Classroom Closet	Bathroom Faucet	Non-Potable	3/4/2021	1.3	Result Below Action Level Continue O&M
LVT-1402	1001	2 Year Old Classroom	Classroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1403	1001	2 Year Old Classroom	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1404	1001A	2 Year Old Classroom Closet	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1405	1002	3 Year Old Classroom	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-1406	1000	Main Entrance Corridor	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1407	1000	Main Entrance Corridor	Bottle Fill Station	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1408	1003	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1409	1005	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1410	1007A	Office Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	3.7	Result Below Action Level Continue O&M

New Building next to Transportation Office

LVT-1442	1000	Common Area	Kitchen Faucet (Cold)	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1443	1000	Common Area	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1444	1000A	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	3.1	Result Below Action Level Continue O&M
LVT-1445	1000A	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1446	1000B	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-1447	1000B	Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Northside Elementary School

LVT-0671	0001	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0672	0001D	Cafeteria Bathroom Vestibule	Bathroom Faucet	Non-Potable	3/9/2021	3.8	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0673	0001B	Cafeteria Bathroom Boys	Bathroom Faucet	Non-Potable	3/9/2021	12	Result Below Action Level Continue O&M
LVT-0674	0001C	Cafeteria Bathroom Girls	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0675	0001A	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	150	Removed From Service, Pending Remediation
LVT-0676	0001A	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	43	Removed From Service, Pending Remediation
LVT-0677	0001A	Kitchen	Kitchen Service Area	Potable	3/9/2021	100	Removed From Service, Pending Remediation
LVT-0678	1048C	Nurse Closet Adjacent Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0680	1052	101	Classroom Faucet	Non-Potable	3/9/2021	1.8	Result Below Action Level Continue O&M
LVT-0681	1056	103C (Interior Walls Removed)	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0682	1059	105	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0683	1059	105	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0684	1059A	105 Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	2.7	Result Below Action Level Continue O&M
LVT-0686	1060	106A	Classroom Faucet	Non-Potable	3/9/2021	1.8	Result Below Action Level Continue O&M
LVT-0687	N/A New Construction	Room 107	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0688	N/A New Construction	Room 107	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0689	N/A New Construction	Room 107 Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0690	N/A New Construction	Room 108	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0691	N/A New Construction	Room 108	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0692	N/A New Construction	Room 108 Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0693	1057	104	Classroom Faucet	Non-Potable	3/9/2021	2.1	Result Below Action Level Continue O&M
LVT-0694	1057A	104 Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	3.4	Result Below Action Level Continue O&M
LVT-0695	1058	Corridor 100 to 103	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0696	1053	102	Classroom Faucet	Non-Potable	3/9/2021	2.2	Result Below Action Level Continue O&M
LVT-0697	1063	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	4.1	Result Below Action Level Continue O&M
LVT-0699	1063	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	2.2	Result Below Action Level Continue O&M
LVT-0701	1063	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.7	Result Below Action Level Continue O&M
LVT-0703	1063	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.6	Result Below Action Level Continue O&M
LVT-0708	1065	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0710	1065	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0712	1065	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.8	Result Below Action Level Continue O&M
LVT-0714	1065	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	2.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0716	1067	207	Classroom Faucet	Non-Potable	3/9/2021	1.8	Result Below Action Level Continue O&M
LVT-0717	1068	209	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0718	1070	211	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0719	1074	213	Classroom Faucet	Non-Potable	3/9/2021	6.4	Result Below Action Level Continue O&M
LVT-0720	1073	Art Room 214	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0721	1072	212	Classroom Faucet	Non-Potable	3/9/2021	26	Placarded for Non-Drinking Use Until Remediated
LVT-0722	1076	Corridor 212 To Custodial Closet	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0723	1071	210	Classroom Faucet	Non-Potable	3/9/2021	1.3	Result Below Action Level Continue O&M
LVT-0724	1069	208	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0725	1047C	Main Office Suite Copy Room	Bathroom Faucet	Non-Potable	3/9/2021	1.5	Result Below Action Level Continue O&M
LVT-0727	1018	421	Classroom Faucet	Non-Potable	3/9/2021	7.3	Result Below Action Level Continue O&M
LVT-0728	1021	423	Classroom Faucet	Non-Potable	3/9/2021	3.0	Result Below Action Level Continue O&M
LVT-0729	1023	425	Classroom Faucet	Non-Potable	3/9/2021	11	Result Below Action Level Continue O&M
LVT-0730	1039	531 Faculty Lounge	Kitchen Faucet (Cold)	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0731	1041	533	Classroom Faucet	Non-Potable	3/9/2021	5.2	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0732	1040	532	Classroom Faucet	Non-Potable	3/9/2021	12	Result Below Action Level Continue O&M
LVT-0733	1030	Faculty Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.2	Result Below Action Level Continue O&M
LVT-0735	1029	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.4	Result Below Action Level Continue O&M
LVT-0737	1029	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0739	1029	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0741	1029	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.5	Result Below Action Level Continue O&M
LVT-0746	1027	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-0748	1027	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	20	Placarded for Non-Drinking Use Until Remediated
LVT-0750	1027	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	12	Result Below Action Level Continue O&M
LVT-0752	1027	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	4.5	Result Below Action Level Continue O&M
LVT-0754	1024	426	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0755	1022	424	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0756	1025	Corridor Rooms 421 To 425	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0757	1019	420	Hand Wash Only	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0758	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	2.6	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0760	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0762	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0764	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0769	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	82	Placarded for Non-Drinking Use Until Remediated
LVT-0771	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	12	Result Below Action Level Continue O&M
LVT-0773	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0775	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	3.7	Result Below Action Level Continue O&M
LVT-0777	1005	315	Classroom Faucet	Non-Potable	3/9/2021	1.5	Result Below Action Level Continue O&M
LVT-0778	1013	Corridor Rooms 317 To Music Office	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0779	1008	317	Classroom Faucet	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0780	1011	319A	Classroom Faucet	Non-Potable	3/9/2021	3.6	Result Below Action Level Continue O&M
LVT-0781	1011A	319A Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	8.2	Result Below Action Level Continue O&M
LVT-0783	1010	320A	Classroom Faucet	Non-Potable	3/9/2021	1.3	Result Below Action Level Continue O&M
LVT-0784	1010A	320A Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	6.4	Result Below Action Level Continue O&M
LVT-0786	1009	318	Classroom Faucet	Non-Potable	3/9/2021	23	Placarded for Non-Drinking Use Until Remediated

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0787	1006	316A	Classroom Faucet	Non-Potable	3/9/2021	4.9	Result Below Action Level Continue O&M
LVT-0788	1002A	Music Office Room 314A Kitchenette	Bathroom Faucet	Non-Potable	3/9/2021	13	Result Below Action Level Continue O&M
LVT-0789	1045	Corridor Main Office To Gym	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0790	1045	Corridor Main Office To Gym	Bottle Fill Station	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0791	1001	Men's Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	1.4	Result Below Action Level Continue O&M
LVT-0793	1043	Bathroom Near Library (Women)	Bathroom Faucet	Non-Potable	3/9/2021	5.5	Result Below Action Level Continue O&M
LVT-0795	1047B1	Main Office Principal's Office Bathroom	Bathroom Faucet	Non-Potable	3/9/2021	7.6	Result Below Action Level Continue O&M
LVT-2200	N/A New Construction	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2201	N/A New Construction	Kitchen	Spray Nozzle	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2202	N/A New Construction	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2203	N/A New Construction	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2204	N/A New Construction	Kitchen	Spray Nozzle	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2205	N/A New Construction	Kitchen	Kitchen Faucet (Cold)	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2206	N/A New Construction	Kitchen	Kitchen Non Potable	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2207	N/A New Construction	Serving Area	Kitchen Non Potable	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2208	N/A New Construction	Kitchen	Kitchen Non Potable	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2209	N/A New Construction	Cafeteria	Hand Wash Only	Non-Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2210	N/A New Construction	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2211	N/A New Construction	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2212	N/A New Construction	Cafeteria	Bottle Fill Station	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2269	1048	Nurse Office	Bottled Water Dispenser	Potable	3/9/2021	<3.0 ND	Result Below Action Level Continue O&M

Seaman Neck Middle School

LVT-2103	2000	Room 201	Classroom Faucet	Non-Potable	3/5/2021	1.4	Result Below Action Level Continue O&M
LVT-2104	2001A	Room 203 Classroom	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2105	2005	Room 204	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2106	2016	2nd Floor Corridor	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2107	2004	Room 205	Classroom Faucet	Non-Potable	3/5/2021	1.1	Result Below Action Level Continue O&M
LVT-2108	2006	Girls Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	14	Result Below Action Level Continue O&M
LVT-2109	2006	Girls Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	10	Result Below Action Level Continue O&M
LVT-2110	2006	Girls Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	4.1	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2111	2006	Girls Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.1	Result Below Action Level Continue O&M
LVT-2113	2008	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2	Result Below Action Level Continue O&M
LVT-2115	2008	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.4	Result Below Action Level Continue O&M
LVT-2116	2008	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2117	2008	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.1	Result Below Action Level Continue O&M
LVT-2119	2009A	Room 207 Classroom	Classroom Faucet	Non-Potable	3/5/2021	2.7	Result Below Action Level Continue O&M
LVT-2120	2010	Room 209	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2121	2011	Room 206	Classroom Faucet	Non-Potable	3/5/2021	2.8	Result Below Action Level Continue O&M
LVT-2122	2013A	Room 211 Classroom	Classroom Faucet	Non-Potable	3/5/2021	1.3	Result Below Action Level Continue O&M
LVT-2123	2012	Room 208	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2124	2014	Room 210	Classroom Faucet	Non-Potable	3/5/2021	2.2	Result Below Action Level Continue O&M
LVT-2125	1032A	Room 110 Classroom	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2126	1031A	Room 108 Classroom	Classroom Faucet	Non-Potable	3/5/2021	66	Placarded for Non-Drinking Use Until Remediated
LVT-2127	1030A	Thinking Room 1 Resource Room	Kitchen Faucet (Cold)	Potable	3/5/2021	4.0	Result Below Action Level Continue O&M
LVT-2128	1029	Room 106	Classroom Faucet	Non-Potable	3/5/2021	3.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2129	1028	Room 109	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2130	1026	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	770	Placarded for Non-Drinking Use Until Remediated
LVT-2132	1026	Boys Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	7.7	Result Below Action Level Continue O&M
LVT-2135	1024	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.3	Result Below Action Level Continue O&M
LVT-2137	1024	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2	Result Below Action Level Continue O&M
LVT-2139	1027A	Room 107 Classroom	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2140	1023A	Room 104 Classroom	Classroom Faucet	Non-Potable	3/5/2021	2.2	Result Below Action Level Continue O&M
LVT-2141	1022A	Room 105 Classroom	Classroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2142	1021	Book Storage	Hand Wash Only	Non-Potable	3/5/2021	5.5	Result Below Action Level Continue O&M
LVT-2143	1020	Room 102	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2144	1019	Room 103	Classroom Faucet	Non-Potable	3/5/2021	2.1	Result Below Action Level Continue O&M
LVT-2145	1018A	Room 101 Classroom	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2146	1033	Corridor Rooms 101 To 110	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2147	1012	Corridor Men's Bathroom To Principal's Office	Water Fountain-No Chiller	Potable	3/5/2021	150	Removed From Service, Pending Remediation
LVT-2148	1011	Men's Room	Bathroom Faucet	Non-Potable	3/5/2021	3.2	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2150	1010	Ladies Room	Bathroom Faucet	Non-Potable	3/5/2021	1.2	Result Below Action Level Continue O&M
LVT-2151	1006C	Custodial Office Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2153	1000	Nurse's Office	Nurse's Office Sink	Potable	3/5/2021	13	Result Below Action Level Continue O&M
LVT-2154	1000B	Nurse's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	4.1	Result Below Action Level Continue O&M
LVT-2156	1002B	K2 Kitchen/Classroom	Home Economics Faucet (Cold)	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2157	1003	Shop Room	Classroom Faucet	Non-Potable	3/5/2021	3.3	Result Below Action Level Continue O&M
LVT-2159	1034	Kitchen	Kitchen Non Potable	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2160	1034	Kitchen	Kitchen Faucet (Cold)	Potable	3/5/2021	40	Removed From Service, Pending Remediation
LVT-2161	1034	Kitchen	Kitchen Faucet (Cold)	Potable	3/5/2021	470	Removed From Service, Pending Remediation
LVT-2162	1034	Kitchen	Spray Nozzle	Non-Potable	3/5/2021	3.5	Result Below Action Level Continue O&M
LVT-2163	1034C	Kitchen Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.3	Result Below Action Level Continue O&M
LVT-2164	1035	Cafeteria	Water Cooler	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2165	1036	Faculty Room	Kitchen Faucet (Cold)	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2166	1037	Ladies Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.2	Result Below Action Level Continue O&M
LVT-2168	1037	Ladies Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2170	1038	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2171	1052	Room 304	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2172	1051	Room 302	Home Economics Faucet (Cold)	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2173	1053A	Room 303 Classroom	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2174	1050	Room 301	Home Economics Faucet (Cold)	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2175	1050	Room 301	Home Economics Faucet (Cold)	Potable	3/5/2021	3.5	Result Below Action Level Continue O&M
LVT-2176	1049	Girls Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2177	1054	Corridor Outside Gymnasium	Water Fountain-No Chiller	Potable	3/5/2021	2.9	Result Below Action Level Continue O&M
LVT-2178	1048	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2180	1054	Corridor Outside Gymnasium	Water Fountain-No Chiller	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2181	1047A1	Physical Education Office Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.5	Result Below Action Level Continue O&M
LVT-2183	1047B	Weight Room	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2184	1047B1	Weight Room Closet	Hand Wash Only	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-2185	1040A1	Physical Therapy Office Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.2	Result Below Action Level Continue O&M
LVT-2187	1040B1	Gym Coach Office Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	3.5	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-2189	1041	Room 305	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M

Summit Lane Elementary School

LVT-0496	0001	Basement Break Room	Kitchen Faucet (Cold)	Potable	3/2/2021	9.6	Result Below Action Level Continue O&M
LVT-0498	1001	Men's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.2	Result Below Action Level Continue O&M
LVT-0500	1003	Women's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	3.2	Result Below Action Level Continue O&M
LVT-0502	1004A	Unisex Bathroom Between Library & Media Center	Bathroom Faucet	Non-Potable	3/2/2021	3.8	Result Below Action Level Continue O&M
LVT-0504	1006	Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.8	Result Below Action Level Continue O&M
LVT-0506	1011	Room 301	Classroom Faucet	Non-Potable	3/2/2021	1.8	Result Below Action Level Continue O&M
LVT-0507	1023	Corridor Library To Room 309	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0508	1013	Room 303	Classroom Faucet	Non-Potable	3/2/2021	48	Placarded for Non-Drinking Use Until Remediated
LVT-0509	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	19	Placarded for Non-Drinking Use Until Remediated
LVT-0511	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	10	Result Below Action Level Continue O&M
LVT-0513	1014	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	6.3	Result Below Action Level Continue O&M
LVT-0519	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	10	Result Below Action Level Continue O&M
LVT-0521	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.5	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0523	1016	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	8.8	Result Below Action Level Continue O&M
LVT-0525	1018	Room 305	Classroom Faucet	Non-Potable	3/2/2021	8.6	Result Below Action Level Continue O&M
LVT-0526	1020	Room 307	Classroom Faucet	Non-Potable	3/2/2021	5.9	Result Below Action Level Continue O&M
LVT-0527	1022	Room 309	Classroom Faucet	Non-Potable	3/2/2021	60	Placarded for Non-Drinking Use Until Remediated
LVT-0528	1021	Room 310	Classroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0529	1019	Room 308	Classroom Faucet	Non-Potable	3/2/2021	5.9	Result Below Action Level Continue O&M
LVT-0530	1017	Room 306	Classroom Faucet	Non-Potable	3/2/2021	7.6	Result Below Action Level Continue O&M
LVT-0531	1012	Room 304	Classroom Faucet	Non-Potable	3/2/2021	6.2	Result Below Action Level Continue O&M
LVT-0532	1010	Room 302	Classroom Faucet	Non-Potable	3/2/2021	9.2	Result Below Action Level Continue O&M
LVT-0533	1008	Room 300	Classroom Faucet	Non-Potable	3/2/2021	9.0	Result Below Action Level Continue O&M
LVT-0534	1026C2A	Boys Physical Education Office Locker Room Area Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	7.0	Result Below Action Level Continue O&M
LVT-0536	1026C1	Boys Physical Education Office/Tool Storage Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	62	Placarded for Non-Drinking Use Until Remediated
LVT-0538	1024	Kitchen	Kitchen Service Area	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0539	1024	Kitchen	Kitchen Non Potable	Non-Potable	3/2/2021	1.2	Result Below Action Level Continue O&M
LVT-0540	1024	Kitchen	Kitchen Faucet (Cold)	Potable	3/2/2021	5.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0541	1024	Kitchen	Kitchen Faucet (Cold)	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0542	1024A	Kitchen Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	110	Placarded for Non-Drinking Use Until Remediated
LVT-0545	1025	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0546	1025	Cafeteria	Bottle Fill Station	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0547	1025	Cafeteria	Hand Wash Only	Non-Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0548	1031	Corridor Outside Gym	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0549	1033	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.3	Result Below Action Level Continue O&M
LVT-0551	1033	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.7	Result Below Action Level Continue O&M
LVT-0553	1033	Girls Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.7	Result Below Action Level Continue O&M
LVT-0558	1035	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	11	Result Below Action Level Continue O&M
LVT-0560	1035	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.3	Result Below Action Level Continue O&M
LVT-0562	1035	Boys Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	8.2	Result Below Action Level Continue O&M
LVT-0564	1037	Room 207 (Interior Walls Removed)	Classroom Faucet	Non-Potable	3/2/2021	3.4	Result Below Action Level Continue O&M
LVT-0565	1039	Room 205	Classroom Faucet	Non-Potable	3/2/2021	5.0	Result Below Action Level Continue O&M
LVT-0566	1041	Room 203	Classroom Faucet	Non-Potable	3/2/2021	5.3	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0567	1045	Room 201	Classroom Faucet	Non-Potable	3/2/2021	5.1	Result Below Action Level Continue O&M
LVT-0568	1045	Room 201	Classroom Faucet	Non-Potable	3/2/2021	3.6	Result Below Action Level Continue O&M
LVT-0569	1045B	Room 201 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.4	Result Below Action Level Continue O&M
LVT-0570	1045	Room 201	Classroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0571	N/A New Construction	Room 199 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0572	N/A New Construction	Room 199	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0573	N/A New Construction	Room 199	Classroom Faucet	Non-Potable	3/2/2021	1.9	Result Below Action Level Continue O&M
LVT-0574	N/A New Construction	Room 200 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.1	Result Below Action Level Continue O&M
LVT-0575	N/A New Construction	Room 200	Classroom Faucet	Non-Potable	3/2/2021	1	Result Below Action Level Continue O&M
LVT-0576	N/A New Construction	Room 200	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0577	1046	Room 202	Classroom Faucet	Non-Potable	3/2/2021	3.6	Result Below Action Level Continue O&M
LVT-0578	1046A	Room 202 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.7	Result Below Action Level Continue O&M
LVT-0579	1042	Room 204	Classroom Faucet	Non-Potable	3/2/2021	2.3	Result Below Action Level Continue O&M
LVT-0580	1040	Room 206	Classroom Faucet	Non-Potable	3/2/2021	6.8	Result Below Action Level Continue O&M
LVT-0581	1047	Corridor 200 Wing	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0582	1038	Room 208	Classroom Faucet	Non-Potable	3/2/2021	6.7	Result Below Action Level Continue O&M
LVT-0583	1036	Room 210	Classroom Faucet	Non-Potable	3/2/2021	1.2	Result Below Action Level Continue O&M
LVT-0584	1032C1	Psychologist Office Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	16	Placarded for Non-Drinking Use Until Remediated
LVT-0585	1031	Corridor Outside Gym	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0586	1031	Corridor Outside Gym	Bottle Fill Station	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0587	1032B1	Social Worker Copy Room Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.4	Result Below Action Level Continue O&M
LVT-0589	1028	Men's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	2.9	Result Below Action Level Continue O&M
LVT-0591	1027	Women's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	3.3	Result Below Action Level Continue O&M
LVT-0593	1027	Women's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	6.9	Result Below Action Level Continue O&M
LVT-0596	1049B	Room 115 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	26	Placarded for Non-Drinking Use Until Remediated
LVT-0597	1048	Room 117	Hand Wash Only	Non-Potable	3/2/2021	2.6	Result Below Action Level Continue O&M
LVT-0598	1026B2	Gym Music Room 116 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	7.6	Result Below Action Level Continue O&M
LVT-0600	1026B1A	Gym Music Room 116 Office Bathroom (Former Locker Room Office Bathroom)	Bathroom Faucet	Non-Potable	3/2/2021	25	Placarded for Non-Drinking Use Until Remediated
LVT-0602	1054	Women's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	13	Result Below Action Level Continue O&M
LVT-0604	1068	Corridor Room 101 To Server Room	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0605	1055	Women's Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	9.3	Result Below Action Level Continue O&M
LVT-0607	1056	Faculty Room	Kitchen Faucet (Cold)	Potable	3/2/2021	2	Result Below Action Level Continue O&M
LVT-0608	1056	Faculty Room	Spray Nozzle	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0609	1058A	Room 108 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	3.9	Result Below Action Level Continue O&M
LVT-0611	1060	Room 106	Classroom Faucet	Non-Potable	3/2/2021	7.4	Result Below Action Level Continue O&M
LVT-0612	1060A	Room 106 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	120	Placarded for Non-Drinking Use Until Remediated
LVT-0614	1062	Room 104	Classroom Faucet	Non-Potable	3/2/2021	1.1	Result Below Action Level Continue O&M
LVT-0615	1062A	Room 104 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.7	Result Below Action Level Continue O&M
LVT-0617	1064	Room 102	Classroom Faucet	Non-Potable	3/2/2021	14	Result Below Action Level Continue O&M
LVT-0618	1064A	Room 102 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	3	Result Below Action Level Continue O&M
LVT-0619	1066	Room 100	Classroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0620	1066A	Room 100 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.9	Result Below Action Level Continue O&M
LVT-0621	1066	Room 100	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0622	N/A New Construction	Room 98	Classroom Faucet	Non-Potable	3/2/2021	6.1	Result Below Action Level Continue O&M
LVT-0623	N/A New Construction	Room 98	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0624	N/A New Construction	Room 98 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	6.5	Result Below Action Level Continue O&M
LVT-0625	N/A New Construction	Room 96 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.6	Result Below Action Level Continue O&M
LVT-0626	N/A New Construction	Room 96	Classroom Faucet	Non-Potable	3/2/2021	3.1	Result Below Action Level Continue O&M
LVT-0627	N/A New Construction	Room 96	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0628	N/A New Construction	Room 97	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0629	N/A New Construction	Room 97	Classroom Faucet	Non-Potable	3/2/2021	4.5	Result Below Action Level Continue O&M
LVT-0630	N/A New Construction	Room 97 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	4.1	Result Below Action Level Continue O&M
LVT-0631	N/A New Construction	Faculty Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0632	N/A New Construction	Room 99	Classroom Faucet	Non-Potable	3/2/2021	1.4	Result Below Action Level Continue O&M
LVT-0633	N/A New Construction	Room 99	Water Fountain-No Chiller	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0634	N/A New Construction	Room 99 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	2.2	Result Below Action Level Continue O&M
LVT-0635	1067A	Room 101 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0636	1067	Room 101	Classroom Faucet	Non-Potable	3/2/2021	13	Result Below Action Level Continue O&M
LVT-0637	1065	Room 103	Classroom Faucet	Non-Potable	3/2/2021	12	Result Below Action Level Continue O&M
LVT-0638	1065A	Room 103 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	6.6	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0640	1063	Room 105	Classroom Faucet	Non-Potable	3/2/2021	7.9	Result Below Action Level Continue O&M
LVT-0641	1063A	Room 105 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	8.2	Result Below Action Level Continue O&M
LVT-0643	1061	Room 107	Classroom Faucet	Non-Potable	3/2/2021	4.4	Result Below Action Level Continue O&M
LVT-0644	1061A	Room 107 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.9	Result Below Action Level Continue O&M
LVT-0646	1059	Room 109	Classroom Faucet	Non-Potable	3/2/2021	6.2	Result Below Action Level Continue O&M
LVT-0647	1059A	Room 109 Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	7.7	Result Below Action Level Continue O&M
LVT-0649	1057A	Nurses Office	Nurse's Office Sink	Potable	3/2/2021	5.2	Result Below Action Level Continue O&M
LVT-0650	1057A1	Nurses Office Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	55	Placarded for Non-Drinking Use Until Remediated
LVT-0652	1053C	Main Office Corridor Closet	Kitchen Non Potable	Non-Potable	3/2/2021	21	Placarded for Non-Drinking Use Until Remediated
LVT-0653	1053B	Main Office Side Corridor Bathroom	Bathroom Faucet	Non-Potable	3/2/2021	1.7	Result Below Action Level Continue O&M
LVT-2265	1023	Corridor Library To Room 309	Bottled Water Dispenser	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2266	1047	Corridor 200 Wing	Bottled Water Dispenser	Potable	3/2/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-2267	1057C	Large Sick Room	Bottled Water Dispenser	Potable	3/2/2021	1.6	Result Below Action Level Continue O&M

Wisdom Lane Middle School

LVT-0810	1003A	Room 103A Office 1	Classroom Faucet	Non-Potable	3/3/2021	6.5	Result Below Action Level Continue O&M
----------	-------	--------------------	------------------	-------------	----------	-----	--

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0811	1005	Room 105	Classroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0812	1007	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	5.1	Result Below Action Level Continue O&M
LVT-0814	1007	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0816	1007	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	1.1	Result Below Action Level Continue O&M
LVT-0818	1007	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	1.5	Result Below Action Level Continue O&M
LVT-0823	1009	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	1.4	Result Below Action Level Continue O&M
LVT-0825	1009	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0827	1009	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	5.3	Result Below Action Level Continue O&M
LVT-0829	1009	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	4.8	Result Below Action Level Continue O&M
LVT-0831	1027	Boys Room	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0833	1027	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	5.2	Result Below Action Level Continue O&M
LVT-0835	1027	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	5.5	Result Below Action Level Continue O&M
LVT-0837	1027	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	5.2	Result Below Action Level Continue O&M
LVT-0842	1029	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	9.7	Result Below Action Level Continue O&M
LVT-0844	1029	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0846	1029	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	5.1	Result Below Action Level Continue O&M
LVT-0848	1029	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	6.2	Result Below Action Level Continue O&M
LVT-0850	1032	Room 121	Classroom Faucet	Non-Potable	3/3/2021	190	Placarded for Non-Drinking Use Until Remediated
LVT-0851	1033	Room 122	Classroom Faucet	Non-Potable	3/3/2021	24	Placarded for Non-Drinking Use Until Remediated
LVT-0852	N/A New Construction	Instrument Storage Room Right	Hand Wash Only	Non-Potable	3/3/2021	5.5	Result Below Action Level Continue O&M
LVT-0853	N/A New Construction	Instrument Storage Room Left	Hand Wash Only	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0854	N/A New Construction	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	15	Result Below Action Level Continue O&M
LVT-0855	N/A New Construction	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0857	N/A New Construction	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0858	N/A New Construction	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	8.8	Result Below Action Level Continue O&M
LVT-0860	0016	Basement B17	Home Economics Faucet (Cold)	Potable	3/3/2021	49	Removed From Service, Pending Remediation
LVT-0861	0016	Basement B17	Home Economics Faucet (Cold)	Potable	3/3/2021	18	Removed From Service, Pending Remediation
LVT-0862	0016	Basement B17	Home Economics Faucet (Cold)	Potable	3/3/2021	26	Removed From Service, Pending Remediation
LVT-0863	0015	Basement Room B15	Home Economics Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0864	0015	Basement Room B15	Home Economics Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0865	0015	Basement Room B15	Home Economics Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0866	0015	Basement Room B15	Home Economics Faucet (Cold)	Potable	3/3/2021	1.9	Result Below Action Level Continue O&M
LVT-0867	0015	Basement Room B15	Home Economics Faucet (Cold)	Potable	3/3/2021	6.5	Result Below Action Level Continue O&M
LVT-0871	0013	Basement Shop Room B13	Classroom Faucet	Non-Potable	3/3/2021	11	Result Below Action Level Continue O&M
LVT-0875	1048A	Boiler Room Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0877	N/A New Construction	Corridor	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0878	N/A New Construction	Corridor	Bottle Fill Station	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0885	N/A New Construction	Library	Hand Wash Only	Non-Potable	3/3/2021	2.3	Result Below Action Level Continue O&M
LVT-0899	N/A New Construction	Room 332	Classroom Faucet	Non-Potable	3/3/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-0900	N/A New Construction	Room 332	Classroom Faucet	Non-Potable	3/3/2021	30	Placarded for Non-Drinking Use Until Remediated
LVT-0901	1086	Room 330	Classroom Faucet	Non-Potable	3/3/2021	110	Placarded for Non-Drinking Use Until Remediated
LVT-0902	1086	Room 330	Classroom Faucet	Non-Potable	3/3/2021	13	Result Below Action Level Continue O&M
LVT-0903	1086	Room 330	Classroom Faucet	Non-Potable	3/3/2021	54	Placarded for Non-Drinking Use Until Remediated
LVT-0907	1079	Room 321	Classroom Faucet	Non-Potable	3/3/2021	4.5	Result Below Action Level Continue O&M
LVT-0914	1075	Girls Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.7	Result Below Action Level Continue O&M


Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0916	1075	Girls Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	4.3	Result Below Action Level Continue O&M
LVT-0918	1075	Girls Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	4.1	Result Below Action Level Continue O&M
LVT-0920	1073	Boys Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	7.7	Result Below Action Level Continue O&M
LVT-0922	1073	Boys Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.1	Result Below Action Level Continue O&M
LVT-0924	1073	Boys Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.4	Result Below Action Level Continue O&M
LVT-0926	1073	Boys Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.1	Result Below Action Level Continue O&M
LVT-0930	1088A	Girls Coach Office Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	8.0	Result Below Action Level Continue O&M
LVT-0932	1072	Room 317	Classroom Faucet	Non-Potable	3/3/2021	39	Placarded for Non-Drinking Use Until Remediated
LVT-0933	1072	Room 317	Classroom Faucet	Non-Potable	3/3/2021	33	Placarded for Non-Drinking Use Until Remediated
LVT-0934	1089	Girls Locker Room	Bathroom Faucet	Non-Potable	3/3/2021	1.3	Result Below Action Level Continue O&M
LVT-0935	1089	Girls Locker Room	Bathroom Faucet	Non-Potable	3/3/2021	7.6	Result Below Action Level Continue O&M
LVT-0936	1089	Girls Locker Room	Water Cooler	Potable	3/3/2021	2.2	Result Below Action Level Continue O&M
LVT-0938	1092A	Boys Phys. Ed. Office Bathroom	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Before Return to Service
LVT-0940	1091	Boys Locker Room	Bathroom Faucet	Non-Potable	3/3/2021	7.1	Result Below Action Level Continue O&M
LVT-0942	1091	Boys Locker Room	Bathroom Faucet	Non-Potable	3/3/2021	2.4	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0944	1047B1	Conference Room Closet	Kitchen Faucet (Cold)	Potable	3/3/2021	2.3	Result Below Action Level Continue O&M
LVT-0945	1050	Ladies Bathroom Room 315B	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0947	1050	Ladies Bathroom Room 315B	Bathroom Faucet	Non-Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0949	1052	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1	Result Below Action Level Continue O&M
LVT-0951	1056	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	8.1	Result Below Action Level Continue O&M
LVT-0953	1056	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	8.8	Result Below Action Level Continue O&M
LVT-0955	1056	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.6	Result Below Action Level Continue O&M
LVT-0957	1056	Ladies Faculty Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.2	Result Below Action Level Continue O&M
LVT-0962	1058	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	18	Placarded for Non-Drinking Use Until Remediated
LVT-0964	1058	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	10	Result Below Action Level Continue O&M
LVT-0966	1058	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	13	Result Below Action Level Continue O&M
LVT-0968	1070	Room 310	Hand Wash Only	Non-Potable	3/3/2021	3.4	Result Below Action Level Continue O&M
LVT-0971	1065	Room 302	Classroom Faucet	Non-Potable	3/3/2021	11	Result Below Action Level Continue O&M
LVT-0972	1064	Room 300	Classroom Faucet	Non-Potable	3/3/2021	56	Placarded for Non-Drinking Use Until Remediated
LVT-0973	1049	Corridor Boiler Room To Room 200	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0974	1049	Corridor Boiler Room To Room 200	Bottle Fill Station	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0975	1044A	Room 208 Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	70	Placarded for Non-Drinking Use Until Remediated
LVT-0977	N/A New Construction	Cafeteria Add On	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0978	N/A New Construction	Cafeteria Add On	Bottle Fill Station	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0979	N/A New Construction	Girls Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0983	N/A New Construction	Boys Room	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0984	1047	Cafeteria	Water Cooler	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-0988	1041	Faculty Room 204	Kitchen Faucet (Cold)	Potable	3/3/2021	2.9	Result Below Action Level Continue O&M
LVT-0989	1046	Kitchen/Room 209	Kitchen Faucet (Cold)	Potable	3/3/2021	2.9	Result Below Action Level Continue O&M
LVT-0990	1046	Kitchen/Room 209	Kitchen Faucet (Cold)	Potable	3/3/2021	2	Result Below Action Level Continue O&M
LVT-0991	1046	Kitchen/Room 209	Kitchen Non Potable	Non-Potable	3/3/2021	2	Result Below Action Level Continue O&M
LVT-0992	1046	Kitchen/Room 209	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0993	1046	Kitchen/Room 209	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
LVT-0994	1046C1	Kitchen Closet Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	13	Result Below Action Level Continue O&M
LVT-0998	1046F	Kitchen Serving Area	Kitchen Non Potable	Non-Potable	3/3/2021	1.1	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
LVT-0999	1039	Nurses Office	Nurse's Office Sink	Potable	3/3/2021	6.5	Result Below Action Level Continue O&M
LVT-1000	1039	Nurses Office	Nurse's Office Sink	Potable	4/19/2021	OOS	Testing Required Prior to Return to Service
LVT-1001	1039A	Nurses Office Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.2	Result Below Action Level Continue O&M
LVT-1004	1037	Ladies Room	Bathroom Faucet	Non-Potable	3/3/2021	1.2	Result Below Action Level Continue O&M
LVT-1006	1037	Ladies Room	Bathroom Faucet	Non-Potable	3/3/2021	1.7	Result Below Action Level Continue O&M
LVT-1008	1036	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.4	Result Below Action Level Continue O&M
LVT-2268	1041	Faculty Room 204	Bottled Water Dispenser	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M

Attachment 2:
Chain of Custody
&
Laboratory Analysis



J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Abbey Lane School
ALS

062104332

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1035	CR	1002	Room 202	CF	3/6/2021	5:22:00 AM
LVT-1036	BR	1002A	Room 202 Bathroom	BF	3/6/2021	5:22:00 AM
LVT-1037	CR	1001	Room 201	CF	3/6/2021	5:23:00 AM
LVT-1038	CR	1003	Room 204	CF	3/6/2021	5:24:00 AM
LVT-1039	CR	1004	Room 203	CF	3/6/2021	5:25:00 AM
LVT-1040	CR	1005	Room 206	CF	3/6/2021	5:27:00 AM
LVT-1041	CR	1006	Room 205	CF	3/6/2021	5:29:00 AM
LVT-1042	CR	1007	Room 208	CF	3/6/2021	5:30:00 AM
LVT-1043	BR	1008	Girl's Bathroom	BF	3/6/2021	5:33:00 AM
LVT-1045	BR	1008	Girl's Bathroom	BF	3/6/2021	5:33:00 AM
LVT-1047	BR	1008	Girl's Bathroom	BF	3/6/2021	5:33:00 AM
LVT-1049	BR	1008	Girl's Bathroom	BF	3/6/2021	5:33:00 AM
LVT-1052	BR	1010	Boy's Bathroom	BF	3/6/2021	5:36:00 AM
LVT-1054	BR	1010	Boy's Bathroom	BF	3/6/2021	5:36:00 AM
LVT-1056	BR	1010	Boy's Bathroom	BF	3/6/2021	5:36:00 AM
LVT-1058	BR	1010	Boy's Bathroom	BF	3/6/2021	5:36:00 AM
LVT-1060	CR	1012	Room 210	CF	3/6/2021	5:38:00 AM
LVT-1061	CR	1013	Room 207	CF	3/6/2021	5:39:00 AM

Building Address
239 Gardiners Avenue
Levittown, NY 11756

Pb 200.5-

A. Jany 03/18/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*


Signature: *[Signature]*

Samplers Name: *A. Jany*

Samplers Signature: *[Signature]*

JCB Project Manager: *Meylan GWTM*

RECEIVED
ENVIRONMENTAL ANALYTICAL
LABORATORY
FLA, NY
2/18/21
P 4:20



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Abbey Lane School

ALS

062104332

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1062	CR	1014	Room 212	CF	3/6/2021	5:41:00 AM
LVT-1063	BR	1016	Women's Room	BF	3/6/2021	5:42:00 AM
LVT-1066	BR	1017	Men's Bathroom	BF	3/6/2021	5:43:00 AM
LVT-1068	BR	1022A	Room Across from Kitchen Bathroom	BF	3/6/2021	5:48:00 AM
LVT-1071	BR	1020	Kitchen Bathroom	BF	3/6/2021	5:50:00 AM
LVT-1073	BR	1053	Bathroom By Main Entrance	BF	3/6/2021	5:52:00 AM
LVT-1075	CR	1026	Room 302	CF	3/6/2021	5:56:00 AM
LVT-1077	BR	1026A	Room 302 Bathroom	BF	3/6/2021	5:56:00 AM
LVT-1079	CR	1025	Room 301	CF	3/6/2021	5:59:00 AM
LVT-1081	BR	1025C	Room 301 Bathroom	BF	3/6/2021	5:59:00 AM
LVT-1083	CR	1027	Room 303	CF	3/6/2021	6:00:00 AM
LVT-1086	CR	1028	Room 304	CF	3/6/2021	6:03:00 AM
LVT-1087	CR	1029	Room 305	CF	3/6/2021	6:05:00 AM
LVT-1088	CR	1030	Room 306	CF	3/6/2021	6:06:00 AM
LVT-1089	BR	1031	Boy's Bathroom	BF	3/6/2021	6:08:00 AM
LVT-1091	BR	1031	Boy's Bathroom	BF	3/6/2021	6:08:00 AM
LVT-1093	BR	1031	Boy's Bathroom	BF	3/6/2021	6:08:00 AM
LVT-1095	BR	1031	Boy's Bathroom	BF	3/6/2021	6:08:00 AM

RECEIVED
ENVIRONMENTAL, INC.
CARLE PLACE NY
3/11/21
11:18 AM

Building Address
239 Gardiners Avenue
Levittown, NY 11756

Pb 200.5 -
As Jimmy 3/18/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Carle

Samplers Name:

Samplers Signature:

JCB Project Manager:

Alina Castelli
Alina Castelli
Meghan Gwinn



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Abbey Lane School

ALS

062104332

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1099	BR	1033	Girl's Bathroom	BF	3/6/2021	6:11:00 AM
LVT-1101	BR	1033	Girl's Bathroom	BF	3/6/2021	6:11:00 AM
LVT-1103	BR	1033	Girl's Bathroom	BF	3/6/2021	6:11:00 AM
LVT-1105	BR	1033	Girl's Bathroom	BF	3/6/2021	6:11:00 AM
LVT-1107	CR	1035	Room 308	CF	3/6/2021	6:14:00 AM
LVT-1108	CR	1034	Room 307	CF	3/6/2021	6:15:00 AM
LVT-1109	CR	1036	Room 310	CF	3/6/2021	6:16:00 AM
LVT-1110	CR	1039	Room 311	CF	3/6/2021	6:17:00 AM
LVT-1111	CR	1040	Room 314	CF	3/6/2021	6:21:00 AM
LVT-1112	BR	1041A	Nurse Bathroom	BF	3/6/2021	6:22:00 AM
LVT-1114	BR	1047B	Principal Bathroom	BF	3/6/2021	6:40:00 AM
LVT-1117	CA	1058	All Purpose Room	WF	3/6/2021	6:21:00 AM
LVT-1118	CA	1058	All Purpose Room	HW	3/6/2021	6:28:00 AM
LVT-1119	KI	1021	Kitchen	SA	3/6/2021	6:31:00 AM
LVT-1120	KI	1021	Kitchen	KC	3/6/2021	6:32:00 AM
LVT-1121	KI	1021	Kitchen	KC	3/6/2021	6:35:00 AM
LVT-1122	KI	1021	Kitchen	SN	3/6/2021	6:35:00 AM
LVT-1123	KI	1021	Kitchen	KC	3/6/2021	6:36:00 AM

Building Address
239 Gardiners Avenue
Levittown, NY 11756

Pb 200.5 -

A. Long 03/18/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Handwritten signature]

Samplers Name: *A. M. Costello*

Samplers Signature: *[Handwritten signature]*

JCB Project Manager: *Meghan Gwynn*

RECEIVED
ENVIRONMENTAL
LABORATORY
MAR 11 2021
11:00 AM

Order ID: 062104332

Page 3 of 5



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Abbey Lane School
ALS

062104332

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1124	KI	1021	Kitchen	SN	3/6/2021	6:36:00 AM
LVT-1125	LI	1059	Library	HW	3/6/2021	6:42:00 AM
LVT-1126	CR	N/A New Construction	Room 401	CF	3/6/2021	6:45:00 AM
LVT-1130	CR	N/A New Construction	Room 402	CF	3/6/2021	6:47:00 AM
LVT-1132	BR	N/A New Construction	Room 402 Bathroom	BF	3/6/2021	6:47:00 AM
LVT-1134	CR	N/A New Construction	Room 403	CF	3/6/2021	6:50:00 AM
LVT-1136	BR	N/A New Construction	Room 403 Bathroom	BF	3/6/2021	6:50:00 AM
LVT-1138	CR	N/A New Construction	Room 404	CF	3/6/2021	6:52:00 AM
LVT-1140	BR	N/A New Construction	Room 404 Bathroom	BF	3/6/2021	6:52:00 AM
LVT-1142	CR	1068	Room 406	CF	3/6/2021	6:54:00 AM
LVT-1143	BR	1065	Boy's Bathroom	BF	3/6/2021	6:56:00 AM
LVT-1145	BR	1065	Boy's Bathroom	BF	3/6/2021	6:56:00 AM
LVT-1147	BR	1065	Boy's Bathroom	BF	3/6/2021	6:56:00 AM
LVT-1153	BR	1063	Girl's Bathroom	BF	3/6/2021	7:01:00 AM
LVT-1155	BR	1063	Girl's Bathroom	BF	3/6/2021	7:01:00 AM
LVT-1157	BR	1063	Girl's Bathroom	BF	3/6/2021	7:01:00 AM
LVT-1159	BR	1063	Girl's Bathroom	BF	3/6/2021	7:01:00 AM
LVT-1162	FL	1062	Faculty Room 409	KC	3/6/2021	7:02:00 AM

RECEIVED
JCB LABORATORIAL, INC.
CARLE PLACE, NY
2/21/21 4:00 PM

Building Address
239 Gardiners Avenue
Levittown, NY 11756

Pb 200.5 -
[Signature] 03/10/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *A. A. Costa*

Samplers Signature: *[Signature]*

JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

062104332

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Abbey Lane School
ALS

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1163	CR	1060	Room 411	CF	3/6/2021	7:03:00 AM
LVT-1166	BR	1072	Women's Faculty Bathroom 1	BF	3/6/2021	7:05:00 AM
LVT-1168	BR	1073	Women's Bathroom 2	BF	3/6/2021	7:07:00 AM
LVT-1172	CR	1077	Art Room 511	CF	3/6/2021	7:10:00 AM
LVT-1173	CR	1077	Art Room 511	CF	3/6/2021	7:10:00 AM
LVT-1175	CR	1082	Room 508	CF	3/6/2021	7:13:00 AM
LVT-1176	BR	1084	Girl's Bathroom	BF	3/6/2021	7:16:00 AM
LVT-1178	BR	1084	Girl's Bathroom	BF	3/6/2021	7:16:00 AM
LVT-1180	BR	1084	Girl's Bathroom	BF	3/6/2021	7:16:00 AM
LVT-1182	BR	1084	Girl's Bathroom	BF	3/6/2021	7:16:00 AM
LVT-1188	BR	1086	Boy's Bathroom	BF	3/6/2021	7:19:00 AM
LVT-1190	BR	1086	Boy's Bathroom	BF	3/6/2021	7:19:00 AM
LVT-1192	BR	1086	Boy's Bathroom	BF	3/6/2021	7:19:00 AM
LVT-1196	CR	1091	Room 501	CF	3/6/2021	6:21:00 AM

Samples Submitted 86

RECEIVED
ENVIRONMENTAL, INC.
8151
CANTON PLACE, NY
MARCH 11 2021
PM 4:20

Building Address
239 Gardiners Avenue
Levittown, NY 11756

Pb200.5-
A. Young 03/18/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *A. Young 03/18/21*
Samplers Signature: *[Signature]*
JCB Project Manager: *Meghan Gwynn*



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/8/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Abbey Lane School, Levittown Union Free School
District, 239 Gardiners Avenue, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062104332. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1035		3/6/2021	062104332-0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1036		3/6/2021	062104332-0002				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1037		3/6/2021	062104332-0003				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1038		3/6/2021	062104332-0004				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.7	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1039		3/6/2021	062104332-0005				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.6	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1040		3/6/2021	062104332-0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.6	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1041		3/6/2021	062104332-0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1042				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	7.8	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1043				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1045				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1047				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1049				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1052				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1054				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	
Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-1056				3/6/2021		DI	3/18/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1056	Collected:	3/6/2021	Lab ID:	062104332-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1058	Collected:	3/6/2021	Lab ID:	062104332-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1060	Collected:	3/6/2021	Lab ID:	062104332-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1061	Collected:	3/6/2021	Lab ID:	062104332-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.3	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1062	Collected:	3/6/2021	Lab ID:	062104332-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	190	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1063	Collected:	3/6/2021	Lab ID:	062104332-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1066	Collected:	3/6/2021	Lab ID:	062104332-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1068	Collected:	3/6/2021	Lab ID:	062104332-0022	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1068	Collected:	3/6/2021	Lab ID:	062104332-0022	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1071	Collected:	3/6/2021	Lab ID:	062104332-0023	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.7 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1073	Collected:	3/6/2021	Lab ID:	062104332-0024	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1075	Collected:	3/6/2021	Lab ID:	062104332-0025	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1077	Collected:	3/6/2021	Lab ID:	062104332-0026	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	430 D	30 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1079	Collected:	3/6/2021	Lab ID:	062104332-0027	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.3 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1081	Collected:	3/6/2021	Lab ID:	062104332-0028	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1083	Collected:	3/6/2021	Lab ID:	062104332-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.8	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1086	Collected:	3/6/2021	Lab ID:	062104332-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.4	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1087	Collected:	3/6/2021	Lab ID:	062104332-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1088	Collected:	3/6/2021	Lab ID:	062104332-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	55	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1089	Collected:	3/6/2021	Lab ID:	062104332-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.5	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1091	Collected:	3/6/2021	Lab ID:	062104332-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1093	Collected:	3/6/2021	Lab ID:	062104332-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1095	Collected:	3/6/2021	Lab ID:	062104332-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-1095				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0036		
200.5	Lead	5.3	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1099				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0037		
200.5	Lead	2.8 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-1101				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0038		
200.5	Lead	4.7	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1103				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0039		
200.5	Lead	17	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1105				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0040		
200.5	Lead	3.0	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1107				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0041		
200.5	Lead	6.8	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1108				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0042		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1109				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0043		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1109	Collected:	3/6/2021	Lab ID:	062104332-0043	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	20	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1110	Collected:	3/6/2021	Lab ID:	062104332-0044	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1111	Collected:	3/6/2021	Lab ID:	062104332-0045	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1112	Collected:	3/6/2021	Lab ID:	062104332-0046	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1114	Collected:	3/6/2021	Lab ID:	062104332-0047	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1117	Collected:	3/6/2021	Lab ID:	062104332-0048	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1118	Collected:	3/6/2021	Lab ID:	062104332-0049	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	19	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1119	Collected:	3/6/2021	Lab ID:	062104332-0050	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1119	Collected:	3/6/2021	Lab ID:	062104332-0050	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	26	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1120	Collected:	3/6/2021	Lab ID:	062104332-0051	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.1	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1121	Collected:	3/6/2021	Lab ID:	062104332-0052	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.8 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1122	Collected:	3/6/2021	Lab ID:	062104332-0053	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1123	Collected:	3/6/2021	Lab ID:	062104332-0054	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1124	Collected:	3/6/2021	Lab ID:	062104332-0055	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1125	Collected:	3/6/2021	Lab ID:	062104332-0056	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-1126				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0057		
200.5	Lead	4.1	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1130				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0058		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1132				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0059		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1134				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0060		
200.5	Lead	3.3	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1136				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0061		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1138				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0062		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1140				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0063		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i> LVT-1142				<i>Collected:</i> 3/6/2021	<i>Lab ID:</i> 062104332-0064		
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1142		3/6/2021	062104332-0064				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.8	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1143		3/6/2021	062104332-0065				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.5 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1145		3/6/2021	062104332-0066				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1147		3/6/2021	062104332-0067				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.0 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1153		3/6/2021	062104332-0068				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	15	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1155		3/6/2021	062104332-0069				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.5 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1157		3/6/2021	062104332-0070				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.6	3.0 µg/L	3/17/2021	DI	3/18/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1159		3/6/2021	062104332-0071				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.6	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1162		3/6/2021	062104332-0072				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1163		3/6/2021	062104332-0073				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	36	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1166		3/6/2021	062104332-0074				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1168		3/6/2021	062104332-0075				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1172		3/6/2021	062104332-0076				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.3	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1173		3/6/2021	062104332-0077				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	28	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1175		3/6/2021	062104332-0078				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1175	Collected:	3/6/2021	Lab ID:	062104332-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1176	Collected:	3/6/2021	Lab ID:	062104332-0079	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.4	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1178	Collected:	3/6/2021	Lab ID:	062104332-0080	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.8	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1180	Collected:	3/6/2021	Lab ID:	062104332-0081	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1182	Collected:	3/6/2021	Lab ID:	062104332-0082	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1188	Collected:	3/6/2021	Lab ID:	062104332-0083	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.5	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Client Sample Description		LVT-1190	Collected:	3/6/2021	Lab ID:	062104332-0084	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104332
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/8/2021 04:20 PM
 Collected: 3/6/2021

Project: 19-45328, Abbey Lane School, Levittown Union Free School District, 239 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-1192 **Collected:** 3/6/2021 **Lab ID:** 062104332-0085

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	3/17/2021	DI	3/18/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1196 **Collected:** 3/6/2021 **Lab ID:** 062104332-0086

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/17/2021	DI	3/18/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: B&G Office
BGO

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1412	HA	1003	Parts Storage Room	IM	3/4/2021	5:30:00 AM
LVT-1415	FL	1017	Break Room	KC	3/4/2021	5:24:00 AM
LVT-1416	HA	1019	Lobby	WC	3/4/2021	5:25:00 AM
LVT-1417	HA	1019	Lobby	WF	3/4/2021	5:25:00 AM
LVT-1418	KI	1018	Ladies Bathroom Entrance	KC	3/4/2021	5:28:00 AM
LVT-1419	KI	1018	Ladies Bathroom Entrance	SN	3/4/2021	5:29:00 AM
LVT-1420	BR	1018A	Ladies Bathroom	BF	3/4/2021	5:30:00 AM
LVT-1421	BR	1017C	Men's Bathroom	BF	3/4/2021	5:25:00 AM
LVT-1422	BR	1017C	Men's Bathroom	BF	3/4/2021	5:26:00 AM
LVT-1423	BR	1017C	Men's Bathroom	BF	3/4/2021	5:27:00 AM

Samples Submitted 10

062104097

21 MAR -4 PM 1:13
LABORATORY

Building Address
850 Seaman Neck Road
Levittown, NY 11756

Pb 200.5 -
A. Lamy 03/09/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Handwritten Signature]

Samplers Name: Alina Castelluzzo

Samplers Signature: Alina Castelluzzo

JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, B&G Office, Levittown Union Free School District, 850
Seaman Neck Road, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062104097. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104097
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:13 PM
 Collected: 3/4/2021

Project: 19-45328, B&G Office, Levittown Union Free School District, 850 Seaman Neck Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1412	Collected:	3/4/2021	Lab ID:	062104097-0001	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-1415	Collected:	3/4/2021	Lab ID:	062104097-0002	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-1416	Collected:	3/4/2021	Lab ID:	062104097-0003	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-1417	Collected:	3/4/2021	Lab ID:	062104097-0004	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-1418	Collected:	3/4/2021	Lab ID:	062104097-0005	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-1419	Collected:	3/4/2021	Lab ID:	062104097-0006	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1420	Collected:	3/4/2021	Lab ID:	062104097-0007	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104097
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:13 PM
 Collected: 3/4/2021

Project: 19-45328, B&G Office, Levittown Union Free School District, 850 Seaman Neck Road, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-1421 **Collected:** 3/4/2021 **Lab ID:** 062104097-0008

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1422 **Collected:** 3/4/2021 **Lab ID:** 062104097-0009

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1423 **Collected:** 3/4/2021 **Lab ID:** 062104097-0010

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



062104007
Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
 1775 Expressway North Hauppauge, NY 11788
 TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
 Building: B&G Transportation Offices
 BGT

Client:
 Levittown Union Free School District

Retest/New Install
 Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1437	BR	1000A	Bathroom	BF	3/4/2021	5:16:00 AM
LVT-1438	KI	1004	Kitchen	KC	3/4/2021	5:10:00 AM
LVT-1439	BR	2001	Womens Bathroom	BF	3/4/2021	5:12:00 AM

Samples Submitted 3

21 MAR -4 PM 1:12
 ANALYTICAL
 CARLE PLACE, NY

Building Address
 850 Seaman Neck Road
 Levittown, NY 11756

Pb 200.5 -
A. Jiang 03/09/21

Analysis Type: ELAP 200.5 @
 Lab Received: Unique Mckay
 Signature: um 3/4/21 1:12 pm

Samplers Name: Ailing Castelluzzo
 Samplers Signature: Ailing Castelluzzo
 JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

**B & G Transportation Offices, 850 Seaman Neck Road,
Levittown, NY 11756, Levittown Union Free School District, 19-
45328**

The reference number for these samples is EMSL Order #062104007. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104007
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:12 PM
 Collected: 3/4/2021

Project: **B & G Transportation Offices, 850 Seaman Neck Road, Levittown, NY 11756, Levittown Union Free School District, 19-45328**

Analytical Results

Client Sample Description LVT-1437 **Collected:** 3/4/2021 **Lab ID:** 062104007-0001
 Bathroom

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.0	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1438 **Collected:** 3/4/2021 **Lab ID:** 062104007-0002
 Kitchen

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1439 **Collected:** 3/4/2021 **Lab ID:** 062104007-0003
 Womens Bathroom

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	22	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

062104005

JCB #: 19-45328
Building: B&G Bus Garage
BUS

Client:
Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk / Rush 3

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1429	BR	1000A	Locker Room Bathroom	BF	3/4/2021	5:02:00 AM
LVT-1430	BR	1000A	Locker Room Bathroom	BF	3/4/2021	5:02:00 AM
LVT-1432	LR	1000	Locker Room	WC	3/4/2021	5:03:00 AM

Samples Submitted 3

21 MAR -4 PM 1:10
ST ANALYTICAL
CARLE PLACE, NY

Building Address
850 Seaman Neck Road
Levittown, NY 11756

Pb 200.5 -
A. Lung 03/09/21

Analysis Type: ELAP 200.5 (M)
Lab Received: Unique Mckel
Signature: LM 3/4/21 1:10pm

Samplers Name: Aina Castelluzzo
Samplers Signature: Aina Castelluzzo
JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

B & G Bus Garage, 850 Seaman Neck Road, Levittown, NY 11756,
Levittown Union Free School District, 19-45328

The reference number for these samples is EMSL Order #062104005. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104005
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:10 PM
 Collected: 3/4/2021

Project: **B & G Bus Garage, 850 Seaman Neck Road, Levittown, NY 11756, Levittown Union Free School District, 19-45328**

Analytical Results

Client Sample Description LVT-1429 **Collected:** 3/4/2021 **Lab ID:** 062104005-0001
 Locker Room Bathroom

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1430 **Collected:** 3/4/2021 **Lab ID:** 062104005-0002
 Locker Room Bathroom

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-1432 **Collected:** 3/4/2021 **Lab ID:** 062104005-0003
 Locker Room

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0227	BR	2000A	Room 252 Bathroom	BF	2/13/2021	7:19:00 AM
LVT-0231	OF	2021A	Library 234 Magazine Room	KC	2/13/2021	7:46:00 AM
LVT-0233	BR	2014	Men's Faculty Bathroom	BF	2/13/2021	7:25:00 AM
LVT-0235	BR	2014	Men's Faculty Bathroom	BF	2/13/2021	7:25:00 AM
LVT-0237	BR	2014	Men's Faculty Bathroom	BF	2/13/2021	7:25:00 AM
LVT-0239	BR	2016	Ladies Faculty Bathroom	BF	2/13/2021	7:32:00 AM
LVT-0241	BR	2016	Ladies Faculty Bathroom	BF	2/13/2021	7:32:00 AM
LVT-0243	BR	2016	Ladies Faculty Bathroom	BF	2/13/2021	7:32:00 AM
LVT-0245	BR	2016	Ladies Faculty Bathroom	BF	2/13/2021	7:32:00 AM
LVT-0301	CR	2054	Room 212	CF	2/13/2021	7:53:00 AM
LVT-0302	CR	2058	Room 213	CF	2/13/2021	7:56:00 AM
LVT-0304	BR	2063B	Room 207 Bathroom	BF	2/13/2021	8:02:00 AM
LVT-0307	KI	1008	Room 107	KC	2/13/2021	8:28:00 AM
LVT-0309	BR	1008C1	English Chairperson Conference Room Bathroom	BF	2/13/2021	8:28:00 AM
LVT-0311	BR	2065	Ladies Faculty Bathroom	BF	2/13/2021	8:08:00 AM
LVT-0313	BR	2065	Ladies Faculty Bathroom	BF	2/13/2021	8:08:00 AM
LVT-0315	BR	2065	Ladies Faculty Bathroom	BF	2/13/2021	8:08:00 AM
LVT-0317	BR	2065	Ladies Faculty Bathroom	BF	2/13/2021	8:08:00 AM

Building Address
120 Division Avenue
Levittown, NY 11756

Pb200.5 -

A. Lunny 02/26/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

AD
Caule

Samplers Name:

Samplers Signature:

JCB Project Manager:

A. Lina Castelluzzo
Olivia Castelluzzo
Meghan Gwynn



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client: Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0319	BR	2061A	Room 207A Bathroom	BF	2/13/2021	8:05:00 AM
LVT-0321	BR	2061A	Room 207A Bathroom	BF	2/13/2021	8:05:00 AM
LVT-0323	BR	2061A	Room 207A Bathroom	BF	2/13/2021	8:05:00 AM
LVT-0325	BR	1004A	Men's Bathroom	BF	2/13/2021	8:19:00 AM
LVT-0327	BR	1004A	Men's Bathroom	BF	2/13/2021	8:19:00 AM
LVT-0329	BR	1004A	Men's Bathroom	BF	2/13/2021	8:19:00 AM
LVT-0331	BR	1005	Ladies Bathroom	BF	2/13/2021	8:22:00 AM
LVT-0333	BR	1005	Ladies Bathroom	BF	2/13/2021	8:22:00 AM
LVT-0335	BR	1005	Ladies Bathroom	BF	2/13/2021	8:22:00 AM
LVT-0337	BR	1005	Ladies Bathroom	BF	2/13/2021	8:22:00 AM
LVT-0340	CR	1030	Room 129	CF	2/13/2021	8:38:00 AM
LVT-0341	HE	1027	Room 125	EC	2/13/2021	8:32:00 AM
LVT-0342	HE	1027	Room 125	EC	2/13/2021	8:32:00 AM
LVT-0343	HE	1027	Room 125	EC	2/13/2021	8:32:00 AM
LVT-0344	HE	1027	Room 125	EC	2/13/2021	8:32:00 AM
LVT-0346	BR	1033A	Boys Bathroom	BF	2/13/2021	8:40:00 AM
LVT-0348	BR	1033A	Boys Bathroom	BF	2/13/2021	8:40:00 AM
LVT-0350	BR	1033A	Boys Bathroom	BF	2/13/2021	8:40:00 AM

Building Address
120 Division Avenue
Levittown, NY 11756

Pb 206.5 -
A. Luang 02/26/21

Analysis Type: ELAP 200.5

Lab Received: *Daale*

Signature: *[Signature]*

Samplers Name: *Ailing Castanillo*
Samplers Signature: *[Signature]*
JCB Project Manager: *Meghan E Wynn*

062102932

OrderID: 062102932



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

Client: Levittown Union Free School District
Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0353	BR	1035	Girls Bathroom	BF	2/13/2021	8:42:00 AM
LVT-0354	BR	1035	Girls Bathroom	BF	2/13/2021	8:42:00 AM
LVT-0356	BR	1035	Girls Bathroom	BF	2/13/2021	8:42:00 AM
LVT-0358	FL	1038	Room 133 Faculty	KC	2/13/2021	8:45:00 AM
LVT-0360	BR	1038A	Room 133 Faculty Men's Bathroom	BF	2/13/2021	8:47:00 AM
LVT-0362	BR	1038A	Room 133 Faculty Men's Bathroom	BF	2/13/2021	8:47:00 AM
LVT-0364	BR	1038A	Room 133 Faculty Men's Bathroom	BF	2/13/2021	8:47:00 AM
LVT-0366	BR	1038A	Room 133 Faculty Men's Bathroom	BF	2/13/2021	8:47:00 AM
LVT-0368	BR	1038B	Room 133 Faculty Ladies Bathroom	BF	2/13/2021	8:49:00 AM
LVT-0369	BR	1038B	Room 133 Faculty Ladies Bathroom	BF	2/13/2021	8:49:00 AM
LVT-0371	BR	1042	Ladies Bathroom	BF	2/13/2021	8:51:00 AM
LVT-0372	BR	1043	Men's Bathroom	BF	2/13/2021	8:52:00 AM
LVT-0373	KI	1046B2	Main Office Kitchen	KC	2/13/2021	8:59:00 AM
LVT-0374	BR	1046D	Main Office Ladies Bathroom	BF	2/13/2021	8:59:00 AM
LVT-0375	BR	1046E	Main Office Men's Bathroom	BF	2/13/2021	8:59:00 AM
LVT-0376	BR	1046F2	Main Office Principal's Office Bathroom	BF	2/13/2021	9:06:00 AM
LVT-0377	NO	1049	Room 140 Health Office	NS	2/13/2021	9:04:00 AM
LVT-0379	ST	1049D1	Room 140 Back File Room Ice Room	IM	2/13/2021	9:04:00 AM

Page 3 of 8

Building Address
120 Division Avenue
Levittown, NY 11756

Pb 200.5 -
A. Young 02/26/21

Analysis Type: ELAP 200.5
Lab Received: *Facile*
Signature: *[Signature]*

Samplers Name: *A. King Castelluzzo*
Samplers Signature: *[Signature]*
JCB Project Manager: *M. P. King G. W. King*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0380	BR	1051	Boys Bathroom	BF	2/13/2021	9:09:00 AM
LVT-0382	BR	1051	Boys Bathroom	BF	2/13/2021	9:09:00 AM
LVT-0384	BR	1051	Boys Bathroom	BF	2/13/2021	9:09:00 AM
LVT-0389	BR	1053	Girls Bathroom	BF	2/13/2021	9:12:00 AM
LVT-0391	BR	1053	Girls Bathroom	BF	2/13/2021	9:12:00 AM
LVT-0393	BR	1053	Girls Bathroom	BF	2/13/2021	9:12:00 AM
LVT-0395	BR	1053	Girls Bathroom	BF	2/13/2021	9:12:00 AM
LVT-0397	CR	1056	Room 146	CF	2/13/2021	9:15:00 AM
LVT-0398	CR	1057	Life Skills Room 150	CF	2/13/2021	9:17:00 AM
LVT-0399	BR	1057C	Life Skills Room 150 Bathroom	BF	2/13/2021	9:17:00 AM
LVT-0401	BR	1061	Faculty Bathroom	BF	2/13/2021	9:20:00 AM
LVT-0402	CR	1062	Room 151	CF	2/13/2021	9:21:00 AM
LVT-0403	HE	1064	Room 152	EC	2/13/2021	9:23:00 AM
LVT-0404	HE	1064	Room 152	SN	2/13/2021	9:23:00 AM
LVT-0405	HE	1064	Room 152	EC	2/13/2021	9:24:00 AM
LVT-0406	HE	1064	Room 152	SN	2/13/2021	9:24:00 AM
LVT-0407	HE	1064	Room 152	EC	2/13/2021	9:26:00 AM
LVT-0408	BR	1064C	Room 152 Bathroom	BF	2/13/2021	9:26:00 AM

Building Address
120 Division Avenue
Levittown, NY 11756

Pb200.5 -
A. Lunny 02/26/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *A. Lunny*
Samplers Signature: *[Signature]*
JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client:
Levittown Union Free School District

Retest/New Install
Turn Arounds: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0410	CR	1066	Room 155	CF	2/13/2021	9:28:00 AM
LVT-0414	BR	1048D2	Girls Locker Room 2 Shower Area	BF	2/13/2021	7:12:00 AM
LVT-0418	SP	1095C	Room 318 File Storage	HW	2/13/2021	10:05:00 AM
LVT-0421	CA	1069	West Cafeteria (Renovated)	WF	2/13/2021	9:49:00 AM
LVT-0423	CA	1071	East Cafeteria (Renovated)	WF	2/13/2021	9:49:00 AM
LVT-0425	KI	1070	Kitchen (Reconstructed)	KN	2/13/2021	6:29:00 AM
LVT-0426	KI	1070	Kitchen (Reconstructed)	KC	2/13/2021	6:29:00 AM
LVT-0427	KI	1070	Kitchen (Reconstructed)	KN	2/13/2021	6:29:00 AM
LVT-0428	KI	1070	Kitchen (Reconstructed)	KC	2/13/2021	6:32:00 AM
LVT-0429	KI	1070	Kitchen (Reconstructed)	KC	2/13/2021	6:32:00 AM
LVT-0430	KI	1070	Kitchen (Reconstructed)	KC	2/13/2021	6:32:00 AM
LVT-0431	KI	1070	Kitchen (Reconstructed)	SN	2/13/2021	6:34:00 AM
LVT-0433	BR	1070A	Kitchen Office (Interior Wall Removed, Part of New Serving Line)	BF	2/13/2021	6:34:00 AM
LVT-0434	BR	1070B	Kitchen Ladies Bathroom 1 (Renovated)	BF	2/13/2021	6:34:00 AM
LVT-0435	BR	1073A	Custodial Lounge Bathroom	BF	2/13/2021	9:53:00 AM
LVT-0442	SP	1104	Room 313	IM	2/13/2021	6:46:00 AM
LVT-0443	BR	1104A	Room 313 Bathroom	BF	2/13/2021	6:46:00 AM
LVT-0445	HA	1109	Gym/Lobby Corridor	WF	2/13/2021	6:43:00 AM

Page 5 of 8

Order ID: 062102932

Building Address
120 Division Avenue
Levittown, NY 11756

Pb200.5 -
A. Jiang 02/26/21

Analysis Type: ELAP 200.5

Lab Replaced:

Signature:

[Signature]

Samplers Name: Aimee Coyle
Samplers Signature: [Signature]
JCB Project Manager: Meghan B. Williams



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client:
Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0446	BR	1099B	Room 317 Gym Office Bathroom	BF	2/13/2021	10:02:00 AM
LVT-0448	CR	1096	Room 319 Robotics	CF	2/13/2021	10:06:00 AM
LVT-0449	CR	1096	Room 319 Robotics	CF	2/13/2021	10:06:00 AM
LVT-0450	CR	1086	Engineering Room 323	CF	2/13/2021	10:09:00 AM
LVT-0451	CR	1086	Engineering Room 323	CF	2/13/2021	10:09:00 AM
LVT-0452	BR	1083	Men's Faculty Bathroom	BF	2/13/2021	10:11:00 AM
LVT-0454	BR	1083	Men's Faculty Bathroom	BF	2/13/2021	10:11:00 AM
LVT-0457	BR	1081	Ladies Faculty Bathroom	BF	2/13/2021	10:16:00 AM
LVT-0459	BR	1081	Ladies Faculty Bathroom	BF	2/13/2021	10:16:00 AM
LVT-0461	CR	1080	Graphics Room 326	CF	2/13/2021	10:17:00 AM
LVT-0462	CR	1080	Graphics Room 326	CF	2/13/2021	10:17:00 AM
LVT-0464	SP	1078A	Room 328 Dark Room	SN	2/13/2021	10:22:00 AM
LVT-0465	SP	1078A	Room 328 Dark Room	SN	2/13/2021	10:22:00 AM
LVT-0466	SP	1078A	Room 328 Dark Room	CF	2/13/2021	10:22:00 AM
LVT-0467	SP	1078A	Room 328 Dark Room	CF	2/13/2021	10:22:00 AM
LVT-0468	CR	1076	Print Shop	CF	2/13/2021	10:27:00 AM
LVT-0469	CR	1076	Print Shop	CF	2/13/2021	10:27:00 AM
LVT-0470	CR	1075	Room 329	CF	2/13/2021	10:31:00 AM

Building Address
120 Division Avenue
Levittown, NY 11756

Pb200.5 -
A. J. [Signature] 02/25/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *Alicia Castekuzo*

Samplers Signature: *[Signature]*

JCB Project Manager: *Meghan G. [Signature]*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062-1 02932

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0471	CR	1075	Room 329	CF	2/13/2021	10:31:00 AM
LVT-0472	CR	1075	Room 329	CF	2/13/2021	10:31:00 AM
LVT-0473	CR	1075	Room 329	SN	2/13/2021	10:29:00 AM
LVT-0474	CR	1075	Room 329	CF	2/13/2021	10:29:00 AM
LVT-2246	SP	1104	Room 313	HB	2/13/2021	6:49:00 AM
LVT-2247	LR	1104	Room 313	WF	2/13/2021	6:59:00 AM
LVT-2249	BR	1104	Room 313	BF	2/13/2021	7:00:00 AM
LVT-2250	BR	1104	Room 313	BF	2/13/2021	7:02:00 AM
LVT-2251	BR	1104	Room 313	BF	2/13/2021	7:04:00 AM
LVT-2256	HA	2029	Corridor Storage Room to Room 252	BW	2/13/2021	7:30:00 AM
LVT-2257	OF	2031	Room 232	BW	2/13/2021	7:40:00 AM
LVT-2258	HA	2056	Corridor Rooms 212 to 230	BW	2/13/2021	7:49:00 AM
LVT-2259	HA	1037	Corridor Room 114-134	BW	2/13/2021	8:43:00 AM
LVT-2260	HA	1044	Auditorium Lobby	BW	2/13/2021	8:54:00 AM
LVT-2261	HA	1068	Corridor Boys Bathroom to Room 164	BW	2/13/2021	9:13:00 AM
LVT-2262	CR	1066	Room 155	SN	2/13/2021	9:30:00 AM
LVT-2263	CR	1066	Room 155	BW	2/13/2021	9:30:00 AM
LVT-2264	HA	1097	Corridor Rooms 319-324	BW	2/13/2021	10:12:00 AM

Building Address
120 Division Avenue
Levittown, NY 11756

Pb 200.5
A. Young 2/26/21

Analysis Type: ELAP 200.5
Lab Received: *Chaele*
Signature: *[Signature]*

Samplers Name: *A. J. H. COSTA*
Samplers Signature: *[Signature]*
JCB Project Manager: *M. P. H. G. G. G.*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Division Avenue High School
DAH

062102932

Client: Levittown Union Free School District

Retest/New Install:
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 126

21 FEB 15 PM 5:05

ST. ANTHONY'S ANALYTICAL, INC.
CARLE PLACE, NY

Building Address
120 Division Avenue
Levittown, NY 11756

Pb200.5 -

A. J. [Signature] 02/26/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *[Signature]* A. J. [Signature] 02/26/21

Samplers Signature: *[Signature]*

JCB Project Manager: *[Signature]* Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/15/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Levittown Union Free School District, 120 Division
Avenue, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062102932. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0227				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0001		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0231				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0002		
200.5	Lead	1.0 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0233				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0003		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0235				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0004		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0237				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0005		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0239				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0006		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0241				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0007		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0243				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0008		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0243	Collected:	2/13/2021	Lab ID:	062102932-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0245	Collected:	2/13/2021	Lab ID:	062102932-0009	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0301	Collected:	2/13/2021	Lab ID:	062102932-0010	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	20	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0302	Collected:	2/13/2021	Lab ID:	062102932-0011	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	98	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0304	Collected:	2/13/2021	Lab ID:	062102932-0012	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	19	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0307	Collected:	2/13/2021	Lab ID:	062102932-0013	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0309	Collected:	2/13/2021	Lab ID:	062102932-0014	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0311 **Collected:** 2/13/2021 **Lab ID:** 062102932-0015

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0313 **Collected:** 2/13/2021 **Lab ID:** 062102932-0016

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0315 **Collected:** 2/13/2021 **Lab ID:** 062102932-0017

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.5	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0317 **Collected:** 2/13/2021 **Lab ID:** 062102932-0018

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.8	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0319 **Collected:** 2/13/2021 **Lab ID:** 062102932-0019

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.5 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0321 **Collected:** 2/13/2021 **Lab ID:** 062102932-0020

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.7 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0323 **Collected:** 2/13/2021 **Lab ID:** 062102932-0021

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0325		2/13/2021	062102932-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.8 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0327		2/13/2021	062102932-0023				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.1	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0329		2/13/2021	062102932-0024				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.9	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0331		2/13/2021	062102932-0025				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.9 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0333		2/13/2021	062102932-0026				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0335		2/13/2021	062102932-0027				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.2	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0337		2/13/2021	062102932-0028				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	28	3.0 µg/L	2/25/2021	AM	2/26/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0340	Collected:	2/13/2021	Lab ID:	062102932-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	56	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0341	Collected:	2/13/2021	Lab ID:	062102932-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0342	Collected:	2/13/2021	Lab ID:	062102932-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	28	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0343	Collected:	2/13/2021	Lab ID:	062102932-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0344	Collected:	2/13/2021	Lab ID:	062102932-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0346	Collected:	2/13/2021	Lab ID:	062102932-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	32	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0348	Collected:	2/13/2021	Lab ID:	062102932-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.7	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0350		2/13/2021	062102932-0036				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0353		2/13/2021	062102932-0037				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.2	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0354		2/13/2021	062102932-0038				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.0	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0356		2/13/2021	062102932-0039				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.7 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0358		2/13/2021	062102932-0040				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0360		2/13/2021	062102932-0041				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	13	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0362		2/13/2021	062102932-0042				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.1	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0364				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0043		
200.5	Lead	7.2	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0366				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0044		
200.5	Lead	6.5	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0368				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0045		
200.5	Lead	4.2	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0369				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0046		
200.5	Lead	46	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0371				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0047		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0372				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0048		
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0373				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0049		
200.5	Lead	17	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0374				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0050		
200.5	Lead	17	3.0 µg/L	2/25/2021	AM	2/26/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0374	Collected:	2/13/2021	Lab ID:	062102932-0050	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.8	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0375	Collected:	2/13/2021	Lab ID:	062102932-0051	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.4	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0376	Collected:	2/13/2021	Lab ID:	062102932-0052	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.7 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0377	Collected:	2/13/2021	Lab ID:	062102932-0053	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.5	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0379	Collected:	2/13/2021	Lab ID:	062102932-0054	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0380	Collected:	2/13/2021	Lab ID:	062102932-0055	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	720 D	30 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0382	Collected:	2/13/2021	Lab ID:	062102932-0056	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	110	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0384	Collected:	2/13/2021	Lab ID:	062102932-0057	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0384 **Collected:** 2/13/2021 **Lab ID:** 062102932-0057

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	390 D	12 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0389 **Collected:** 2/13/2021 **Lab ID:** 062102932-0058

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.1	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0391 **Collected:** 2/13/2021 **Lab ID:** 062102932-0059

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0393 **Collected:** 2/13/2021 **Lab ID:** 062102932-0060

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0395 **Collected:** 2/13/2021 **Lab ID:** 062102932-0061

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0397 **Collected:** 2/13/2021 **Lab ID:** 062102932-0062

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	26	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0398 **Collected:** 2/13/2021 **Lab ID:** 062102932-0063

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.8 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0399	Collected:	2/13/2021	Lab ID:	062102932-0064	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0401	Collected:	2/13/2021	Lab ID:	062102932-0065	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0402	Collected:	2/13/2021	Lab ID:	062102932-0066	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.3	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0403	Collected:	2/13/2021	Lab ID:	062102932-0067	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0404	Collected:	2/13/2021	Lab ID:	062102932-0068	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0405	Collected:	2/13/2021	Lab ID:	062102932-0069	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.7 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0406	Collected:	2/13/2021	Lab ID:	062102932-0070	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	43	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0407	Collected:	2/13/2021	Lab ID:	062102932-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.5	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0408	Collected:	2/13/2021	Lab ID:	062102932-0072	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0410	Collected:	2/13/2021	Lab ID:	062102932-0073	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0414	Collected:	2/13/2021	Lab ID:	062102932-0074	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0418	Collected:	2/13/2021	Lab ID:	062102932-0075	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	10	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0421	Collected:	2/13/2021	Lab ID:	062102932-0076	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0423	Collected:	2/13/2021	Lab ID:	062102932-0077	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0425	Collected:	2/13/2021	Lab ID:	062102932-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0425	Collected:	2/13/2021	Lab ID:	062102932-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0426	Collected:	2/13/2021	Lab ID:	062102932-0079	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0427	Collected:	2/13/2021	Lab ID:	062102932-0080	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0428	Collected:	2/13/2021	Lab ID:	062102932-0081	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	26	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0429	Collected:	2/13/2021	Lab ID:	062102932-0082	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0430	Collected:	2/13/2021	Lab ID:	062102932-0083	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0431	Collected:	2/13/2021	Lab ID:	062102932-0084	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0433	Collected:	2/13/2021	Lab ID:	062102932-0085	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0433	Collected:	2/13/2021	Lab ID:	062102932-0085	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0434	Collected:	2/13/2021	Lab ID:	062102932-0086	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0435	Collected:	2/13/2021	Lab ID:	062102932-0087	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.3	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0442	Collected:	2/13/2021	Lab ID:	062102932-0088	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0443	Collected:	2/13/2021	Lab ID:	062102932-0089	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.3	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0445	Collected:	2/13/2021	Lab ID:	062102932-0090	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0446	Collected:	2/13/2021	Lab ID:	062102932-0091	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.3	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Client Sample Description		LVT-0448	Collected:	2/13/2021	Lab ID:	062102932-0092	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0448				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0092		
200.5	Lead	35	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0449				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0093		
200.5	Lead	7.3	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0450				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0094		
200.5	Lead	25	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0451				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0095		
200.5	Lead	<3.0 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0452				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0096		
200.5	Lead	3.8	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0454				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0097		
200.5	Lead	23	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0457				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0098		
200.5	Lead	150	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0459				<i>Collected:</i> 2/13/2021	<i>Lab ID:</i> 062102932-0099		
200.5	Lead						

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0459		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0099			
200.5	Lead	23	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0461		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0100			
200.5	Lead	1.2 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0462		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0101			
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0464		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0102			
200.5	Lead	25	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0465		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0103			
200.5	Lead	23	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0466		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0104			
200.5	Lead	140	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0467		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0105			
200.5	Lead	13	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i> LVT-0468		<i>Collected:</i> 2/13/2021		<i>Lab ID:</i> 062102932-0106			

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0468 **Collected:** 2/13/2021 **Lab ID:** 062102932-0106

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0469 **Collected:** 2/13/2021 **Lab ID:** 062102932-0107

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-0470 **Collected:** 2/13/2021 **Lab ID:** 062102932-0108

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	210	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0471 **Collected:** 2/13/2021 **Lab ID:** 062102932-0109

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.5	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0472 **Collected:** 2/13/2021 **Lab ID:** 062102932-0110

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	11	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0473 **Collected:** 2/13/2021 **Lab ID:** 062102932-0111

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	210	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-0474 **Collected:** 2/13/2021 **Lab ID:** 062102932-0112

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2246		2/13/2021	062102932-0113				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.7 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2247		2/13/2021	062102932-0114				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2249		2/13/2021	062102932-0115				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2250		2/13/2021	062102932-0116				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2251		2/13/2021	062102932-0117				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2256		2/13/2021	062102932-0118				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2257		2/13/2021	062102932-0119				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102932
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/15/2021 05:05 PM
 Collected: 2/13/2021

Project: 19-45328, Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2258 **Collected:** 2/13/2021 **Lab ID:** 062102932-0120

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2259 **Collected:** 2/13/2021 **Lab ID:** 062102932-0121

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2260 **Collected:** 2/13/2021 **Lab ID:** 062102932-0122

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2261 **Collected:** 2/13/2021 **Lab ID:** 062102932-0123

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2262 **Collected:** 2/13/2021 **Lab ID:** 062102932-0124

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	56	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2263 **Collected:** 2/13/2021 **Lab ID:** 062102932-0125

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL

Client Sample Description LVT-2264 **Collected:** 2/13/2021 **Lab ID:** 062102932-0126

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/25/2021	AM	2/26/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone/Fax: (516) 997-7251 / (516) 997-7528

<http://www.EMSL.com>

carleplacelab@emsl.com

EMSL Order: 062102932

CustomerID: JCBR50

CustomerPO:

ProjectID:

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - Result was below the MDL.

RL = Reporting Limit (the value below which is not defensibly quantifiable)

D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: East Broadway Elementary School
EBE

062102389

Client:
Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1494	CR	1034	Room 113	CF	2/4/2021	5:33:00 AM
LVT-1495	CR	1033	Room 116	CF	2/4/2021	5:33:00 AM
LVT-1496	CR	1030	Room 114	CF	2/4/2021	5:34:00 AM
LVT-1497	CR	1029	Room 111	CF	2/4/2021	5:35:00 AM
LVT-1498	CR	1028	Room 112	CF	2/4/2021	5:36:00 AM
LVT-1499	CR	1027	Room 109	CF	2/4/2021	5:36:00 AM
LVT-1500	BR	1026	Girls Bathroom	BF	2/4/2021	5:37:00 AM
LVT-1502	BR	1026	Girls Bathroom	BF	2/4/2021	5:37:00 AM
LVT-1504	BR	1026	Girls Bathroom	BF	2/4/2021	5:38:00 AM
LVT-1506	BR	1026	Girls Bathroom	BF	2/4/2021	5:38:00 AM
LVT-1508	BR	1025	Boys Bathroom	BF	2/4/2021	5:38:00 AM
LVT-1510	BR	1025	Boys Bathroom	BF	2/4/2021	5:39:00 AM
LVT-1515	CR	1040	Room 305 Art Room	CF	2/4/2021	5:40:00 AM
LVT-1516	CR	1040	Room 305 Art Room	CF	2/4/2021	5:41:00 AM
LVT-1517	CR	1041	Room 306	CF	2/4/2021	5:42:00 AM
LVT-1518	BR	1041A	Room 306 Bathroom	BF	2/4/2021	5:43:00 AM
LVT-1520	FL	1043	Room 303 Faculty	HW	2/4/2021	5:44:00 AM
LVT-1521	BR	1045	Men's/Women's Bathroom	BF	2/4/2021	5:45:00 AM

Building Address
751 Seaman Neck Road
Seaford, NY 11783

P6200.5-
A. J. Jany 02/15/21

Analysis Type: ELAP 200.5 (10)
Lab Received: *[Signature]*
Signature: *[Signature]*

Samplers Name: Michael Bower
Samplers Signature: *[Signature]*
JCB Project Manager: Anthony Lombardo

2 FEB 2021 11:00 AM
P
2:00 PM



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: East Broadway Elementary School
EBE

062102389

Client: Levittown Union Free School District
Retest/New Install:
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1523	BR	1046	Women's Room	BF	2/4/2021	5:46:00 AM
LVT-1525	BR	1046	Women's Room	BF	2/4/2021	5:46:00 AM
LVT-1526	BR	1049A	Principal's Office Bathroom	BF	2/4/2021	5:48:00 AM
LVT-1528	KI	1055	Kitchen	SA	2/4/2021	5:50:00 AM
LVT-1529	KI	1055	Kitchen	KC	2/4/2021	5:51:00 AM
LVT-1530	KI	1055	Kitchen	KC	2/4/2021	5:51:00 AM
LVT-1531	KI	1055	Kitchen	KN	2/4/2021	5:52:00 AM
LVT-1532	KI	1055	Kitchen	KC	2/4/2021	5:53:00 AM
LVT-1533	KI	1055	Kitchen	KC	2/4/2021	5:53:00 AM
LVT-1534	NO	1050	Nurse Office	HW	2/4/2021	5:54:00 AM
LVT-1535	BR	1050A	Nurse Office Bathroom	BF	2/4/2021	5:55:00 AM
LVT-1536	BR	1051A	Custodial Office Bathroom	BF	2/4/2021	5:56:00 AM
LVT-1539	CA	1053	Cafeteria	WF	2/4/2021	5:58:00 AM
LVT-1540	BR	1058C2A	Gym Classroom Office Bathroom	BF	2/4/2021	6:01:00 AM
LVT-1542	BR	1058C1A	Gym Classroom Bathroom	BF	2/4/2021	6:04:00 AM
LVT-1547	CR	1087	Room 221	CF	2/4/2021	6:06:00 AM
LVT-1548	CR	1086	Room 220	CF	2/4/2021	6:07:00 AM
LVT-1549	CR	1085	Room 218	CF	2/4/2021	6:08:00 AM

Building Address
751 Seaman Neck Road
Seaford, NY 11783

Ps 200.5-
A. Jimmy 02/15/21

Analysis Type: ELAP 200.5
Lab Received: *Jaale*
Signature: *[Signature]*

Samplers Name: *Michael Bowes*
Samplers Signature: *[Signature]*
JCB Project Manager: *Anthony Lombardo*



Lead in Water: Chain of Custody for

062102389

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: East Broadway Elementary School
EBE

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1550	CR	1084	Room 219	CF	2/4/2021	6:09:00 AM
LVT-1551	CR	1081	Room 217 A & B	CF	2/4/2021	6:10:00 AM
LVT-1552	BR	1083	Girls Bathroom	BF	2/4/2021	6:11:00 AM
LVT-1554	BR	1083	Girls Bathroom	BF	2/4/2021	6:12:00 AM
LVT-1555	BR	1083	Girls Bathroom	BF	2/4/2021	6:12:00 AM
LVT-1557	BR	1080	Boys Bathroom	BF	2/4/2021	6:12:00 AM
LVT-1559	BR	1080	Boys Bathroom	BF	2/4/2021	6:12:00 AM
LVT-1561	BR	1080	Boys Bathroom	BF	2/4/2021	6:12:00 AM
LVT-1563	CR	1061	Room 201	CF	2/4/2021	6:15:00 AM
LVT-1564	CR	1062	Room 202	CF	2/4/2021	6:16:00 AM
LVT-1565	CR	1062	Room 202	DW	2/4/2021	6:17:00 AM
LVT-1566	CR	1063	Room 203	CF	2/4/2021	6:18:00 AM
LVT-1567	CR	1065	Room 205	CF	2/4/2021	6:20:00 AM
LVT-1568	CR	1066	Room 206	CF	2/4/2021	6:21:00 AM
LVT-1570	BR	1069	Boys Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1572	BR	1069	Boys Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1574	BR	1069	Boys Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1578	BR	1071	Girls Bathroom	BF	2/4/2021	6:25:00 AM

Building Address
751 Seaman Neck Road
Seaford, NY 11783

Pb 200.5-
A-Jenny 02/15/21

Analysis Type: ELAP 200.5
Lab Recieved: *[Signature]*
Signature: *[Signature]*

Samplers Name: Michael Bowler
Samplers Signature: *[Signature]*
JCB Project Manager: Anthony Lombardo

Page 4 of 5

OrderID: 062102389



Lead in Water: Chain of Custody for

062102389

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: East Broadway Elementary School
EBE

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1580	BR	1071	Girls Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1582	BR	1071	Girls Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1584	BR	1071	Girls Bathroom	BF	2/4/2021	6:25:00 AM
LVT-1594	CR	1072	Room 207A	CF	2/4/2021	6:28:00 AM
LVT-1596	CR	1073	Room 209	CF	2/4/2021	6:29:00 AM
LVT-1597	CR	1075	Room 211	CF	2/4/2021	6:30:00 AM
LVT-1598	CR	1076	Room 213	CF	2/4/2021	6:31:00 AM
LVT-1599	CR	1002	Room 98	CF	2/4/2021	5:08:00 AM
LVT-1601	BR	1002B	Room 98 Bathroom	BF	2/4/2021	5:08:00 AM
LVT-2222	CR	1015	Room 107A	BW	2/4/2021	5:23:00 AM
LVT-2223	NO	1050	Nurse Office	BW	2/4/2021	5:55:00 AM
LVT-2224	CA	1053	Cafeteria	BW	2/4/2021	6:00:00 AM
LVT-2225	OF	1058C2	Gym Classroom Office	BW	2/4/2021	6:02:00 AM
LVT-2226	HA	1022	Entrance Vestibule Adjacent to School Store	BW	2/4/2021	6:33:00 AM
LVT-2227	HA	1089	Exit Vestibule By Library	BW	2/4/2021	6:34:00 AM

Samples Submitted 87

RECEIVED
LABORATORY
FEB 11 2:20
JCB PROJECT MGR.

Building Address
751 Seaman Neck Road
Seaford, NY 11783

P200.5 -
A. J. Jany 02/15/21

Analysis Type: ELAP 200.5 ^{AI}
Lab Received: [Signature]
Signature: [Signature]

Sampler's Name: Michael Bowen
Sampler's Signature: [Signature]
JCB Project Manager: Anthony Lombardi

Page 5 of 5

Order ID: 062102389



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/4/2021. The results are tabulated on the attached data pages for the following client designated project:

#19-45328, East Broadway Elementary School, Levittown Union
Free School District, 751 Seaman Neck Road, Seaford, NY 11783

The reference number for these samples is EMSL Order #062102389. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1451	Collected:	2/4/2021	Lab ID:	062102389-0001	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1453	Collected:	2/4/2021	Lab ID:	062102389-0002	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1456	Collected:	2/4/2021	Lab ID:	062102389-0003	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1458	Collected:	2/4/2021	Lab ID:	062102389-0004	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1460	Collected:	2/4/2021	Lab ID:	062102389-0005	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1462	Collected:	2/4/2021	Lab ID:	062102389-0006	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1465	Collected:	2/4/2021	Lab ID:	062102389-0007	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.0 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-1468		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0008			
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1471		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0009			
200.5	Lead	1.8 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-1474		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0010			
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1478		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0011			
200.5	Lead	5.0	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1480		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0012			
200.5	Lead	11	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1482		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0013			
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1486		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0014			
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1488		<i>Collected:</i> 2/4/2021		<i>Lab ID:</i> 062102389-0015			
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1488	Collected:	2/4/2021	Lab ID:	062102389-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1490	Collected:	2/4/2021	Lab ID:	062102389-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1491	Collected:	2/4/2021	Lab ID:	062102389-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1492	Collected:	2/4/2021	Lab ID:	062102389-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1494	Collected:	2/4/2021	Lab ID:	062102389-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1495	Collected:	2/4/2021	Lab ID:	062102389-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1496	Collected:	2/4/2021	Lab ID:	062102389-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-1497				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0022		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1498				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0023		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1499				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0024		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1500				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0025		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1502				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0026		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1504				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0027		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1506				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0028		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i> LVT-1508				<i>Collected:</i> 2/4/2021	<i>Lab ID:</i> 062102389-0029		
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1508	Collected:	2/4/2021	Lab ID:	062102389-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1510	Collected:	2/4/2021	Lab ID:	062102389-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1515	Collected:	2/4/2021	Lab ID:	062102389-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	51	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1516	Collected:	2/4/2021	Lab ID:	062102389-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1517	Collected:	2/4/2021	Lab ID:	062102389-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1518	Collected:	2/4/2021	Lab ID:	062102389-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1520	Collected:	2/4/2021	Lab ID:	062102389-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1521	Collected:	2/4/2021	Lab ID:	062102389-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1523	Collected:	2/4/2021	Lab ID:	062102389-0037	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1525	Collected:	2/4/2021	Lab ID:	062102389-0038	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1526	Collected:	2/4/2021	Lab ID:	062102389-0039	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1528	Collected:	2/4/2021	Lab ID:	062102389-0040	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1529	Collected:	2/4/2021	Lab ID:	062102389-0041	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1530	Collected:	2/4/2021	Lab ID:	062102389-0042	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1531		2/4/2021	062102389-0043				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1532		2/4/2021	062102389-0044				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1533		2/4/2021	062102389-0045				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1534		2/4/2021	062102389-0046				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1535		2/4/2021	062102389-0047				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1536		2/4/2021	062102389-0048				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1539		2/4/2021	062102389-0049				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1540		2/4/2021	062102389-0050				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.1 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1542		2/4/2021	062102389-0051				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1547		2/4/2021	062102389-0052				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.9	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1548		2/4/2021	062102389-0053				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1549		2/4/2021	062102389-0054				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1550		2/4/2021	062102389-0055				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1551		2/4/2021	062102389-0056				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1552		2/4/2021	062102389-0057				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1552	Collected:	2/4/2021	Lab ID:	062102389-0057	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1554	Collected:	2/4/2021	Lab ID:	062102389-0058	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1555	Collected:	2/4/2021	Lab ID:	062102389-0059	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1557	Collected:	2/4/2021	Lab ID:	062102389-0060	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1559	Collected:	2/4/2021	Lab ID:	062102389-0061	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1561	Collected:	2/4/2021	Lab ID:	062102389-0062	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1563	Collected:	2/4/2021	Lab ID:	062102389-0063	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.3 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1564	Collected:	2/4/2021	Lab ID:	062102389-0064	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.4	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1565	Collected:	2/4/2021	Lab ID:	062102389-0065	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	140	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1566	Collected:	2/4/2021	Lab ID:	062102389-0066	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1567	Collected:	2/4/2021	Lab ID:	062102389-0067	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1568	Collected:	2/4/2021	Lab ID:	062102389-0068	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1570	Collected:	2/4/2021	Lab ID:	062102389-0069	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1572	Collected:	2/4/2021	Lab ID:	062102389-0070	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1574	Collected:	2/4/2021	Lab ID:	062102389-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1574		2/4/2021	062102389-0071				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1578		2/4/2021	062102389-0072				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1580		2/4/2021	062102389-0073				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1582		2/4/2021	062102389-0074				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1584		2/4/2021	062102389-0075				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1594		2/4/2021	062102389-0076				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.4 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1596		2/4/2021	062102389-0077				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-1597	Collected:	2/4/2021	Lab ID:	062102389-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1598	Collected:	2/4/2021	Lab ID:	062102389-0079	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1599	Collected:	2/4/2021	Lab ID:	062102389-0080	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-1601	Collected:	2/4/2021	Lab ID:	062102389-0081	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-2222	Collected:	2/4/2021	Lab ID:	062102389-0082	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-2223	Collected:	2/4/2021	Lab ID:	062102389-0083	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-2224	Collected:	2/4/2021	Lab ID:	062102389-0084	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL
Client Sample Description		LVT-2225	Collected:	2/4/2021	Lab ID:	062102389-0085	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102389
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/4/2021 02:20 PM
 Collected: 2/4/2021

Project: #19-45328, East Broadway Elementary School, Levittown Union Free School District, 751 Seaman Neck Road, Seaford, NY 11783

Analytical Results

Client Sample Description LVT-2225 **Collected:** 2/4/2021 **Lab ID:** 062102389-0085

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

Client Sample Description LVT-2226 **Collected:** 2/4/2021 **Lab ID:** 062102389-0086

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

Client Sample Description LVT-2227 **Collected:** 2/4/2021 **Lab ID:** 062102389-0087

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/12/2021	AM	2/15/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Building: Gardiners Avenue Elementary School

GAE

062102416

Client:

Levittown Union Free School District

Retest/New Install

Turn Around Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1609	CR	1001	Room 100	CF	2/5/2021	5:27:00 AM
LVT-1611	BR	1001A	Room 100 Bathroom	BF	2/5/2021	5:27:00 AM
LVT-1613	CR	1000	Room 101	CF	2/5/2021	5:29:00 AM
LVT-1614	BR	1000A	Room 101 Bathroom	BF	2/5/2021	5:29:00 AM
LVT-1618	CR	1004	Room 102 & Side Office	CF	2/5/2021	5:31:00 AM
LVT-1619	CR	1005	Room 103	CF	2/5/2021	5:32:00 AM
LVT-1620	CR	1006	Room 104	CF	2/5/2021	5:32:00 AM
LVT-1622	CR	1007	Room 105	CF	2/5/2021	5:35:00 AM
LVT-1623	CR	1008	Room 106	CF	2/5/2021	5:35:00 AM
LVT-1624	CR	1009	Room 107	CF	2/5/2021	5:36:00 AM
LVT-1625	CR	1010	Room 108	CF	2/5/2021	5:42:00 AM
LVT-1626	BR	1011	Boys Bathroom	BF	2/5/2021	5:44:00 AM
LVT-1628	BR	1011	Boys Bathroom	BF	2/5/2021	5:44:00 AM
LVT-1633	BR	1013	Girls Room	BF	2/5/2021	5:46:00 AM
LVT-1635	BR	1013	Girls Room	BF	2/5/2021	5:46:00 AM
LVT-1638	CR	1015	Room 109	CF	2/5/2021	5:47:00 AM
LVT-1639	BR	1017A	Room 112 Bathroom	BF	2/5/2021	5:48:00 AM
LVT-1642	BR	1020	Men's Bathroom	BF	2/5/2021	5:48:00 AM

Building Address

610 Gardiners Avenue

Levittown, NY 11756

Alyssa McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received: *Caele*

Signature: *[Signature]*

Samplers Name: *Alina Costello*

Samplers Signature: *Alina Costello*

JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Gardiners Avenue Elementary School
GAE

062102416

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1644	BR	1022	Women's Room	BF	2/5/2021	5:50:00 AM
LVT-1646	CR	1025	Room 200	CF	2/5/2021	5:52:00 AM
LVT-1647	CR	1026	Room 201	CF	2/5/2021	5:53:00 AM
LVT-1649	CR	1028	Room 202	CF	2/5/2021	5:54:00 AM
LVT-1650	CR	1029	Room 203	CF	2/5/2021	5:56:00 AM
LVT-1651	CR	1030	Room 204	CF	2/5/2021	5:57:00 AM
LVT-1652	CR	1031	Room 205	CF	2/5/2021	5:58:00 AM
LVT-1654	BR	1032	Girls Room	BF	2/5/2021	6:00:00 AM
LVT-1655	BR	1032	Girls Room	BF	2/5/2021	6:00:00 AM
LVT-1660	CR	1035	Room 206	CF	2/5/2021	6:00:00 AM
LVT-1661	BR	1034	Boys Room	BF	2/5/2021	6:01:00 AM
LVT-1663	BR	1034	Boys Room	BF	2/5/2021	6:01:00 AM
LVT-1664	BR	1037A	Assistant Principal Room 200B Bathroom	BF	2/5/2021	6:13:00 AM
LVT-1666	CR	1038	Room 207	CF	2/5/2021	6:05:00 AM
LVT-1667	CR	1040	Computer Room 209	CF	2/5/2021	6:06:00 AM
LVT-1669	LI	1039	Library	HW	2/5/2021	6:07:00 AM
LVT-1670	BR	1042A	Entrance Lobby Men's Room	BF	2/5/2021	6:08:00 AM
LVT-1672	CA	1043	Cafeteria	HW	2/5/2021	6:09:00 AM

Building Address
610 Gardiners Avenue
Levittown, NY 11756

Alyssa McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received: *Caelo*

Signature: *[Signature]*

Samplers Name: *Alyssa McDonald*
Samplers Signature: *[Signature]*
JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

062102416

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Building: Gardiners Avenue Elementary School

GAE

Client:

Levittown Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1674	CA	1043	Cafeteria	WF	2/5/2021	6:10:00 AM
LVT-1675	OF	1043D	Custodians Office	HW	2/5/2021	6:15:00 AM
LVT-1676	KI	1043C	Kitchen	SA	2/5/2021	5:15:00 AM
LVT-1677	KI	1043C	Kitchen	KN	2/5/2021	5:17:00 AM
LVT-1678	KI	1043C	Kitchen	KC	2/5/2021	5:17:00 AM
LVT-1679	KI	1043C	Kitchen	KC	2/5/2021	5:18:00 AM
LVT-1683	BR	1043C4	Kitchen Bathroom	BF	2/5/2021	5:19:00 AM
LVT-1685	BR	1042B	Entrance Lobby Ladies Room	BF	2/5/2021	6:16:00 AM
LVT-1687	BR	1042C2	Principals Bathroom	BF	2/5/2021	6:18:00 AM
LVT-1691	CR	1046	Room 300	CF	2/5/2021	6:19:00 AM
LVT-1693	FL	1047	Faculty Room 301	KC	2/5/2021	6:21:00 AM
LVT-1694	BR	1048A	Chair Persons Office Room 300D Bathroom	BF	2/5/2021	6:29:00 AM
LVT-1696	BR	1049	Boys Room	BF	2/5/2021	6:31:00 AM
LVT-1698	BR	1049	Boys Room	BF	2/5/2021	6:31:00 AM
LVT-1700	BR	1049	Boys Room	BF	2/5/2021	6:31:00 AM
LVT-1705	BR	1051	Girls Bathroom	BF	2/5/2021	6:32:00 AM
LVT-1707	BR	1051	Girls Bathroom	BF	2/5/2021	6:32:00 AM
LVT-1709	BR	1051	Girls Bathroom	BF	2/5/2021	6:32:00 AM

Building Address

610 Gardiners Avenue

Levittown, NY 11756

Auppa McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Handwritten Signature]

Samplers Name: Ariana Castelluzzo

Samplers Signature: [Handwritten Signature]

JCB Project Manager: Meghan Gwynn

OrderID: 062102416

Page 3 of 5



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Gardiners Avenue Elementary School
GAE

062102416

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1711	CR	1052	Room 302	CF	2/5/2021	6:33:00 AM
LVT-1712	CR	1053	Room 303	CF	2/5/2021	6:34:00 AM
LVT-1713	CR	1054	Room 304	CF	2/5/2021	6:35:00 AM
LVT-1714	CR	1055	Room 305	CF	2/5/2021	6:36:00 AM
LVT-1716	CR	1058	Room 306	CF	2/5/2021	6:37:00 AM
LVT-1717	CR	1059	Room 307	CF	2/5/2021	6:38:00 AM
LVT-1718	CR	1060	Room 308	CF	2/5/2021	6:38:00 AM
LVT-1719	BR	1062A	Psychologist Office Room 400A Bathroom	BF	2/5/2021	6:39:00 AM
LVT-1722	BR	1064A	Physical Education Office Bathroom	BF	2/5/2021	6:40:00 AM
LVT-1724	BR	1065	Men's Bathroom	BF	2/5/2021	6:41:00 AM
LVT-1726	BR	1066	Ladies Room	BF	2/5/2021	6:41:00 AM
LVT-1728	CR	1069	Room 400	CF	2/5/2021	6:42:00 AM
LVT-1729	CR	1070	Room 401	CF	2/5/2021	6:43:00 AM
LVT-1730	CR	1071	Room 402	CF	2/5/2021	6:44:00 AM
LVT-1731	CR	1072	Room 403	CF	2/5/2021	6:45:00 AM
LVT-1732	CR	1073	Room 404	CF	2/5/2021	6:45:00 AM
LVT-1733	BR	1074	Girls Bathroom	BF	2/5/2021	6:49:00 AM
LVT-1735	BR	1074	Girls Bathroom	BF	2/5/2021	6:49:00 AM

Building Address
610 Gardiners Avenue
Levittown, NY 11756

Supervisor 2/22/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *Alina Castelluzzo*
Samplers Signature: *[Signature]*
JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Gardiners Avenue Elementary School
GAE

062102416

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1737	BR	1074	Girls Bathroom	BF	2/5/2021	6:49:00 AM
LVT-1742	BR	1076	Boys Room	BF	2/5/2021	6:51:00 AM
LVT-1744	BR	1076	Boys Room	BF	2/5/2021	6:51:00 AM
LVT-1746	BR	1076	Boys Room	BF	2/5/2021	6:51:00 AM
LVT-1749	CR	1077	Room 405	CF	2/5/2021	6:52:00 AM
LVT-1750	CR	1078	Room 406	CF	2/5/2021	6:53:00 AM
LVT-1751	CR	1079	Room 407	CF	2/5/2021	6:54:00 AM
LVT-1752	CR	1080	Room 408	CF	2/5/2021	6:55:00 AM
LVT-1753	CR	1084	Room 409	CF	2/5/2021	6:56:00 AM
LVT-1754	CR	1083	Room 410	CF	2/5/2021	6:57:00 AM
LVT-2228	HA	1018	Corridor Near Boys Bathroom	BW	2/5/2021	5:39:00 AM
LVT-2229	HA	1041	Corridor Near Room 203	BW	2/5/2021	5:56:00 AM
LVT-2230	FL	1047	Faculty Room 301	IM	2/5/2021	6:25:00 AM
LVT-2231	HA	1061	Corridor Near Faculty Room	BW	2/5/2021	6:27:00 AM
LVT-2232	HA	1085	Corridor Near Girls Bathroom	BW	2/5/2021	6:46:00 AM

Samples Submitted 87

RECEIVED
JCB PROJECT MGR.
PLACEMENT
NY
2/5/21
5:58 PM

Building Address
610 Gardiners Avenue
Levittown, NY 11756

Aysha Mohamed 2/22/21

Analysis Type: ELAP 200.5

Lab Received: _____

Signature: _____

[Handwritten Signature]

Samplers Name: Aysha Mohamed

Samplers Signature: *[Handwritten Signature]*

JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Gardiners Avenue Elementary School, Levittown Union
Free School District, 610 Gardiners Avenue, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062102416. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1609		2/5/2021	062102416-0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1611		2/5/2021	062102416-0002				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1613		2/5/2021	062102416-0003				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1614		2/5/2021	062102416-0004				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1618		2/5/2021	062102416-0005				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1619		2/5/2021	062102416-0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1620		2/5/2021	062102416-0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.0	3.0 µg/L	2/17/2021	DI	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1622		2/5/2021	062102416-0008				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1623		2/5/2021	062102416-0009				
200.5	Lead	3.0	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1624		2/5/2021	062102416-0010				
200.5	Lead	1.1 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
LVT-1625		2/5/2021	062102416-0011				
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1626		2/5/2021	062102416-0012				
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1628		2/5/2021	062102416-0013				
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1633		2/5/2021	062102416-0014				
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1635		2/5/2021	062102416-0015				

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1635		2/5/2021	062102416-0015				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1638		2/5/2021	062102416-0016				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1639		2/5/2021	062102416-0017				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1642		2/5/2021	062102416-0018				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.3 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1644		2/5/2021	062102416-0019				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1646		2/5/2021	062102416-0020				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	31	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1647		2/5/2021	062102416-0021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1649		2/5/2021	062102416-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1650		2/5/2021	062102416-0023				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1651		2/5/2021	062102416-0024				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.3	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1652		2/5/2021	062102416-0025				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1654		2/5/2021	062102416-0026				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1655		2/5/2021	062102416-0027				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1660		2/5/2021	062102416-0028				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1661	Collected:	2/5/2021	Lab ID:	062102416-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.0 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1663	Collected:	2/5/2021	Lab ID:	062102416-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1664	Collected:	2/5/2021	Lab ID:	062102416-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	11	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1666	Collected:	2/5/2021	Lab ID:	062102416-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	20	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1667	Collected:	2/5/2021	Lab ID:	062102416-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	12	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1669	Collected:	2/5/2021	Lab ID:	062102416-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	37	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1670	Collected:	2/5/2021	Lab ID:	062102416-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.9	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1672	Collected:	2/5/2021	Lab ID:	062102416-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1672	Collected:	2/5/2021	Lab ID:	062102416-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1674	Collected:	2/5/2021	Lab ID:	062102416-0037	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1675	Collected:	2/5/2021	Lab ID:	062102416-0038	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	15	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1676	Collected:	2/5/2021	Lab ID:	062102416-0039	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.8	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1677	Collected:	2/5/2021	Lab ID:	062102416-0040	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.3 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1678	Collected:	2/5/2021	Lab ID:	062102416-0041	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Client Sample Description		LVT-1679	Collected:	2/5/2021	Lab ID:	062102416-0042	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.2	3.0 µg/L	2/17/2021	DI	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1683		2/5/2021	062102416-0043				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1685		2/5/2021	062102416-0044				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1687		2/5/2021	062102416-0045				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1691		2/5/2021	062102416-0046				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.3	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1693		2/5/2021	062102416-0047				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.3 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1694		2/5/2021	062102416-0048				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.9	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1696		2/5/2021	062102416-0049				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1698		2/5/2021	062102416-0050				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.1 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1700		2/5/2021	062102416-0051				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	2/17/2021	DI	2/19/2021	AL

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1705		2/5/2021	062102416-0052				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1707		2/5/2021	062102416-0053				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1709		2/5/2021	062102416-0054				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1711		2/5/2021	062102416-0055				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.0	3.0 µg/L	2/17/2021	DI	2/19/2021	AL

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1712		2/5/2021	062102416-0056				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	15	3.0 µg/L	2/17/2021	DI	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1713		2/5/2021	062102416-0057				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.8	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1714		2/5/2021	062102416-0058				
200.5	Lead	2.5 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
LVT-1716		2/5/2021	062102416-0059				
200.5	Lead	70	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
LVT-1717		2/5/2021	062102416-0060				
200.5	Lead	1.4 J	3.0 µg/L	2/17/2021	DI	2/19/2021	AL
Lead MDL: 1.0µg/L							
LVT-1718		2/5/2021	062102416-0061				
200.5	Lead	3.0	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
LVT-1719		2/5/2021	062102416-0062				
200.5	Lead	11	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
LVT-1722		2/5/2021	062102416-0063				
200.5	Lead	45	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1724	Collected:	2/5/2021	Lab ID:	062102416-0064	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1726	Collected:	2/5/2021	Lab ID:	062102416-0065	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1728	Collected:	2/5/2021	Lab ID:	062102416-0066	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1729	Collected:	2/5/2021	Lab ID:	062102416-0067	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	11	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1730	Collected:	2/5/2021	Lab ID:	062102416-0068	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.8	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1731	Collected:	2/5/2021	Lab ID:	062102416-0069	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	20	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1732	Collected:	2/5/2021	Lab ID:	062102416-0070	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	30	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1733	Collected:	2/5/2021	Lab ID:	062102416-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1733		2/5/2021	062102416-0071				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.7 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1735		2/5/2021	062102416-0072				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1737		2/5/2021	062102416-0073				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.1	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1742		2/5/2021	062102416-0074				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1744		2/5/2021	062102416-0075				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1746		2/5/2021	062102416-0076				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1749		2/5/2021	062102416-0077				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description				Collected:	Lab ID:		
LVT-1750				2/5/2021	062102416-0078		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	57	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description				Collected:	Lab ID:		
LVT-1751				2/5/2021	062102416-0079		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description				Collected:	Lab ID:		
LVT-1752				2/5/2021	062102416-0080		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.1	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description				Collected:	Lab ID:		
LVT-1753				2/5/2021	062102416-0081		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.1	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1754				2/5/2021	062102416-0082		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.3	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-2228				2/5/2021	062102416-0083		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-2229				2/5/2021	062102416-0084		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-2230				2/5/2021	062102416-0085		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102416
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/5/2021 04:58 PM
 Collected: 2/5/2021

Project: 19-45328, Gardiners Avenue Elementary School, Levittown Union Free School District, 610 Gardiners Avenue, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2230 **Collected:** 2/5/2021 **Lab ID:** 062102416-0085

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL

Client Sample Description LVT-2231 **Collected:** 2/5/2021 **Lab ID:** 062102416-0086

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL

Client Sample Description LVT-2232 **Collected:** 2/5/2021 **Lab ID:** 062102416-0087

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

062102420

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0001	SP	1001A	Room 100A Orchestra Storage Room	HW	2/6/2021	5:24:00 AM
LVT-0002	CR	1003	Room 103	CF	2/6/2021	5:25:00 AM
LVT-0003	CR	1003	Room 103	CF	2/6/2021	5:25:00 AM
LVT-0004	CR	1003	Room 103	CF	2/6/2021	5:26:00 AM
LVT-0005	CR	1004	Room 105	CF	2/6/2021	5:27:00 AM
LVT-0006	CR	1004	Room 105	CF	2/6/2021	5:28:00 AM
LVT-0007	CR	1004	Room 105	CF	2/6/2021	5:28:00 AM
LVT-0008	CR	1008	Room 102	CF	2/6/2021	5:29:00 AM
LVT-0009	CR	1008	Room 102	SN	2/6/2021	5:30:00 AM
LVT-0010	SP	1008B	Film Darkroom	HW	2/6/2021	5:31:00 AM
LVT-0011	SP	1008C	Print Darkroom	HW	2/6/2021	5:32:00 AM
LVT-0012	CR	1012	Room 113A	CF	2/6/2021	5:33:00 AM
LVT-0013	CR	1012	Room 113A	CF	2/6/2021	5:33:00 AM
LVT-0014	CR	1014	Men's Faculty Bathroom	BF	2/6/2021	5:34:00 AM
LVT-0016	CR	1014	Men's Faculty Bathroom	BF	2/6/2021	5:34:00 AM
LVT-0018	CR	1014	Men's Faculty Bathroom	BF	2/6/2021	5:35:00 AM
LVT-0020	CR	1014	Men's Faculty Bathroom	BF	2/6/2021	5:35:00 AM
LVT-0021	HA	1030	Corridor Rooms 100A to 124	DW	2/6/2021	5:36:00 AM

Building Address
3369 Jerusalem Road
Levittown, NY 11756

Pb- *A. J. J. 02/19/21*

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *Alina Castellano*

Samplers Signature: *Alina Castellano*

JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

062102420

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0024	BR	1016	Women's Faculty Bathroom	BF	2/6/2021	5:36:00 AM
LVT-0025	BR	1016	Women's Faculty Bathroom	BF	2/6/2021	5:37:00 AM
LVT-0027	BR	1016	Women's Faculty Bathroom	BF	2/6/2021	5:37:00 AM
LVT-0029	BR	1016	Women's Faculty Bathroom	BF	2/6/2021	5:38:00 AM
LVT-0031	BR	1016	Women's Faculty Bathroom	BF	2/6/2021	5:38:00 AM
LVT-0034	BR	1032A1	Boys Locker Room Coach Bathroom	BF	2/6/2021	5:39:00 AM
LVT-0036	BR	1032E	Boys Locker Room Shower Wall Chase	BF	2/6/2021	5:40:00 AM
LVT-0038	BR	1032E	Boys Locker Room Shower Wall Chase	BF	2/6/2021	5:41:00 AM
LVT-0041	HA	1031	Gym Lobby/Corridor	WF	2/6/2021	5:42:00 AM
LVT-0043	HA	N/A New Construction	New Gym Hall	WF	2/6/2021	5:42:00 AM
LVT-0044	SP	N/A New Construction	New Gym Hall Closet	IM	2/6/2021	5:43:00 AM
LVT-0045	BR	1038B1	Girls Locker Room Bathroom in Office	BF	2/6/2021	5:44:00 AM
LVT-0047	BR	1038D	Girls Locker Room Bathroom	BF	2/6/2021	5:45:00 AM
LVT-0048	BR	N/A New Construction	New Gym Locker Room Bathroom	BF	2/6/2021	5:46:00 AM
LVT-0053	CR	2009	Room 221	CF	2/6/2021	6:03:00 AM
LVT-0054	CR	2009	Room 221	SN	2/6/2021	6:04:00 AM
LVT-0056	CA	2033	Cafeteria A	WF	2/6/2021	6:05:00 AM
LVT-0066	BR	2030	Girls Bathroom	BF	2/6/2021	6:06:00 AM

Building Address
3369 Jerusalem Road
Levittown, NY 11756

PO - J. J. J. 02/19/21

Analysis Type: ELAP 200.5

Lab Received: Chelle

Signature: [Signature]

Samplers Name: Alicia Castorillo
Samplers Signature: [Signature]
JCB Project Manager: Meghan Gwynn



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

062102420

Client:
Levittown Union Free School District

Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0068	BR	2030	Girls Bathroom	BF	2/6/2021	6:07:00 AM
LVT-0070	BR	2030	Girls Bathroom	BF	2/6/2021	6:08:00 AM
LVT-0072	BR	2030	Girls Bathroom	BF	2/6/2021	6:09:00 AM
LVT-0074	BR	2030	Girls Bathroom	BF	2/6/2021	6:10:00 AM
LVT-0077	BR	2028	Boys Bathroom	BF	2/6/2021	6:11:00 AM
LVT-0079	BR	2028	Boys Bathroom	BF	2/6/2021	6:11:00 AM
LVT-0081	BR	2028	Boys Bathroom	BF	2/6/2021	6:12:00 AM
LVT-0083	BR	2028	Boys Bathroom	BF	2/6/2021	6:12:00 AM
LVT-0088	HE	2015	Room 211	EC	2/6/2021	6:14:00 AM
LVT-0089	HE	2015	Room 211	EC	2/6/2021	6:14:00 AM
LVT-0090	HE	2015	Room 211	EC	2/6/2021	6:15:00 AM
LVT-0091	HE	2015	Room 211	EC	2/6/2021	6:15:00 AM
LVT-0092	BR	2024	Women's Faculty Bathroom	BF	2/6/2021	6:17:00 AM
LVT-0093	BR	2024	Women's Faculty Bathroom	BF	2/6/2021	6:17:00 AM
LVT-0094	BR	2023	Men's Faculty Bathroom	BF	2/6/2021	6:18:00 AM
LVT-0096	NO	2044	Nurses Office	NS	2/6/2021	6:20:00 AM
LVT-0097	NO	2044B	Nurses Office Sick Room	NS	2/6/2021	6:21:00 AM
LVT-0098	BR	2044A1	Nurses Office Bathroom	BF	2/6/2021	6:22:00 AM

Building Address
3369 Jerusalem Road
Levittown, NY 11756

Pb- *[Signature]* 02/19/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *Aline Castelli*
Samplers Signature: *Aline Castelli*
JCB Project Manager: *Meghan Gwyn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

062102420

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AMERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0100	FL	2014	Faculty Lounge 213	WC	2/6/2021	6:34:00 AM
LVT-0101	FL	2014	Faculty Lounge 213	KC	2/6/2021	6:34:00 AM
LVT-0102	FL	2014	Faculty Lounge 213	KC	2/6/2021	6:35:00 AM
LVT-0106	BR	2043A1	Guidance Chair Office Bathroom	BF	2/6/2021	6:59:00 AM
LVT-0108	BR	2042	Women's Bathroom	BF	2/6/2021	6:25:00 AM
LVT-0109	HA	2045	Corridor From Nurses Office to Room 99	DW	2/6/2021	6:26:00 AM
LVT-0110	BR	2041	Men's Bathroom	BF	2/6/2021	6:27:00 AM
LVT-0112	CR	N/A New Construction	New Construction Room C4	CF	2/6/2021	6:28:00 AM
LVT-0113	CR	N/A New Construction	New Construction Room C4	CF	2/6/2021	6:29:00 AM
LVT-0114	CR	N/A New Construction	New Construction Room C4	CF	2/6/2021	6:29:00 AM
LVT-0115	CR	N/A New Construction	New Construction Room C4	CF	2/6/2021	6:29:00 AM
LVT-0116	BR	N/A New Construction	New Construction Mens Bathroom	BF	2/6/2021	6:31:00 AM
LVT-0119	HA	N/A New Construction	New Construction Mens Lobby Hall	WF	2/6/2021	6:32:00 AM
LVT-0120	BR	N/A New Construction	New Construction Womens Bathroom	BF	2/6/2021	6:33:00 AM
LVT-0123	KI	2034A	Kitchen	WF	2/6/2021	6:38:00 AM
LVT-0124	KI	2034	Kitchen (Reconstructed)	KN	2/6/2021	6:39:00 AM
LVT-0125	KI	2034	Kitchen (Reconstructed)	KC	2/6/2021	6:39:00 AM
LVT-0126	KI	2034	Kitchen (Reconstructed)	KC	2/6/2021	6:40:00 AM

Building Address
3369 Jerusalem Road
Levittown, NY 11756

Pb - Spring 02/19/21

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: Aina Costelluzo
Samplers Signature: Aina Costelluzo
JCB Project Manager: Meghan Gwynn



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

062102420

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0127	KI	2034	Kitchen (Reconstructed)	KC	2/6/2021	6:40:00 AM
LVT-0128	KI	2034	Kitchen (Reconstructed)	KN	2/6/2021	6:41:00 AM
LVT-0136	BR	N/A New Construction	New Construction Boys Locker Room Bathroom	BF	2/6/2021	5:43:00 AM
LVT-0197	BR	3017	Women's Faculty Room	BF	2/6/2021	6:43:00 AM
LVT-0199	BR	3017	Women's Faculty Room	BF	2/6/2021	6:44:00 AM
LVT-0201	BR	3017	Women's Faculty Room	BF	2/6/2021	6:44:00 AM
LVT-0203	BR	3017	Women's Faculty Room	BF	2/6/2021	6:45:00 AM
LVT-0205	BR	3017	Women's Faculty Room	BF	2/6/2021	6:45:00 AM
LVT-0208	HA	3036	Corridor Rooms 300-322	WF	2/6/2021	6:46:00 AM
LVT-0209	BR	3019	Men's Room	BF	2/6/2021	6:50:00 AM
LVT-0211	BR	3019	Men's Room	BF	2/6/2021	6:50:00 AM
LVT-0213	BR	3019	Men's Room	BF	2/6/2021	6:50:00 AM
LVT-0215	BR	3019	Men's Room	BF	2/6/2021	6:50:00 AM
LVT-0217	OF	3021A2	Assistant Principals Office	HW	2/6/2021	6:50:00 AM
LVT-0218	HA	3036	Corridor Rooms 300-322	DW	2/6/2021	6:50:00 AM
LVT-2233	HA	1030	Corridor Rooms 100A to 124	BW	2/6/2021	5:33:00 AM
LVT-2234	HA	2036	Corridor Rooms 208 to Stairwell	BW	2/6/2021	5:54:00 AM
LVT-2235	HA	N/A New Construction	New Construction Hallway o/s Room C4	BW	2/6/2021	6:30:00 AM

Building Address
3369 Jerusalem Road
Levittown, NY 11756

Pb- *A. Jung* 02/19/21

Analysis Type: ELAP 200.5

Lab Received: *Callie*

Signature: *[Signature]*

Sampler's Name: *Alina Castelluzzo*

Sampler's Signature: *Alina Castelluzzo*

JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: General Douglas MacArthur High School
MAC

062102420

Client: Levittown Union Free School District
Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 90

21 FEB -9 PM 12:00
STATE OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Building Address
3369 Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: *Jaely*

Signature: *[Signature]*

Samplers Name: Alina Castelli 4220

Samplers Signature: *Alina Castelli*

JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/9/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45328, General Douglas MacArthur High School, Levittown
Union Free School District, 3369 Jerusalem Road, Levittown, NY
11756

The reference number for these samples is EMSL Order #062102420. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0001	Collected:	2/6/2021	Lab ID:	062102420-0001	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	19	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0002	Collected:	2/6/2021	Lab ID:	062102420-0002	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0003	Collected:	2/6/2021	Lab ID:	062102420-0003	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0004	Collected:	2/6/2021	Lab ID:	062102420-0004	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0005	Collected:	2/6/2021	Lab ID:	062102420-0005	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0006	Collected:	2/6/2021	Lab ID:	062102420-0006	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0007	Collected:	2/6/2021	Lab ID:	062102420-0007	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0008	Collected:	2/6/2021	Lab ID:	062102420-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0009	Collected:	2/6/2021	Lab ID:	062102420-0009	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	19	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0010	Collected:	2/6/2021	Lab ID:	062102420-0010	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0011	Collected:	2/6/2021	Lab ID:	062102420-0011	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	100	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0012	Collected:	2/6/2021	Lab ID:	062102420-0012	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0013	Collected:	2/6/2021	Lab ID:	062102420-0013	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0014	Collected:	2/6/2021	Lab ID:	062102420-0014	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0016	Collected:	2/6/2021	Lab ID:	062102420-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0016	Collected:	2/6/2021	Lab ID:	062102420-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.9	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0018	Collected:	2/6/2021	Lab ID:	062102420-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.3 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0020	Collected:	2/6/2021	Lab ID:	062102420-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0021	Collected:	2/6/2021	Lab ID:	062102420-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0024	Collected:	2/6/2021	Lab ID:	062102420-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0025	Collected:	2/6/2021	Lab ID:	062102420-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0027	Collected:	2/6/2021	Lab ID:	062102420-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.0	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0022</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0023</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0024</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0025</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0026</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0027</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0028</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0029</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0044	Collected:	2/6/2021	Lab ID:	062102420-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0045	Collected:	2/6/2021	Lab ID:	062102420-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	48	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0047	Collected:	2/6/2021	Lab ID:	062102420-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0048	Collected:	2/6/2021	Lab ID:	062102420-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0053	Collected:	2/6/2021	Lab ID:	062102420-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0054	Collected:	2/6/2021	Lab ID:	062102420-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	18	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0056	Collected:	2/6/2021	Lab ID:	062102420-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Client Sample Description		LVT-0066	Collected:	2/6/2021	Lab ID:	062102420-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0066				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0036		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0068				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0037		
200.5	Lead	68	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0070				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0038		
200.5	Lead	17	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0072				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0039		
200.5	Lead	33	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0074				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0040		
200.5	Lead	19	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0077				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0041		
200.5	Lead	4.5	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0079				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0042		
200.5	Lead	20	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0081				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0043		
200.5	Lead	20	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0081				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0043		
200.5	Lead	36	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0083				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0044		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0088				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0045		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0089				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0046		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0090				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0047		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0091				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0048		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0092				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0049		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0093				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0050		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0050</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0051</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0052</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0053</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0054</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0055</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.8	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0056</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0057</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0102				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0057		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0106				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0058		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0108				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0059		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0109				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0060		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0110				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0061		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0112				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0062		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0113				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0063		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i> LVT-0114				<i>Collected:</i> 2/6/2021	<i>Lab ID:</i> 062102420-0064		
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0064</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.4	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0065</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	19	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0066</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0067</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0068</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0069</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0070</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0071</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0071</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0072</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0073</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0074</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0075</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0076</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0077</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0078</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021

Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0078</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0079</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0080</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	AM	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0081</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0082</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0083</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0084</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0085</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102420
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 12:00 PM
 Collected: 2/6/2021


Project: 19-45328, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0085</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0086</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0087</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0088</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0089</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/6/2021</i>	<i>Lab ID:</i>	<i>062102420-0090</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/16/2021	DI	2/19/2021	AL

Definitions:

MDL - method detection limit
 J - Result was below the reporting limit, but at or above the MDL
 ND - Result was below the MDL
 RL = Reporting Limit (the value below which is not defensibly quantifiable)
 D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Jonas E. Salk Middle School
SALK

062102494

Client:
Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1221	CR	0006	Shop Room B5	CF	2/9/2021	5:19:00 AM
LVT-1224	SP	0009	Weight Room	IM	2/9/2021	5:20:00 AM
LVT-1226	SP	0009	Weight Room	WF	2/9/2021	5:20:00 AM
LVT-1231	BR	0010C	Girls Locker Room Phys. Ed. Office	BF	2/9/2021	5:21:00 AM
LVT-1235	BR	1000	Men's Faculty Bathroom (Across From Gym)	BF	2/9/2021	5:27:00 AM
LVT-1238	BR	1002	Ladies Faculty Bathroom	BF	2/9/2021	5:27:00 AM
LVT-1240	BR	1003	Girls Bathroom	BF	2/9/2021	5:29:00 AM
LVT-1242	BR	1003	Girls Bathroom	BF	2/9/2021	5:29:00 AM
LVT-1244	BR	1003	Girls Bathroom	BF	2/9/2021	5:29:00 AM
LVT-1248	HE	1007	Room 128/126	EC	2/9/2021	5:30:00 AM
LVT-1250	HE	1007	Room 128/126	EC	2/9/2021	5:33:00 AM
LVT-1251	HE	1007	Room 128/126	EC	2/9/2021	5:33:00 AM
LVT-1252	HE	1007	Room 128/126	EC	2/9/2021	5:34:00 AM
LVT-1253	HE	1007	Room 128/126	EC	2/9/2021	5:34:00 AM
LVT-1254	CR	1012	Room 123	KC	2/9/2021	5:36:00 AM
LVT-1255	HE	1014	Room 122	EC	2/9/2021	5:37:00 AM
LVT-1256	HE	1014	Room 122	EC	2/9/2021	5:37:00 AM
LVT-1257	HE	1014	Room 122	EC	2/9/2021	5:38:00 AM

Building Address

3359 Old Jerusalem Road ^{Pb 200.5}
Levittown, NY 11756
Anthony Lombardo 2/22/21

Analysis Type: ELAP 200.5

Lab Recieved: *[Signature]*

Signature: *[Signature]*

Samplers Name: Michael Bowen

Sampler's Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

062102494

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Jonas E. Salk Middle School

Client: Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush _____

SALK

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1258	HE	1014	Room 122	EC	2/9/2021	5:38:00 AM
LVT-1259	BR	1013	Ladies Bathroom	BF	2/9/2021	5:39:00 AM
LVT-1261	BR	1013	Ladies Bathroom	BF	2/9/2021	5:39:00 AM
LVT-1264	BR	1015	Men's Faculty Bathroom	BF	2/9/2021	5:41:00 AM
LVT-1266	BR	1015	Men's Faculty Bathroom	BF	2/9/2021	5:41:00 AM
LVT-1268	NO	1023B	Nurses Office	NS	2/9/2021	5:42:00 AM
LVT-1269	BR	1023B2B	Nurses Office Cot Room Bathroom	BF	2/9/2021	5:43:00 AM
LVT-1271	BR	1024C1	Assistant Principal Office Bathroom	BF	2/9/2021	5:45:00 AM
LVT-1273	BR	1025A	Principals Office Bathroom	BF	2/9/2021	5:46:00 AM
LVT-1274	KI	1026A	Main Office Kitchen	KC	2/9/2021	5:47:00 AM
LVT-1276	CR	1035	Room 107	CF	2/9/2021	5:50:00 AM
LVT-1277	CR	1035	Room 107	CF	2/9/2021	5:51:00 AM
LVT-1278	CR	1035	Room 107	CF	2/9/2021	5:52:00 AM
LVT-1280	BR	1037	Boys Bathroom	BF	2/9/2021	5:56:00 AM
LVT-1281	BR	1037	Boys Bathroom	BF	2/9/2021	5:58:00 AM
LVT-1283	CR	1040	Room 109	CF	2/9/2021	5:59:00 AM
LVT-1284	CR	1040	Room 109	CF	2/9/2021	6:00:00 AM
LVT-1285	CR	1040	Room 109	CF	2/9/2021	6:01:00 AM

Building Address

3359 Old Jerusalem Road
Levittown, NY 11756

Pb 200.5 -

Ally 02/23/21
Alyssa McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received: _____

Signature: _____

Ally

Samplers Name: Michael Bowen

Samplers Signature: _____

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
 1775 Expressway North Hauppauge, NY 11788
 TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
 Building: Jonas E. Salk Middle School
 SALK

062102494

Client: Levittown Union Free School District
 Retest/New Install []
 Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1287	BR	1039	Girls Bathroom	BF	2/9/2021	6:02:00 AM
LVT-1289	BR	1039	Girls Bathroom	BF	2/9/2021	6:03:00 AM
LVT-1292	BR	1043	Men's Faculty Bathroom	BF	2/9/2021	6:04:00 AM
LVT-1293	BR	1043	Men's Faculty Bathroom	BF	2/9/2021	6:05:00 AM
LVT-1294	BR	1049A1	Boiler Storage Room Bathroom	BF	2/9/2021	6:08:00 AM
LVT-1297	CR	1051	Room 111	CF	2/9/2021	6:09:00 AM
LVT-1298	CR	1051	Room 111	CF	2/9/2021	6:10:00 AM
LVT-1299	CR	1051	Room 111	CF	2/9/2021	6:11:00 AM
LVT-1300	CR	1052	Room 112	CF	2/9/2021	6:56:00 AM
LVT-1301	CR	1052	Room 112	CF	2/9/2021	6:56:00 AM
LVT-1302	CR	1052	Room 112	CF	2/9/2021	6:57:00 AM
LVT-1303	CR	1056	Room 114	CF	2/9/2021	6:15:00 AM
LVT-1304	CR	1056	Room 114	CF	2/9/2021	6:16:00 AM
LVT-1305	CR	1056	Room 114	CF	2/9/2021	6:16:00 AM
LVT-1307	CR	1056	Room 114	CF	2/9/2021	6:17:00 AM
LVT-1309	OF	1057C	Room 116 Office 2	HW	2/9/2021	6:18:00 AM
LVT-1311	BR	1061	Ladies Bathroom	BF	2/9/2021	6:19:00 AM
LVT-1312	BR	1061	Ladies Bathroom	BF	2/9/2021	6:20:00 AM

Building Address
 3359 Old Jerusalem Road
 Levittown, NY 11756

Pb200.5-

Anthony McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Michael Bower

Sampler's Name: Michael Bower

Sampler's Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

062102494

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Building: Jonas E. Salk Middle School

SALK

Client:

Levittown Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1314	KI	1064	Kitchen	KC	2/9/2021	6:23:00 AM
LVT-1315	KI	1064	Kitchen	KC	2/9/2021	6:24:00 AM
LVT-1316	KI	1064	Kitchen	KC	2/9/2021	6:25:00 AM
LVT-1317	KI	1064	Kitchen	KC	2/9/2021	6:26:00 AM
LVT-1318	KI	1064	Kitchen	KN	2/9/2021	6:27:00 AM
LVT-1319	KI	1064	Kitchen	SN	2/9/2021	6:28:00 AM
LVT-1320	KI	1064	Kitchen	KC	2/9/2021	6:29:00 AM
LVT-1321	BR	1064B	Kitchen Locker Room	BF	2/9/2021	6:30:00 AM
LVT-1323	BR	1064F1	Kitchen Exit Vestibule Bathroom	BF	2/9/2021	6:31:00 AM
LVT-1351	BR	2004A	Boys Room Bathroom	BF	2/9/2021	6:48:00 AM
LVT-1361	BR	2013	Ladies Faculty Bathroom	BF	2/9/2021	6:43:00 AM
LVT-1362	BR	2013	Ladies Faculty Bathroom	BF	2/9/2021	6:44:00 AM
LVT-1363	FL	2016	Faculty Room	KC	2/9/2021	6:42:00 AM
LVT-1364	LI	2020A	Library Work Room	KC	2/9/2021	6:41:00 AM
LVT-1365	BR	2025	Men's Faculty Bathroom	BF	2/9/2021	6:39:00 AM
LVT-1367	BR	2025	Men's Faculty Bathroom	BF	2/9/2021	6:40:00 AM
LVT-1372	BR	2039	Boys Bathroom	BF	2/9/2021	6:34:00 AM
LVT-1374	BR	2039	Boys Bathroom	BF	2/9/2021	6:34:00 AM

Building Address

3359 Old Jerusalem Road
Levittown, NY 11756

*Pb 2005-
A. Long 02/23/21
Alyssa McDonald 2/22/21*

Analysis Type: ELAP 200.5

Lab Received: _____

Signature: _____

[Handwritten Signature]

Samplers Name: Michael Bowen

Samplers Signature: _____

JCB Project Manager: Anthony Lombardo

062102494



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Building: Jonas E. Salk Middle School

SALK

SRNT:

Levittown Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1376	BR	2039	Boys Bathroom	BF	2/9/2021	6:35:00 AM
LVT-1378	BR	2039	Boys Bathroom	BF	2/9/2021	6:36:00 AM
LVT-1585	GY	1067	Boys Entrance Into Gym	WF	2/9/2021	6:33:00 AM
LVT-1586	BR	2002	Girls Bathroom	BF	2/9/2021	6:46:00 AM
LVT-1587	BR	2002	Girls Bathroom	BF	2/9/2021	6:47:00 AM
LVT-1589	BR	2002	Girls Bathroom	BF	2/9/2021	6:48:00 AM
LVT-1591	BR	2002	Girls Bathroom	BF	2/9/2021	6:49:00 AM
LVT-2236	NO	1023	Health Vestibule	BW	2/9/2021	5:45:00 AM
LVT-2237	HA	1044	Auditorium Lobby	BW	2/9/2021	6:06:00 AM

Samples Submitted 81

21 FEB -9 PM 4: 59
OFFICE PLACEMENT

OrderID: 062102494

Building Address

3359 Old Jerusalem Road

Levittown, NY 11756

Pb200.5-

A. Lunn 2/23/21
Alyssa McDonald 2/22/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Gaele

Samplers Name: Michael Bowen

Samplers Signature:

JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/9/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Jonas E. Salk Middle School, Levittown Union Free
School District, 3359 Old Jerusalem Road, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062102494. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1221	Collected:	2/9/2021	Lab ID:	062102494-0001	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1224	Collected:	2/9/2021	Lab ID:	062102494-0002	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1226	Collected:	2/9/2021	Lab ID:	062102494-0003	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1231	Collected:	2/9/2021	Lab ID:	062102494-0004	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1235	Collected:	2/9/2021	Lab ID:	062102494-0005	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1238	Collected:	2/9/2021	Lab ID:	062102494-0006	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1240	Collected:	2/9/2021	Lab ID:	062102494-0007	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1242	Collected:	2/9/2021	Lab ID:	062102494-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0008</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0009</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0010</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0011</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0012</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0013</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0014</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0015</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1254		2/9/2021	062102494-0015				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1255		2/9/2021	062102494-0016				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.0	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1256		2/9/2021	062102494-0017				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.5 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1257		2/9/2021	062102494-0018				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1258		2/9/2021	062102494-0019				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	48	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1259		2/9/2021	062102494-0020				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1261		2/9/2021	062102494-0021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1264		2/9/2021	062102494-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0022</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0023</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0024</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0025</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0026</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0027</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0028</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0029</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1276	Collected:	2/9/2021	Lab ID:	062102494-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.4 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1277	Collected:	2/9/2021	Lab ID:	062102494-0030	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1278	Collected:	2/9/2021	Lab ID:	062102494-0031	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	9.4	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1280	Collected:	2/9/2021	Lab ID:	062102494-0032	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1281	Collected:	2/9/2021	Lab ID:	062102494-0033	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1283	Collected:	2/9/2021	Lab ID:	062102494-0034	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1284	Collected:	2/9/2021	Lab ID:	062102494-0035	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1285	Collected:	2/9/2021	Lab ID:	062102494-0036	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	13	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1287	Collected:	2/9/2021	Lab ID:	062102494-0037	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1289	Collected:	2/9/2021	Lab ID:	062102494-0038	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1292	Collected:	2/9/2021	Lab ID:	062102494-0039	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1293	Collected:	2/9/2021	Lab ID:	062102494-0040	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1294	Collected:	2/9/2021	Lab ID:	062102494-0041	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1297	Collected:	2/9/2021	Lab ID:	062102494-0042	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1298	Collected:	2/9/2021	Lab ID:	062102494-0043	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1298		2/9/2021	062102494-0043				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1299		2/9/2021	062102494-0044				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.0	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1300		2/9/2021	062102494-0045				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1301		2/9/2021	062102494-0046				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.5	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1302		2/9/2021	062102494-0047				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.9	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1303		2/9/2021	062102494-0048				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1304		2/9/2021	062102494-0049				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.3	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-1305		Collected: 2/9/2021	Lab ID: 062102494-0050				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1307		Collected: 2/9/2021	Lab ID: 062102494-0051				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

Client Sample Description LVT-1309		Collected: 2/9/2021	Lab ID: 062102494-0052				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	12	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

Client Sample Description LVT-1311		Collected: 2/9/2021	Lab ID: 062102494-0053				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1312		Collected: 2/9/2021	Lab ID: 062102494-0054				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1314		Collected: 2/9/2021	Lab ID: 062102494-0055				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1315		Collected: 2/9/2021	Lab ID: 062102494-0056				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1316		2/9/2021	062102494-0057				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1317		2/9/2021	062102494-0058				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1318		2/9/2021	062102494-0059				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1319		2/9/2021	062102494-0060				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1320		2/9/2021	062102494-0061				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.7	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1321		2/9/2021	062102494-0062				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1323		2/9/2021	062102494-0063				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.2	3.0 µg/L	2/17/2021	DI	2/22/2021	AM



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1351	Collected:	2/9/2021	Lab ID:	062102494-0064	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1361	Collected:	2/9/2021	Lab ID:	062102494-0065	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1362	Collected:	2/9/2021	Lab ID:	062102494-0066	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1363	Collected:	2/9/2021	Lab ID:	062102494-0067	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.9	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1364	Collected:	2/9/2021	Lab ID:	062102494-0068	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1365	Collected:	2/9/2021	Lab ID:	062102494-0069	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1367	Collected:	2/9/2021	Lab ID:	062102494-0070	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1372	Collected:	2/9/2021	Lab ID:	062102494-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1374	Collected:	2/9/2021	Lab ID:	062102494-0072	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Client Sample Description		LVT-1376	Collected:	2/9/2021	Lab ID:	062102494-0073	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1378	Collected:	2/9/2021	Lab ID:	062102494-0074	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.7 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1585	Collected:	2/9/2021	Lab ID:	062102494-0075	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.8 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1586	Collected:	2/9/2021	Lab ID:	062102494-0076	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1587	Collected:	2/9/2021	Lab ID:	062102494-0077	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102494
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/9/2021 04:59 PM
 Collected: 2/9/2021

Project: 19-45328, Jonas E. Salk Middle School, Levittown Union Free School District, 3359 Old Jerusalem Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0078</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0079</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0080</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	2/17/2021	DI	2/22/2021	AM
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>2/9/2021</i>	<i>Lab ID:</i>	<i>062102494-0081</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/22/2021	AM	2/23/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Laurel Lane School
LLS

062102536

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2064	BR	1000B1	Room 101 Boys Bathroom	BF	2/10/2021	5:06:00 AM
LVT-2066	BR	1002A	Room 104 Bathroom	BF	2/10/2021	5:07:00 AM
LVT-2069	OF	1003	Room 105	HW	2/10/2021	5:10:00 AM
LVT-2070	BR	1007	Bathroom D	BF	2/10/2021	5:11:00 AM
LVT-2072	BR	1007	Bathroom D	BF	2/10/2021	5:12:00 AM
LVT-2074	BR	1005A	Principal's Office Bathroom	BF	2/10/2021	6:02:00 AM
LVT-2075	OF	1008	Small Kitchen	KC	2/10/2021	6:02:00 AM
LVT-2076	HA	1016	Corridor (Server Room - Room 102)	WC	2/10/2021	5:17:00 AM
LVT-2077	BR	1010	Bathroom E	BF	2/10/2021	5:17:00 AM
LVT-2080	KI	1013	Kitchen	KC	2/10/2021	5:18:00 AM
LVT-2081	KI	1013	Kitchen	KC	2/10/2021	5:18:00 AM
LVT-2082	BR	1018	Visitor Bathroom	BF	2/10/2021	5:19:00 AM
LVT-2083	FL	1017	Room 108 Associate Executive Director Office	KC	2/10/2021	5:20:00 AM
LVT-2084	BR	1025	Bathroom G	BF	2/10/2021	5:21:00 AM
LVT-2085	CR	1027	Room 114 Nurse/Classroom 5	CF	2/10/2021	5:22:00 AM
LVT-2086	BR	1027A	Room 114/Classroom 5 Bathroom	BF	2/10/2021	5:23:00 AM
LVT-2088	HA	1033	Corridor (Gymnasium - Room 118)	DW	2/10/2021	5:24:00 AM
LVT-2089	BR	1028A	Room 115/Exercise Bathroom	BF	2/10/2021	5:28:00 AM

Building Address Pb2005 -
11 Laurel Lane
Levittown, NY 11756

A. J. [Signature] 02/29/21

Analysis Type: ELAP 200.5

Lab Received: _____

Signature: _____

[Signature]

Samplers Name: Michael Bowen

Samplers Signature: _____

JCB Project Manager: Anthony Lombardo

2
FEB 11 2021
P
H
S



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Laurel Lane School

LLS

062102536

Client: Levittown Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2091	CR	1032	Room 118/Classroom 6	CF	2/10/2021	5:26:00 AM
LVT-2092	BR	1032A	Room 118/Classroom 6 Bathroom	BF	2/10/2021	5:26:00 AM
LVT-2094	CR	1031	Room 117/Clinic 2 / Room 8	CF	2/10/2021	5:26:00 AM
LVT-2095	BR	1031A	Room 117/Clinic 2 Bathroom	BF	2/10/2021	5:28:00 AM
LVT-2097	CR	1030	Room 116/Clinic 1	CF	2/10/2021	5:30:00 AM
LVT-2098	BR	1030A	Room 116/Clinic 1 Bathroom	BF	2/10/2021	5:30:00 AM
LVT-2238	CR	1004	Room 106	BW	2/10/2021	5:15:00 AM
LVT-2239	CR	1032	Room 118/Classroom 6	BW	2/10/2021	5:30:00 AM
LVT-2240	HA	1033	Corridor (Gymnasium - Room 118)	HW	2/10/2021	5:34:00 AM
LVT-2241	HA	1016	Corridor (Server Room - Room 102)	HW	2/10/2021	5:35:00 AM

Samples Submitted 28

21 FEB 10 PM 4:16
ANALYTICAL, INC.
ORACLE PLACE, NY

Building Address P200.5 -
11 Laurel Lane
Levittown, NY 11756

A. Lamy 02/24/21

Analysis Type: ELAP 200.5

Lab Received: _____

Signature: _____

Gaele

Samplers Name: Michael Bowen

Samplers Signature: _____

JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/10/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Laurel Lane School, Levittown Union Free School
District, 11 Laurel Lane, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062102536. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102536
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/10/2021 04:16 PM
 Collected: 2/10/2021

Project: 19-45328, Laurel Lane School, Levittown Union Free School District, 11 Laurel Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0001</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	10	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0002</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.5	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0003</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.4	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0004</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	20	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0005</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.4 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0006</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.5	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0007</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0008</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102536
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/10/2021 04:16 PM
 Collected: 2/10/2021

Project: 19-45328, Laurel Lane School, Levittown Union Free School District, 11 Laurel Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2076 **Collected:** 2/10/2021 **Lab ID:** 062102536-0008

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	30	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2077 **Collected:** 2/10/2021 **Lab ID:** 062102536-0009

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2080 **Collected:** 2/10/2021 **Lab ID:** 062102536-0010

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.4	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2081 **Collected:** 2/10/2021 **Lab ID:** 062102536-0011

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	10	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2082 **Collected:** 2/10/2021 **Lab ID:** 062102536-0012

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2083 **Collected:** 2/10/2021 **Lab ID:** 062102536-0013

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Lead MDL: 1.0µg/L

Client Sample Description LVT-2084 **Collected:** 2/10/2021 **Lab ID:** 062102536-0014

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.9	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

Client Sample Description LVT-2085 **Collected:** 2/10/2021 **Lab ID:** 062102536-0015

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
--------	-----------	--------	----------	-----------	---------	---------------	---------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102536
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/10/2021 04:16 PM
 Collected: 2/10/2021

Project: 19-45328, Laurel Lane School, Levittown Union Free School District, 11 Laurel Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0015</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.7	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0016</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.4	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0017</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	120	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0018</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	23	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0019</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.6	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0020</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	25	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0021</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0022</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/22/2021	AM	2/23/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102536
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/10/2021 04:16 PM
 Collected: 2/10/2021

Project: 19-45328, Laurel Lane School, Levittown Union Free School District, 11 Laurel Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0022</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	71	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0023</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	18	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0024</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.8	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0025</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0026</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0027</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/10/2021</i>	<i>Lab ID:</i>	<i>062102536-0028</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	2/22/2021	AM	2/23/2021	AL
Lead MDL: 1.0µg/L							



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone/Fax: (516) 997-7251 / (516) 997-7528

<http://www.EMSL.com>

carleplacelab@emsl.com

EMSL Order:	062102536
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - Result was below the MDL.

RL = Reporting Limit (the value below which is not defensibly quantifiable)

D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School

062103866

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

SLE

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0496	SP	0001	Basement Break Room	KC	3/2/2021	6:13:00 AM
LVT-0498	BR	1001	Men's Bathroom	BF	3/2/2021	6:15:00 AM
LVT-0500	BR	1003	Women's Bathroom	BF	3/2/2021	6:16:00 AM
LVT-0502	BR	1004A	Unisex Bathroom Between Library & Media Center	BF	3/2/2021	6:18:00 AM
LVT-0504	BR	1006	Bathroom	BF	3/2/2021	6:19:00 AM
LVT-0506	CR	1011	Room 301	CF	3/2/2021	6:21:00 AM
LVT-0508	CR	1013	Room 303	CF	3/2/2021	6:23:00 AM
LVT-0509	BR	1014	Boys Bathroom	BF	3/2/2021	6:24:00 AM
LVT-0511	BR	1014	Boys Bathroom	BF	3/2/2021	6:24:00 AM
LVT-0513	BR	1014	Boys Bathroom	BF	3/2/2021	6:25:00 AM
LVT-0519	BR	1016	Girls Bathroom	BF	3/2/2021	6:25:00 AM
LVT-0521	BR	1016	Girls Bathroom	BF	3/2/2021	6:26:00 AM
LVT-0523	BR	1016	Girls Bathroom	BF	3/2/2021	6:26:00 AM
LVT-0525	CR	1018	Room 305	CF	3/2/2021	6:27:00 AM
LVT-0526	CR	1020	Room 307	CF	3/2/2021	6:28:00 AM
LVT-0527	CR	1022	Room 309	CF	3/2/2021	6:29:00 AM
LVT-0529	CR	1019	Room 308	CF	3/2/2021	6:31:00 AM
LVT-0530	CR	1017	Room 306	CF	3/2/2021	6:32:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb206.5
A. Lunny 03/09/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Handwritten Signature]

Samplers Name: Michael Bowen

Samplers Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

Client: Levittown Union Free School District
Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0531	CR	1012	Room 304	CF	3/2/2021	6:33:00 AM
LVT-0532	CR	1010	Room 302	CF	3/2/2021	6:34:00 AM
LVT-0533	CR	1008	Room 300	CF	3/2/2021	6:35:00 AM
LVT-0534	BR	1026C2A	Boys Physical Education Office Locker Room Area Bathroom	BF	3/2/2021	6:36:00 AM
LVT-0536	BR	1026C1	Boys Physical Education Office/Tool Storage Bathroom	BF	3/2/2021	6:37:00 AM
LVT-0538	KI	1024	Kitchen	SA	3/2/2021	6:38:00 AM
LVT-0539	KI	1024	Kitchen	KN	3/2/2021	6:39:00 AM
LVT-0540	KI	1024	Kitchen	KC	3/2/2021	6:40:00 AM
LVT-0541	KI	1024	Kitchen	KC	3/2/2021	6:41:00 AM
LVT-0542	BR	1024A	Kitchen Bathroom	BF	3/2/2021	6:42:00 AM
LVT-0546	CA	1025	Cafeteria	WF	3/2/2021	6:43:00 AM
LVT-0547	CA	1025	Cafeteria	HW	3/2/2021	6:44:00 AM
LVT-0549	BR	1033	Girls Bathroom	BF	3/2/2021	6:45:00 AM
LVT-0551	BR	1033	Girls Bathroom	BF	3/2/2021	6:45:00 AM
LVT-0553	BR	1033	Girls Bathroom	BF	3/2/2021	6:46:00 AM
LVT-0558	BR	1035	Boys Bathroom	BF	3/2/2021	6:46:00 AM
LVT-0560	BR	1035	Boys Bathroom	BF	3/2/2021	6:47:00 AM
LVT-0562	BR	1035	Boys Bathroom	BF	3/2/2021	6:47:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb 206.5 -
A. Jany 03/09/21

Analysis Type: ELAP 200.5 ^{AD}


Lab Received: *Maile*

Signature: *[Signature]*

Samplers Name: Michael Bowen

Samplers Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0564	CR	1037	Room 207 (Interior Walls Removed)	CF	3/2/2021	6:48:00 AM
LVT-0565	CR	1039	Room 205	CF	3/2/2021	6:49:00 AM
LVT-0566	CR	1041	Room 203	CF	3/2/2021	6:50:00 AM
LVT-0567	CR	1045	Room 201	CF	3/2/2021	6:51:00 AM
LVT-0568	CR	1045	Room 201	CF	3/2/2021	6:52:00 AM
LVT-0569	BR	1045B	Room 201 Bathroom	BF	3/2/2021	6:53:00 AM
LVT-0571	BR	N/A New Construction	Room 199 Bathroom	BF	3/2/2021	6:54:00 AM
LVT-0573	CR	N/A New Construction	Room 199	CF	3/2/2021	6:55:00 AM
LVT-0574	BR	N/A New Construction	Room 200 Bathroom	BF	3/2/2021	6:57:00 AM
LVT-0575	CR	N/A New Construction	Room 200	CF	3/2/2021	6:58:00 AM
LVT-0577	CR	1046	Room 202	CF	3/2/2021	6:59:00 AM
LVT-0578	BR	1046A	Room 202 Bathroom	BF	3/2/2021	7:00:00 AM
LVT-0579	CR	1042	Room 204	CF	3/2/2021	7:04:00 AM
LVT-0580	CR	1040	Room 206	CF	3/2/2021	7:05:00 AM
LVT-0582	CR	1038	Room 208	CF	3/2/2021	7:06:00 AM
LVT-0583	CR	1036	Room 210	CF	3/2/2021	7:07:00 AM
LVT-0584	BR	1032C1	Psychologist Office Bathroom	BF	3/2/2021	7:08:00 AM
LVT-0586	HA	1031	Corridor Outside Gym	WF	3/2/2021	7:09:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Jany 03/09/21

Analysis Type: ELAP 200.5 ^{AD}

Lab Received: *Chaele*

Signature: *[Signature]*

Samplers Name: Michael Bowen

Samplers Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

062103866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: ~~Normal 1 wk~~ Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0587	BR	1032B1	Social Worker Copy Room Bathroom	BF	3/2/2021	7:10:00 AM
LVT-0589	BR	1028	Men's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0591	BR	1027	Women's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0593	BR	1027	Women's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0596	BR	1049B	Room 115 Bathroom	BF	3/2/2021	7:13:00 AM
LVT-0597	CA	1048	Room 117	HW	3/2/2021	7:13:00 AM
LVT-0598	BR	1026B2	Gym Music Room 116 Bathroom	BF	3/2/2021	7:14:00 AM
LVT-0600	BR	1026B1A	Gym Music Room 116 Office Bathroom (Former Locker Room Office Bathroom)	BF	3/2/2021	7:14:00 AM
LVT-0602	BR	1054	Women's Bathroom	BF	3/2/2021	7:12:00 AM
LVT-0605	BR	1055	Women's Bathroom	BF	3/2/2021	7:19:00 AM
LVT-0607	FL	1056	Faculty Room	KC	3/2/2021	7:20:00 AM
LVT-0609	BR	1058A	Room 108 Bathroom	BF	3/2/2021	7:21:00 AM
LVT-0611	CR	1060	Room 106	CF	3/2/2021	7:22:00 AM
LVT-0612	BR	1060A	Room 106 Bathroom	BF	3/2/2021	7:23:00 AM
LVT-0614	CR	1062	Room 104	CF	3/2/2021	7:24:00 AM
LVT-0615	BR	1062A	Room 104 Bathroom	BF	3/2/2021	7:24:00 AM
LVT-0617	CR	1064	Room 102	CF	3/2/2021	7:25:00 AM
LVT-0618	BR	1064A	Room 102 Bathroom	BF	3/2/2021	7:26:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb200.5-

A. Luning 03/09/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

AO
Paule

Samplers Name: Michael Bowen

Samplers Signature:

JCB Project Manager:

Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0620	BR	1066A	Room 100 Bathroom	BF	3/2/2021	7:28:00 AM
LVT-0622	CR	N/A New Construction	Room 98	CF	3/2/2021	7:29:00 AM
LVT-0624	BR	N/A New Construction	Room 98 Bathroom	BF	3/2/2021	7:30:00 AM
LVT-0625	BR	N/A New Construction	Room 96 Bathroom	BF	3/2/2021	7:31:00 AM
LVT-0626	CR	N/A New Construction	Room 96	CF	3/2/2021	7:32:00 AM
LVT-0629	CR	N/A New Construction	Room 97	CF	3/2/2021	7:33:00 AM
LVT-0630	BR	N/A New Construction	Room 97 Bathroom	BF	3/2/2021	7:34:00 AM
LVT-0631	BR	N/A New Construction	Faculty Bathroom	BF	3/2/2021	7:35:00 AM
LVT-0632	CR	N/A New Construction	Room 99	CF	3/2/2021	7:36:00 AM
LVT-0634	BR	N/A New Construction	Room 99 Bathroom	BF	3/2/2021	7:38:00 AM
LVT-0635	BR	1067A	Room 101 Bathroom	BF	3/2/2021	7:39:00 AM
LVT-0636	CR	1067	Room 101	CF	3/2/2021	7:40:00 AM
LVT-0637	CR	1065	Room 103	CF	3/2/2021	7:41:00 AM
LVT-0638	BR	1065A	Room 103 Bathroom	BF	3/2/2021	7:42:00 AM
LVT-0640	CR	1063	Room 105	CF	3/2/2021	7:43:00 AM
LVT-0641	BR	1063A	Room 105 Bathroom	BF	3/2/2021	7:44:00 AM
LVT-0643	CR	1061	Room 107	CF	3/2/2021	7:45:00 AM
LVT-0644	BR	1061A	Room 107 Bathroom	BF	3/2/2021	7:45:00 AM

Building Address

4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Loney 03/09/21

Analysis Type: ELAP 200.5 ^{AO}

Lab Received: *Chelle*

Signature: *[Signature]*

Samplers Name: *Michael Bowen*

Samplers Signature: *[Signature]*

JCB Project Manager: *Anthony Lombardo*



Lead in Water: Chain of Custody for

062103866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0646	CR	1059	Room 109	CF	3/2/2021	7:46:00 AM
LVT-0647	BR	1059A	Room 109 Bathroom	BF	3/2/2021	7:47:00 AM
LVT-0649	NO	1057A	Nurses Office	NS	3/2/2021	7:48:00 AM
LVT-0650	BR	1057A1	Nurses Office Bathroom	BF	3/2/2021	7:49:00 AM
LVT-0652	KI	1053C	Main Office Corridor Closet	KC	3/2/2021	7:50:00 AM
LVT-0653	BR	1053B	Main Office Side Corridor Bathroom	BF	3/2/2021	7:51:00 AM
LVT-2265	HA	1023	Corridor Library To Room 309	BW	3/2/2021	6:21:00 AM
LVT-2266	HA	1047	Corridor 200 Wing	BW	3/2/2021	6:56:00 AM
LVT-2267	NO	1057C	Large Sick Room	BW	3/2/2021	7:48:00 AM

Samples Submitted 99

LABORATORY
CAFELPLACE, NY
21 MAR - 2 PM 3:05

Building Address
4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Juncy 03/09/21

Analysis Type: ELAP 200.5 ⁴⁰
Lab Received: *Charles*
Signature: *Charles*

Samplers Name: Michael Bowen
Samplers Signature: *Michael Bowen*
JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/22/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Lee Road Elementary School, Levittown Union Free
School District, 901 Lee Road, Wantagh, NY 11793**

The reference number for these samples is EMSL Order #062103419. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description LVT-1920			Collected: 2/11/2021	Lab ID: 062103419-0001			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.7	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1922			Collected: 2/11/2021	Lab ID: 062103419-0002			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1925			Collected: 2/11/2021	Lab ID: 062103419-0003			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1926			Collected: 2/11/2021	Lab ID: 062103419-0004			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1927			Collected: 2/11/2021	Lab ID: 062103419-0005			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1928			Collected: 2/11/2021	Lab ID: 062103419-0006			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1929			Collected: 2/11/2021	Lab ID: 062103419-0007			
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description		LVT-1931	Collected:	2/11/2021	Lab ID:	062103419-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1932	Collected:	2/11/2021	Lab ID:	062103419-0009	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1934	Collected:	2/11/2021	Lab ID:	062103419-0010	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1935	Collected:	2/11/2021	Lab ID:	062103419-0011	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1937	Collected:	2/11/2021	Lab ID:	062103419-0012	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.7	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1938	Collected:	2/11/2021	Lab ID:	062103419-0013	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1940	Collected:	2/11/2021	Lab ID:	062103419-0014	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description LVT-1942		Collected: 2/11/2021	Lab ID: 062103419-0015				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1943		Collected: 2/11/2021	Lab ID: 062103419-0016				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.0	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1945		Collected: 2/11/2021	Lab ID: 062103419-0017				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1947		Collected: 2/11/2021	Lab ID: 062103419-0018				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.0 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1949		Collected: 2/11/2021	Lab ID: 062103419-0019				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1951		Collected: 2/11/2021	Lab ID: 062103419-0020				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1953		Collected: 2/11/2021	Lab ID: 062103419-0021				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description		LVT-1955	Collected:	2/11/2021	Lab ID:	062103419-0022	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1957	Collected:	2/11/2021	Lab ID:	062103419-0023	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.1	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1959	Collected:	2/11/2021	Lab ID:	062103419-0024	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1961	Collected:	2/11/2021	Lab ID:	062103419-0025	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1963	Collected:	2/11/2021	Lab ID:	062103419-0026	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1965	Collected:	2/11/2021	Lab ID:	062103419-0027	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1967	Collected:	2/11/2021	Lab ID:	062103419-0028	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.4 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description LVT-1969 **Collected:** 2/11/2021 **Lab ID:** 062103419-0029

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1971 **Collected:** 2/11/2021 **Lab ID:** 062103419-0030

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1973 **Collected:** 2/11/2021 **Lab ID:** 062103419-0031

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.1	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1974 **Collected:** 2/11/2021 **Lab ID:** 062103419-0032

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1976 **Collected:** 2/11/2021 **Lab ID:** 062103419-0033

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1977 **Collected:** 2/11/2021 **Lab ID:** 062103419-0034

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1979 **Collected:** 2/11/2021 **Lab ID:** 062103419-0035

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1981 **Collected:** 2/11/2021 **Lab ID:** 062103419-0036

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description LVT-1981 **Collected:** 2/11/2021 **Lab ID:** 062103419-0036

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1982 **Collected:** 2/11/2021 **Lab ID:** 062103419-0037

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1984 **Collected:** 2/11/2021 **Lab ID:** 062103419-0038

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

Client Sample Description LVT-1985 **Collected:** 2/11/2021 **Lab ID:** 062103419-0039

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1986 **Collected:** 2/11/2021 **Lab ID:** 062103419-0040

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1987 **Collected:** 2/11/2021 **Lab ID:** 062103419-0041

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1988 **Collected:** 2/11/2021 **Lab ID:** 062103419-0042

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-1993 **Collected:** 2/11/2021 **Lab ID:** 062103419-0043

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description		LVT-1993	Collected:	2/11/2021	Lab ID:	062103419-0043	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1996	Collected:	2/11/2021	Lab ID:	062103419-0044	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-1997	Collected:	2/11/2021	Lab ID:	062103419-0045	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1999	Collected:	2/11/2021	Lab ID:	062103419-0046	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2001	Collected:	2/11/2021	Lab ID:	062103419-0047	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2003	Collected:	2/11/2021	Lab ID:	062103419-0048	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.7	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Client Sample Description		LVT-2004	Collected:	2/11/2021	Lab ID:	062103419-0049	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103419
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/22/2021 01:40 PM
 Collected: 2/11/2021

Project: 19-45328, Lee Road Elementary School, Levittown Union Free School District, 901 Lee Road, Wantagh, NY 11793

Analytical Results

Client Sample Description LVT-2242 **Collected:** 2/11/2021 **Lab ID:** 062103419-0050

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Client Sample Description LVT-2243 **Collected:** 2/11/2021 **Lab ID:** 062103419-0051

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	2/26/2021	AM	3/2/2021	AL

Lead MDL: 1.0µg/L

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Levittown Memorial Education Center
LMEC

062102864

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1760	CR	0005	Room 11	SN	2/12/2021	6:31:00 AM
LVT-1761	CR	0005	Room 11	SN	2/12/2021	6:31:00 AM
LVT-1762	CR	0005	Room 11	SN	2/12/2021	6:32:00 AM
LVT-1763	CR	0005	Room 11	SN	2/12/2021	6:32:00 AM
LVT-1764	CR	0005	Room 11	SN	2/12/2021	6:32:00 AM
LVT-1765	CR	0005	Room 11	CF	2/12/2021	6:30:00 AM
LVT-1766	CR	0006	Room 9	CF	2/12/2021	6:28:00 AM
LVT-1767	CR	0006	Room 9	SN	2/12/2021	6:28:00 AM
LVT-1768	CR	0007A	Room 7 Laundry Room 7A	CF	2/12/2021	6:26:00 AM
LVT-1769	CR	0007	Room 7	SN	2/12/2021	6:25:00 AM
LVT-1770	CR	0007	Room 7	SN	2/12/2021	6:25:00 AM
LVT-1771	CR	0007	Room 7	SN	2/12/2021	6:25:00 AM
LVT-1772	CR	0007	Room 7	SN	2/12/2021	6:24:00 AM
LVT-1773	CR	0007	Room 7	SN	2/12/2021	6:24:00 AM
LVT-1775	BR	0013	Ladies Bathroom	BF	2/12/2021	6:16:00 AM
LVT-1782	BR	0018A	Ladies Bathroom	BF	2/12/2021	6:16:00 AM
LVT-1784	BR	0019A	Men's Bathroom	BF	2/12/2021	6:15:00 AM
LVT-1786	CR	0020A	Room 5 Printing Room	CF	2/12/2021	6:20:00 AM

Building Address
150 Abbey Lane
Levittown, NY 11756

Pb2005 -

A. James 02/25/21

Analysis Type: ELAP 2005

Lab Received:

Signature:

[Handwritten Signature]

Samplers Name: *A. Khan (ASTP/11/220)*

Samplers Signature: *[Handwritten Signature]*

JCB Project Manager: *Meghan Gwan*



Lead in Water: Chain of Custody for

062102864

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Levittown Memorial Education Center
LMEC

Client: Levittown Union Free School District
Retest/New Install:
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1787	HA	0029	Corridor Room 5 to Custodial Area	DW	2/12/2021	6:12:00 AM
LVT-1788	CR	0027	Room 1 (Garage/Auto Shop)	CF	2/12/2021	6:12:00 AM
LVT-1789	CR	0027	Room 1 (Garage/Auto Shop)	CF	2/12/2021	6:12:00 AM
LVT-1790	CR	0027	Room 1 (Garage/Auto Shop)	DW	2/12/2021	6:12:00 AM
LVT-1792	HA	0029	Corridor Room 5 to Custodial Area	WF	2/12/2021	6:11:00 AM
LVT-1793	NO	0028	Room 2 Nurse Office	NS	2/12/2021	6:09:00 AM
LVT-1796	CC	0030	Custodial Corridor	HW	2/12/2021	6:36:00 AM
LVT-1799	CR	1003A1A	Room 120 Office Bathroom Closet	BF	2/12/2021	7:03:00 AM
LVT-1801	CR	1003B	Room 120 Storage/Old Bathroom	CF	2/12/2021	7:02:00 AM
LVT-1803	CR	1003B	Room 120 Storage/Old Bathroom	CF	2/12/2021	7:02:00 AM
LVT-1805	CR	1003B	Room 120 Storage/Old Bathroom	CF	2/12/2021	7:02:00 AM
LVT-1810	CR	1010	Room 115	CF	2/12/2021	6:58:00 AM
LVT-1811	KI	1021	Room 101 Kitchen	KC	2/12/2021	7:59:00 AM
LVT-1812	KI	1021	Room 101 Kitchen	KC	2/12/2021	7:59:00 AM
LVT-1813	BR	1020	Ladies Bathroom	BF	2/12/2021	6:52:00 AM
LVT-1815	BR	1020	Ladies Bathroom	BF	2/12/2021	6:52:00 AM
LVT-1820	BR	1018	Men's Bathroom	BF	2/12/2021	6:51:00 AM
LVT-1822	BR	1018	Men's Bathroom	BF	2/12/2021	6:51:00 AM

Building Address
150 Abbey Lane
Levittown, NY 11756

Pb208.5-
[Signature] 02/25/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Signature]

Samplers Name: Aina Caspini

Samplers Signature: *[Signature]*

JCB Project Manager: Meghan Gwynn

Order ID: 062102864

Page 2 of 5



Lead in Water: Chain of Custody for

0621 02864

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Levittown Memorial Education Center
LMEC

Client: Levittown Union Free School District
Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1824	FL	1017	Room 100	KC	2/12/2021	6:50:00 AM
LVT-1826	CR	1013	Room 108	CF	2/12/2021	6:55:00 AM
LVT-1827	CR	1011	Room 110	CF	2/12/2021	6:55:00 AM
LVT-1828	CR	1011	Room 110	SN	2/12/2021	6:57:00 AM
LVT-1842	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:10:00 AM
LVT-1844	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:10:00 AM
LVT-1846	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:10:00 AM
LVT-1848	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:11:00 AM
LVT-1850	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:11:00 AM
LVT-1852	BR	1029	Culinary Girls Dressing Room	BF	2/12/2021	7:11:00 AM
LVT-1855	CR	1034	Fitness Room 206	SN	2/12/2021	7:17:00 AM
LVT-1857	BR	1036	Ladies Bathroom	BF	2/12/2021	7:22:00 AM
LVT-1859	BR	1036	Ladies Bathroom	BF	2/12/2021	7:22:00 AM
LVT-1861	BR	1036	Ladies Bathroom	BF	2/12/2021	7:23:00 AM
LVT-1863	BR	1036	Ladies Bathroom	BF	2/12/2021	7:23:00 AM
LVT-1865	BR	1036	Ladies Bathroom	BF	2/12/2021	7:23:00 AM
LVT-1866	BR	1039D3	Room 209 Wood Shop Locker Room	BF	2/12/2021	7:30:00 AM
LVT-1868	BR	1039D3	Room 209 Wood Shop Locker Room	BF	2/12/2021	7:30:00 AM

Building Address
150 Abbey Lane
Levittown, NY 11756

Ph 2065 -
A. J. [Signature]

Analysis Type: ELAP 2005
Lab Received: *Gaele*
Signature: *[Signature]*

Samplers Name: *Alina Castelluzzo*
Samplers Signature: *Alina Castelluzzo*
JCB Project Manager: *Meghan Gwynn*

Page 3 of 5

OrderID: 062102864



Lead in Water: Chain of Custody for

062102864

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Levittown Memorial Education Center
LMEC

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk / Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1869	BR	1039D3	Room 209 Wood Shop Locker Room	BF	2/12/2021	7:30:00 AM
LVT-1870	BR	1039D3	Room 209 Wood Shop Locker Room	BF	2/12/2021	7:30:00 AM
LVT-1872	BR	1037	Boys Bathroom	BF	2/12/2021	7:27:00 AM
LVT-1874	BR	1037	Boys Bathroom	BF	2/12/2021	7:27:00 AM
LVT-1875	BR	1037	Boys Bathroom	BF	2/12/2021	7:27:00 AM
LVT-1876	BR	1038	Men's Bathroom	BF	2/12/2021	7:32:00 AM
LVT-1882	BR	1065A	Room 301 Bathroom	BF	2/12/2021	7:37:00 AM
LVT-1891	BR	1078	Men's Bathroom	BF	2/12/2021	7:40:00 AM
LVT-1892	BR	1077	Ladies Bathroom	BF	2/12/2021	7:41:00 AM
LVT-1894	SP	1073A	Room 422A	HW	2/12/2021	6:46:00 AM
LVT-1895	FL	1086A	Room 409 Kitchen/Conference	KC	2/12/2021	7:38:00 AM
LVT-1896	BR	1089	Room 414	BF	2/12/2021	7:46:00 AM
LVT-1897	BR	1090D2	Room 410 Assistant Superintendents Office Bathroom	BF	2/12/2021	7:14:00 AM
LVT-1898	BR	1094	Ladies Room	BF	2/12/2021	7:43:00 AM
LVT-1899	BR	1095	Men's Room	BF	2/12/2021	7:44:00 AM
LVT-1900	KI	1097	Room 401	KN	2/12/2021	7:52:00 AM
LVT-1901	KI	1097	Room 401	IM	2/12/2021	7:54:00 AM
LVT-1902	KI	1097	Room 401	KC	2/12/2021	7:55:00 AM

Building Address
150 Abbey Lane
Levittown, NY 11756

Ph 200.5-

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Alina Costantino

Samplers Signature: Alina Costantino

JCB Project Manager: Meghan Gwynn

Order ID: 062102864

Page 4 of 5



Lead in Water: Chain of Custody for

06210 2864

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Levittown Memorial Education Center
LMEC

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1903	KI	1097	Room 401	KC	2/12/2021	7:55:00 AM
LVT-1904	KI	1097	Room 401	KC	2/12/2021	7:55:00 AM
LVT-1905	KI	1097	Room 401	KC	2/12/2021	7:57:00 AM
LVT-1906	KI	1097	Room 401	KC	2/12/2021	7:57:00 AM
LVT-1907	KI	1097	Room 401	SN	2/12/2021	7:57:00 AM
LVT-1908	BR	1097C	Room 401 Freezer Room Bathroom	BF	2/12/2021	7:58:00 AM
LVT-1911	BR	1098B1	Superintendent Office Bathroom	BF	2/12/2021	7:48:00 AM
LVT-1912	BR	1098A1	Superintendent Conference Room Bathroom	BF	2/12/2021	7:49:00 AM
LVT-1913	OF	1098A1	Superintendent Conference Room Bathroom	KC	2/12/2021	7:49:00 AM
LVT-1916	BR	1027	Ladies Bathroom	BF	2/12/2021	7:13:00 AM
LVT-1918	BR	1040A1	Gym Office Bathroom	BF	2/12/2021	7:19:00 AM
LVT-2244	HA	1026	Corridor Rooms Ladies room To 111	BW	2/12/2021	6:54:00 AM
LVT-2245	HA	1041	Corridor Outside Gymnasium	BW	2/12/2021	7:15:00 AM

Samples Submitted 85

21 FEB 12 PM 3:55
ANALYTICAL, INC.
SAMPLE PLACE, NY

Building Address
150 Abbey Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: Alina Castiluzo

Samplers Signature: *[Signature]*

JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/12/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45328, Levittown Memorial Education Center, Levittown
Union Free School District, 150 Abbey Lane, Levittown, NY 11756

The reference number for these samples is EMSL Order #062102864. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

Client Sample Description				Collected:	Lab ID:		
LVT-1760				2/12/2021	062102864-0001		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	15	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1761				2/12/2021	062102864-0002		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	13	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1762				2/12/2021	062102864-0003		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1763				2/12/2021	062102864-0004		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	19	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1764				2/12/2021	062102864-0005		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1765				2/12/2021	062102864-0006		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.6	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1766				2/12/2021	062102864-0007		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	75	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-1767				2/12/2021	062102864-0008		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0008</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	46	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0009</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	10	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0010</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.6	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0011</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.8	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0012</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0013</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.9	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0014</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	10	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0015</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	10	3.0 µg/L	2/23/2021	AM	2/24/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1775	Collected:	2/12/2021	Lab ID:	062102864-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	14	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1782	Collected:	2/12/2021	Lab ID:	062102864-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.3	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1784	Collected:	2/12/2021	Lab ID:	062102864-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1786	Collected:	2/12/2021	Lab ID:	062102864-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1100 D	30 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1787	Collected:	2/12/2021	Lab ID:	062102864-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	62	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1788	Collected:	2/12/2021	Lab ID:	062102864-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	110	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1789	Collected:	2/12/2021	Lab ID:	062102864-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	49	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Client Sample Description		LVT-1790	Collected:	2/12/2021	Lab ID:	062102864-0022	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
<i>Client Sample Description</i> LVT-1790		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	14	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1792		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0023				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-1793		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0024				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.5	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1796		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0025				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1799		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0026				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	40	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1801		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0027				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.5	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1803		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0028				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	18	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i> LVT-1805		<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0029				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0029</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	19	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0030</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	27	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0031</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	54	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0032</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	110	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0033</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0034</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	34	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0035</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.8 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0036</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0036</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.4	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0037</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.7	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0038</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.3	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0039</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1500 D	30 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0040</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	410	6.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0041</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	130	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0042</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.8	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0043</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.8	3.0 µg/L	2/24/2021	AM	2/25/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0043</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.4	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0044</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	15	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0045</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	32	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0046</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	50	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0047</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.1	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0048</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	17	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0049</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.8	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0050</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.8	3.0 µg/L	2/24/2021	AM	2/25/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-1861				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0050		
200.5	Lead	3.7	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1863				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0051		
200.5	Lead	2.7 J	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-1865				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0052		
200.5	Lead	7.7	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1866				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0053		
200.5	Lead	42	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1868				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0054		
200.5	Lead	20	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1869				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0055		
200.5	Lead	30	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1870				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0056		
200.5	Lead	18	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i> LVT-1872				<i>Collected:</i> 2/12/2021	<i>Lab ID:</i> 062102864-0057		
200.5	Lead		3.0 µg/L	2/24/2021	AM	2/25/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0057</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	19	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0058</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.9	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0059</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	36	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0060</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.1	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0061</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	15	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0062</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	18	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0063</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	170	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0064</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	170	3.0 µg/L	2/24/2021	AM	2/25/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0064</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.9	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0065</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.4	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0066</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.4	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0067</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	25	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0068</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.9	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0069</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.7	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0070</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0071</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead						

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-1901	Collected:	2/12/2021	Lab ID:	062102864-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1902	Collected:	2/12/2021	Lab ID:	062102864-0072	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	230	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1903	Collected:	2/12/2021	Lab ID:	062102864-0073	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	32	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1904	Collected:	2/12/2021	Lab ID:	062102864-0074	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	470 D	30 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1905	Collected:	2/12/2021	Lab ID:	062102864-0075	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	98	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1906	Collected:	2/12/2021	Lab ID:	062102864-0076	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	17	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1907	Collected:	2/12/2021	Lab ID:	062102864-0077	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	160	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
Client Sample Description		LVT-1908	Collected:	2/12/2021	Lab ID:	062102864-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062102864
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0078</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	93	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0079</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.7	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0080</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	41	3.0 µg/L	2/24/2021	AM	2/25/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0081</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.8	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0082</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0083</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	14	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0084</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>2/12/2021</i>	<i>Lab ID:</i>	<i>062102864-0085</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order:	062102864
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 2/12/2021 03:55 PM
 Collected: 2/12/2021

Project: 19-45328, Levittown Memorial Education Center, Levittown Union Free School District, 150 Abbey Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2245 **Collected:** 2/12/2021 **Lab ID:** 062102864-0085

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	2/23/2021	AM	2/24/2021	AL
Lead MDL: 1.0µg/L							

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Little Red School House
LRS

062104095

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1400	CR	1002	3 Year Old Classroom	CF	3/4/2021	5:54:00 AM
LVT-1401	BR	1002A	3 Year Old Classroom Closet	BF	3/4/2021	5:54:00 AM
LVT-1402	CR	1001	2 Year Old Classroom	CF	3/4/2021	5:55:00 AM
LVT-1404	BR	1001A	2 Year Old Classroom Closet	BF	3/4/2021	5:56:00 AM
LVT-1407	HA	1000	Main Entrance Corridor	WF	3/4/2021	5:57:00 AM
LVT-1408	BR	1003	Bathroom	BF	3/4/2021	5:58:00 AM
LVT-1409	BR	1005	Bathroom	BF	3/4/2021	5:59:00 AM
LVT-1410	BR	1007A	Office Bathroom	BF	3/4/2021	6:00:00 AM

Samples Submitted 8

21 MAR -4 PM 1:14
SAMPLE PLACE, NY

Building Address
Sand Hill Road & Wantagh Ave
Levittown, NY 11756

Pb 200.5 -
A. Liang 6/3/09/24

Analysis Type: ELAP 200.5

Lab Recieved: *[Signature]*

Signature: *[Signature]*

Samplers Name: Arina Castelluzzo

Samplers Signature: *[Signature]*

JCB Project Manager: M. P. Khan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Little Red School House, Levittown Union Free School
District, Sand Hill Road & Wantagh Ave, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062104095. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104095
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:14 PM
 Collected: 3/4/2021

Project: 19-45328, Little Red School House, Levittown Union Free School District, Sand Hill Road & Wantagh Ave, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1400		3/4/2021	062104095-0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1401		3/4/2021	062104095-0002				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1402		3/4/2021	062104095-0003				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1404		3/4/2021	062104095-0004				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1407		3/4/2021	062104095-0005				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1408		3/4/2021	062104095-0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1409		3/4/2021	062104095-0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104095
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:14 PM
 Collected: 3/4/2021

Project: 19-45328, Little Red School House, Levittown Union Free School District, Sand Hill Road & Wantagh Ave, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-1410 **Collected:** 3/4/2021 **Lab ID:** 062104095-0008

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.7	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328

Building: New
Building/
Dispatch
Office

Client:

Re-test/New Install []

Turn Around: Normal (twk)

Rush _____

Sample ID	Functional Space Type	Outlet Type	AHERA ID	Common Room Name	Sample Date	Sample Time
LVT-1442	FL	WC	1000	Common Area	3/4/2021	5:34 A.M.
LVT-1443	FL	WC	1000	Common Area	3/4/2021	5:35 A.M.
LVT-1444	BR	BF	1000A	Bathroom	3/4/2021	5:35 A.M.
LVT-1445	BR	BF	1000A	Bathroom	3/4/2021	5:36 A.M.
LVT-1446	BR	BF	1000B	Bathroom	3/4/2021	5:37 A.M.
LVT-1447	BR	BF	1000B	Bathroom	3/4/2021	5:37 A.M.

Total Number of Samples: 6

21 MAR -4 PM 1:11
SCALE PLACEMENT

Building Address
850 Seaman Neck Road
Levittown, NY 11756

Pb200.5 -

A. J. [Signature] 03/04/21

Analysis Type: ELAP 200.5 (A)

Lab Received: Unique Metrol

Signature: um 3/4/21 1:11 PM

Samplers Name: Alina Castelluzzo

Samplers Signature: Alina Castelluzzo

JCB Project Manager: Meghan Gwinn

062104006



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

**New Building/ Dispatch Office, 850 Seaman Neck Road,
Levittown, NY 11756, 19-45328**

The reference number for these samples is EMSL Order #062104006. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104006
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 01:11 PM
 Collected: 3/4/2021

Project: **New Building/ Dispatch Office, 850 Seaman Neck Road, Levittown, NY 11756, 19-45328**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1442 Common Area		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1443 Common Area		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1444 Bathroom		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	3.1	3.0 µg/L	3/8/2021	AM	3/9/2021
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1445 Bathroom		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1446 Bathroom		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-1447 Bathroom		3/4/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021

Definitions:

MDL - method detection limit
 J - Result was below the reporting limit, but at or above the MDL
 ND - Result was below the MDL
 RL = Reporting Limit (the value below which is not defensibly quantifiable)
 D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Northside Elementary School
NES

062104538

Client:
Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0672	BR	0001D	Cafeteria Bathroom Vestibule	BF	3/9/2021	5:16:00 AM
LVT-0673	BR	0001B	Cafeteria Bathroom Boys	BF	3/9/2021	5:16:00 AM
LVT-0674	BR	0001C	Cafeteria Bathroom Girls	BF	3/9/2021	5:17:00 AM
LVT-0675	KI	0001A	Kitchen	KC	3/9/2021	5:18:00 AM
LVT-0676	KI	0001A	Kitchen	KC	3/9/2021	5:18:00 AM
LVT-0677	KI	0001A	Kitchen	SA	3/9/2021	5:19:00 AM
LVT-0678	BR	1048C	Nurse Closet Adjacent Bathroom	BF	3/9/2021	5:21:00 AM
LVT-0680	CR	1052	101	CF	3/9/2021	5:22:00 AM
LVT-0681	CR	1056	103C (Interior Walls Removed)	CF	3/9/2021	5:23:00 AM
LVT-0682	CR	1059	105	CF	3/9/2021	5:24:00 AM
LVT-0684	BR	1059A	105 Bathroom	BF	3/9/2021	5:24:00 AM
LVT-0686	CR	1060	106A	CF	3/9/2021	5:25:00 AM
LVT-0687	CR	N/A New Construction	Room 107	CF	3/9/2021	5:26:00 AM
LVT-0689	BR	N/A New Construction	Room 107 Bathroom	BF	3/9/2021	5:27:00 AM
LVT-0690	CR	N/A New Construction	Room 108	CF	3/9/2021	5:28:00 AM
LVT-0692	BR	N/A New Construction	Room 108 Bathroom	BF	3/9/2021	5:29:00 AM
LVT-0693	CR	1057	104	CF	3/9/2021	5:30:00 AM
LVT-0694	BR	1057A	104 Bathroom	BF	3/9/2021	5:31:00 AM

RECEIVED
ANALYTICAL INC
MAR 9 11 10 AM '21

Building Address
35 Pelican Road
Levittown, NY 11756

Pb20c.5-
A. J. [Signature] 03/19/21

Analysts Type: ELAP 200.5

Lab Recieved:

Signature:

[Signature]

Samplers Name: Alina Castelluzzo
Samplers Signature: Alina Castelluzzo
JCB Project Manager: Meghan Bwyll



Lead in Water: Chain of Custody for

062104538

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Northside Elementary School
NES

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0696	CR	1053	102	CF	3/9/2021	5:32:00 AM
LVT-0697	BR	1063	Boys Bathroom	BF	3/9/2021	5:33:00 AM
LVT-0699	BR	1063	Boys Bathroom	BF	3/9/2021	5:33:00 AM
LVT-0701	BR	1063	Boys Bathroom	BF	3/9/2021	5:34:00 AM
LVT-0703	BR	1063	Boys Bathroom	BF	3/9/2021	5:34:00 AM
LVT-0708	BR	1065	Girls Bathroom	BF	3/9/2021	5:35:00 AM
LVT-0710	BR	1065	Girls Bathroom	BF	3/9/2021	5:35:00 AM
LVT-0712	BR	1065	Girls Bathroom	BF	3/9/2021	5:36:00 AM
LVT-0714	BR	1065	Girls Bathroom	BF	3/9/2021	5:36:00 AM
LVT-0716	CR	1067	207	CF	3/9/2021	5:37:00 AM
LVT-0717	CR	1068	209	CF	3/9/2021	5:38:00 AM
LVT-0718	CR	1070	211	CF	3/9/2021	5:39:00 AM
LVT-0719	CR	1074	213	CF	3/9/2021	5:40:00 AM
LVT-0720	CR	1073	Art Room 214	CF	3/9/2021	5:48:00 AM
LVT-0721	CR	1072	212	CF	3/9/2021	5:49:00 AM
LVT-0723	CR	1071	210	CF	3/9/2021	5:50:00 AM
LVT-0724	CR	1069	208	CF	3/9/2021	5:51:00 AM
LVT-0725	NO	1047C	Main Office Suite Copy Room	BF	3/9/2021	5:52:00 AM

RECEIVED
ENVIRONMENTAL
LABORATORY
3/11/21

Building Address
35 Pelican Road
Levittown, NY 11756

Pb200.5-

Alger Young 3/31/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Signature]

Samplers Name: Alina Caspelluzzo
Samplers Signature: [Signature]
JCB Project Manager: Meghan Gwynn

Order ID: 062104538

Page 2 of 5



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Northside Elementary School
NES

062104538

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0727	CR	1018	421	CF	3/9/2021	5:54:00 AM
LVT-0728	CR	1021	423	CF	3/9/2021	5:55:00 AM
LVT-0729	CR	1023	425	CF	3/9/2021	6:10:00 AM
LVT-0730	FL	1039	531 Faculty Lounge	KC	3/9/2021	6:11:00 AM
LVT-0731	CR	1041	533	CF	3/9/2021	6:12:00 AM
LVT-0732	CR	1040	532	CF	3/9/2021	6:13:00 AM
LVT-0733	BR	1030	Faculty Bathroom	BF	3/9/2021	6:14:00 AM
LVT-0735	BR	1029	Boys Bathroom	BF	3/9/2021	6:14:00 AM
LVT-0737	BR	1029	Boys Bathroom	BF	3/9/2021	6:15:00 AM
LVT-0739	BR	1029	Boys Bathroom	BF	3/9/2021	6:15:00 AM
LVT-0741	BR	1029	Boys Bathroom	BF	3/9/2021	6:16:00 AM
LVT-0746	BR	1027	Girls Bathroom	BF	3/9/2021	6:16:00 AM
LVT-0748	BR	1027	Girls Bathroom	BF	3/9/2021	5:17:00 AM
LVT-0750	BR	1027	Girls Bathroom	BF	3/9/2021	6:18:00 AM
LVT-0752	BR	1027	Girls Bathroom	BF	3/9/2021	6:18:00 AM
LVT-0754	CR	1024	426	CF	3/9/2021	6:19:00 AM
LVT-0755	CR	1022	424	CF	3/9/2021	6:20:00 AM
LVT-0757	OF	1019	420	HW	3/9/2021	5:11:00 AM

Building Address
35 Pelican Road
Levittown, NY 11756

Pb 200.5-

Alger Luning 03/19/21

Analysis Type: ELAP 200.5

Lab Received:

Caule

Signature:

Samplers Name: *Aimee Castelluzzo*
Samplers Signature: *Aimee Castelluzzo*
JCB Project Manager: *Meghan Gwynn*

REC'D
ENVIRONMENTAL
LABORATORY
MAR 11 2021
LEVITTOWN, NY



Lead in Water: Chain of Custody for

062104538

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Northside Elementary School
NES

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0758	BR	1016	Girls Bathroom	BF	3/9/2021	6:21:00 AM
LVT-0760	BR	1016	Girls Bathroom	BF	3/9/2021	6:21:00 AM
LVT-0764	BR	1016	Girls Bathroom	BF	3/9/2021	6:22:00 AM
LVT-0769	BR	1014	Boys Bathroom	BF	3/9/2021	6:23:00 AM
LVT-0771	BR	1014	Boys Bathroom	BF	3/9/2021	6:23:00 AM
LVT-0773	BR	1014	Boys Bathroom	BF	3/9/2021	6:24:00 AM
LVT-0775	BR	1014	Boys Bathroom	BF	3/9/2021	6:24:00 AM
LVT-0777	CR	1005	315	CF	3/9/2021	6:25:00 AM
LVT-0779	CR	1008	317	CF	3/9/2021	6:26:00 AM
LVT-0780	CR	1011	319A	CF	3/9/2021	6:27:00 AM
LVT-0781	BR	1011A	319A Bathroom	BF	3/9/2021	6:28:00 AM
LVT-0783	CR	1010	320A	CF	3/9/2021	6:29:00 AM
LVT-0784	BR	1010A	320A Bathroom	BF	3/9/2021	6:30:00 AM
LVT-0786	CR	1009	318	CF	3/9/2021	6:31:00 AM
LVT-0787	CR	1006	316A	CF	3/9/2021	6:32:00 AM
LVT-0788	BR	1002A	Music Office Room 314A Kitchenette	BF	3/9/2021	6:33:00 AM
LVT-0790	HA	1045	Corridor Main Office To Gym	WF	3/9/2021	6:34:00 AM
LVT-0791	BR	1001	Men's Bathroom	BF	3/9/2021	6:35:00 AM

Building Address
35 Pelican Road
Levittown, NY 11756

Pb 203.5
Algo Lunny 03/19/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

C. Faele

Samplers Name: Alina Castellano
Samplers Signature: Alina Castellano
JCB Project Manager: Meghan Gwynn



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Northside Elementary School
NES

0621 04538

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0793	BR	1043	Bathroom Near Library (Women)	BF	3/9/2021	6:36:00 AM
LVT-0795	BR	1047B1	Main Office Principal's Office Bathroom	BF	3/9/2021	6:37:00 AM
LVT-2200	KI	N/A New Construction	Kitchen	KC	3/9/2021	5:41:00 AM
LVT-2201	KI	N/A New Construction	Kitchen	SN	3/9/2021	5:41:00 AM
LVT-2202	KI	N/A New Construction	Kitchen	KC	3/9/2021	5:42:00 AM
LVT-2203	KI	N/A New Construction	Kitchen	KC	3/9/2021	5:42:00 AM
LVT-2204	KI	N/A New Construction	Kitchen	SN	3/9/2021	5:43:00 AM
LVT-2205	KI	N/A New Construction	Kitchen	KC	3/9/2021	5:43:00 AM
LVT-2206	KI	N/A New Construction	Kitchen	KN	3/9/2021	5:44:00 AM
LVT-2207	KI	N/A New Construction	Serving Area	KN	3/9/2021	5:44:00 AM
LVT-2208	KI	N/A New Construction	Kitchen	KN	3/9/2021	5:45:00 AM
LVT-2209	CA	N/A New Construction	Cafeteria	HW	3/9/2021	5:46:00 AM
LVT-2212	CA	N/A New Construction	Cafeteria	WF	3/9/2021	5:47:00 AM
LVT-2269	NO	1048	Nurse Office	BW	3/9/2021	5:53:00 AM

Samples Submitted 86

RECEIVED
ENVIRONMENTAL, INC.
LABORATORY
3-9 PM 4:10

Building Address
35 Pelican Road
Levittown, NY 11756

PB2005-
Alan Lunny 03/19/21

Analysis Type: ELAP 200.5

Lab Received: *Chaele*

Signature: *[Signature]*

Samplers Name: *Alina Castellano*

Samplers Signature: *Alina Castellano*

JCB Project Manager: *Meghan Gwynn*



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/11/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Northside Elementary School, Levittown Union Free
School District, 35 Pelican Road, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062104538. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
<i>Client Sample Description</i> LVT-0672				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0001		
200.5	Lead	3.8	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0673				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0002		
200.5	Lead	12	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0674				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0003		
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0675				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0004		
200.5	Lead	150	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0676				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0005		
200.5	Lead	43	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0677				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0006		
200.5	Lead	100	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0678				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0007		
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i> LVT-0680				<i>Collected:</i> 3/9/2021		<i>Lab ID:</i> 062104538-0008		
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0680	Collected:	3/9/2021	Lab ID:	062104538-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.8 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0681	Collected:	3/9/2021	Lab ID:	062104538-0009	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0682	Collected:	3/9/2021	Lab ID:	062104538-0010	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0684	Collected:	3/9/2021	Lab ID:	062104538-0011	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.7 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0686	Collected:	3/9/2021	Lab ID:	062104538-0012	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.8 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0687	Collected:	3/9/2021	Lab ID:	062104538-0013	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0689	Collected:	3/9/2021	Lab ID:	062104538-0014	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0690	Collected:	3/9/2021	Lab ID:	062104538-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0692	Collected:	3/9/2021	Lab ID:	062104538-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0693	Collected:	3/9/2021	Lab ID:	062104538-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0694	Collected:	3/9/2021	Lab ID:	062104538-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0696	Collected:	3/9/2021	Lab ID:	062104538-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0697	Collected:	3/9/2021	Lab ID:	062104538-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.1	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-0699	Collected:	3/9/2021	Lab ID:	062104538-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
<i>Client Sample Description</i> LVT-0701		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0703		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0023				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0708		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0024				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i> LVT-0710		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0025				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i> LVT-0712		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0026				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.8 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0714		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0027				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.9 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i> LVT-0716		<i>Collected:</i> 3/9/2021	<i>Lab ID:</i> 062104538-0028				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.8 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0029</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0030</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0031</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.4	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0032</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0033</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	26	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0034</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0035</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/9/2021</i>	<i>Lab ID:</i>	<i>062104538-0036</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0725		3/9/2021		062104538-0036			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0727		3/9/2021		062104538-0037			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.3	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0728		3/9/2021		062104538-0038			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.0	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0729		3/9/2021		062104538-0039			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0730		3/9/2021		062104538-0040			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0731		3/9/2021		062104538-0041			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.2	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0732		3/9/2021		062104538-0042			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0733		3/9/2021		062104538-0043			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0733		3/9/2021	062104538-0043				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0735		3/9/2021	062104538-0044				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.4 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0737		3/9/2021	062104538-0045				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0739		3/9/2021	062104538-0046				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0741		3/9/2021	062104538-0047				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.5 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0746		3/9/2021	062104538-0048				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	20	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0748		3/9/2021	062104538-0049				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	20	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0750				3/9/2021			062104538-0050	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0752				3/9/2021			062104538-0051	
200.5	Lead	4.5	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0754				3/9/2021			062104538-0052	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0755				3/9/2021			062104538-0053	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0757				3/9/2021			062104538-0054	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0758				3/9/2021			062104538-0055	
200.5	Lead	2.6 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
Lead MDL: 1.0µg/L								
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0760				3/9/2021			062104538-0056	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0764				3/9/2021			062104538-0057	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0764 **Collected:** 3/9/2021 **Lab ID:** 062104538-0057

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0769 **Collected:** 3/9/2021 **Lab ID:** 062104538-0058

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	82	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0771 **Collected:** 3/9/2021 **Lab ID:** 062104538-0059

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	12	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0773 **Collected:** 3/9/2021 **Lab ID:** 062104538-0060

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0775 **Collected:** 3/9/2021 **Lab ID:** 062104538-0061

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.7	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0777 **Collected:** 3/9/2021 **Lab ID:** 062104538-0062

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Lead MDL: 1.0µg/L

Client Sample Description LVT-0779 **Collected:** 3/9/2021 **Lab ID:** 062104538-0063

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-0780 **Collected:** 3/9/2021 **Lab ID:** 062104538-0064

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0780		3/9/2021		062104538-0064			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.6	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0781		3/9/2021		062104538-0065			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.2	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0783		3/9/2021		062104538-0066			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0784		3/9/2021		062104538-0067			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.4	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0786		3/9/2021		062104538-0068			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	23	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0787		3/9/2021		062104538-0069			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.9	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0788		3/9/2021		062104538-0070			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	13	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-0790		3/9/2021		062104538-0071			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description				Collected:	Prep Date	Analyst	Analysis Date	Analyst
LVT-0790				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-0791				3/9/2021		DI	3/19/2021	AL
Lead MDL: 1.0µg/L								
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	1.4 J	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-0793				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	5.5	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-0795				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	7.6	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-2200				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-2201				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-2202				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	
LVT-2203				3/9/2021		DI	3/19/2021	AL
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst	
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104538
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-2203	Collected:	3/9/2021	Lab ID:	062104538-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2204	Collected:	3/9/2021	Lab ID:	062104538-0079	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2205	Collected:	3/9/2021	Lab ID:	062104538-0080	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2206	Collected:	3/9/2021	Lab ID:	062104538-0081	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2207	Collected:	3/9/2021	Lab ID:	062104538-0082	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2208	Collected:	3/9/2021	Lab ID:	062104538-0083	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2209	Collected:	3/9/2021	Lab ID:	062104538-0084	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL
Client Sample Description		LVT-2212	Collected:	3/9/2021	Lab ID:	062104538-0085	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order:	062104538
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/9/2021 04:12 PM
 Collected: 3/9/2021

Project: 19-45328, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2212 **Collected:** 3/9/2021 **Lab ID:** 062104538-0085

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Client Sample Description LVT-2269 **Collected:** 3/9/2021 **Lab ID:** 062104538-0086

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/18/2021	DI	3/19/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Seaman Neck Middle School
SEA

062104164

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal ~~1 wk~~ Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2103	CR	2000	Room 201	CF	3/5/2021	5:12:00 AM
LVT-2104	CR	2001A	Room 203 Classroom	CF	3/5/2021	5:13:00 AM
LVT-2105	CR	2005	Room 204	CF	3/5/2021	5:15:00 AM
LVT-2107	CR	2004	Room 205	CF	3/5/2021	5:14:00 AM
LVT-2108	BR	2006	Girls Bathroom	BF	3/5/2021	5:15:00 AM
LVT-2109	BR	2006	Girls Bathroom	BF	3/5/2021	5:15:00 AM
LVT-2110	BR	2006	Girls Bathroom	BF	3/5/2021	5:16:00 AM
LVT-2111	BR	2006	Girls Bathroom	BF	3/5/2021	5:16:00 AM
LVT-2113	BR	2008	Boys Bathroom	BF	3/5/2021	5:17:00 AM
LVT-2115	BR	2008	Boys Bathroom	BF	3/5/2021	5:17:00 AM
LVT-2116	BR	2008	Boys Bathroom	BF	3/5/2021	5:18:00 AM
LVT-2117	BR	2008	Boys Bathroom	BF	3/5/2021	5:18:00 AM
LVT-2119	CR	2009A	Room 207 Classroom	CF	3/5/2021	5:19:00 AM
LVT-2120	CR	2010	Room 209	CF	3/5/2021	5:20:00 AM
LVT-2121	CR	2011	Room 206	CF	3/5/2021	5:21:00 AM
LVT-2122	CR	2013A	Room 211 Classroom	CF	3/5/2021	5:22:00 AM
LVT-2123	CR	2012	Room 208	CF	3/5/2021	5:23:00 AM
LVT-2124	CR	2014	Room 210	CF	3/5/2021	5:23:00 AM

Building Address
1100 Crestline Place
Seaford, NY 11783

Pg 206.5 -

Alvin Long 03/16/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Michael Bowen

Samplers Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Seaman Neck Middle School
SEA

062104164

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk. Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2125	CR	1032A	Room 110 Classroom	CF	3/5/2021	5:25:00 AM
LVT-2126	CR	1031A	Room 108 Classroom	CF	3/5/2021	5:26:00 AM
LVT-2127	OF	1030A	Thinking Room I Resource Room	KC	3/5/2021	5:28:00 AM
LVT-2128	CR	1029	Room 106	CF	3/5/2021	5:30:00 AM
LVT-2129	CR	1028	Room 109	CF	3/5/2021	5:31:00 AM
LVT-2130	BR	1026	Boys Bathroom	BF	3/5/2021	5:32:00 AM
LVT-2132	BR	1026	Boys Bathroom	BF	3/5/2021	5:33:00 AM
LVT-2135	BR	1024	Women's Bathroom	BF	3/5/2021	5:34:00 AM
LVT-2137	BR	1024	Women's Bathroom	BF	3/5/2021	5:35:00 AM
LVT-2139	CR	1027A	Room 107 Classroom	CF	3/5/2021	5:36:00 AM
LVT-2140	CR	1023A	Room 104 Classroom	CF	3/5/2021	5:37:00 AM
LVT-2142	ST	1021	Book Storage	HW	3/5/2021	5:38:00 AM
LVT-2143	CR	1020	Room 102	CF	3/5/2021	5:39:00 AM
LVT-2144	CR	1019	Room 103	CF	3/5/2021	5:40:00 AM
LVT-2145	CR	1018A	Room 101 Classroom	CF	3/5/2021	5:41:00 AM
LVT-2147	HA	1012	Corridor Men's Bathroom To Principal's Office	DW	3/5/2021	5:41:00 AM
LVT-2148	BR	1011	Men's Room	BF	3/5/2021	5:42:00 AM
LVT-2150	BR	1010	Ladies Room	BF	3/5/2021	5:43:00 AM

Building Address
1100 Crestline Place
Seaford, NY 11783

Pb 200.5 -

Alvin Lunny 03/16/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Michael Bowles

Samplers Name: Michael Bowles

Samplers Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Seaman Neck Middle School
SEA

062104164

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

OrderID: 062104164

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2151	BR	1006C	Custodial Office Bathroom	BF	3/5/2021	5:44:00 AM
LVT-2153	NO	1000	Nurse's Office	NS	3/5/2021	5:45:00 AM
LVT-2154	BR	1000B	Nurse's Bathroom	BF	3/5/2021	5:46:00 AM
LVT-2156	HE	1002B	K2 Kitchen/Classroom	EC	3/5/2021	5:47:00 AM
LVT-2157	CR	1003	Shop Room	CF	3/5/2021	5:48:00 AM
LVT-2159	KI	1034	Kitchen	KN	3/5/2021	5:49:00 AM
LVT-2160	KI	1034	Kitchen	KC	3/5/2021	5:50:00 AM
LVT-2161	KI	1034	Kitchen	KC	3/5/2021	5:51:00 AM
LVT-2162	KI	1034	Kitchen	SN	3/5/2021	5:52:00 AM
LVT-2163	BR	1034C	Kitchen Bathroom	BF	3/5/2021	5:53:00 AM
LVT-2164	CA	1035	Cafeteria	WC	3/5/2021	5:54:00 AM
LVT-2165	FL	1036	Faculty Room	KC	3/5/2021	5:55:00 AM
LVT-2166	BR	1037	Ladies Bathroom	BF	3/5/2021	5:56:00 AM
LVT-2168	BR	1037	Ladies Bathroom	BF	3/5/2021	5:57:00 AM
LVT-2170	BR	1038	Men's Bathroom	BF	3/5/2021	5:58:00 AM
LVT-2171	CR	1052	Room 304	CF	3/5/2021	5:59:00 AM
LVT-2172	HE	1051	Room 302	EC	3/5/2021	6:00:00 AM
LVT-2173	CR	1053A	Room 303 Classroom	CF	3/5/2021	6:01:00 AM

Building Address
1100 Crestline Place
Seaford, NY 11783

Pb 200.5 -

Alvin Young 03/16/21

Analysis Type: ELAP 200.5

Lab Received: *dale*

Signature: *[Signature]*

Sampler's Name: Michael Bowen

Sampler's Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo

Page 3 of 4



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Seaman Neck Middle School

SEA

062104164

Client:
Levittown Union Free School District

Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2174	HE	1050	Room 301	EC	3/5/2021	6:02:00 AM
LVT-2175	HE	1050	Room 301	EC	3/5/2021	6:02:00 AM
LVT-2176	BR	1049	Girls Bathroom	BF	3/5/2021	6:03:00 AM
LVT-2177	HA	1054	Corridor Outside Gymnasium	DW	3/5/2021	6:04:00 AM
LVT-2178	BR	1048	Men's Bathroom	BF	3/5/2021	6:05:00 AM
LVT-2180	HA	1054	Corridor Outside Gymnasium	DW	3/5/2021	6:06:00 AM
LVT-2181	BR	1047A1	Physical Education Office Bathroom	BF	3/5/2021	6:07:00 AM
LVT-2185	BR	1040A1	Physical Therapy Office Bathroom	BF	3/5/2021	6:08:00 AM
LVT-2187	BR	1040B1	Gym Coach Office Bathroom	BF	3/5/2021	6:09:00 AM
LVT-2189	CR	1041	Room 305	CF	3/5/2021	6:10:00 AM

Samples Submitted 64

Building Address
1100 Crestline Place
Seaford, NY 11783

9b 200.5 (61-64)
A. Long 2/23/21

Analysts Type: ELAP 200.5 ¹⁰
Lab Received: *[Signature]*
Signature: *[Signature]*

Samplers Name: Michael Bowen
Samplers Signature: *[Signature]*
JCB Project Manager: Anthony Lombardo

21 MAR -5 PM 2:01
SAMPLE PLACE, NY



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Seaman Neck Middle School, Levittown Union Free
School District, 1100 Crestline Place, Seaford, NY 11783**

The reference number for these samples is EMSL Order #062104164. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2103		3/5/2021		062104164-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.4 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2104		3/5/2021		062104164-0002			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2105		3/5/2021		062104164-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2107		3/5/2021		062104164-0004			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2108		3/5/2021		062104164-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	14	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2109		3/5/2021		062104164-0006			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	10	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2110		3/5/2021		062104164-0007			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.1	3.0 µg/L	3/10/2021	AM	3/16/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-2111	Collected:	3/5/2021	Lab ID:	062104164-0008	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2113	Collected:	3/5/2021	Lab ID:	062104164-0009	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2115	Collected:	3/5/2021	Lab ID:	062104164-0010	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.4 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2116	Collected:	3/5/2021	Lab ID:	062104164-0011	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2117	Collected:	3/5/2021	Lab ID:	062104164-0012	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2119	Collected:	3/5/2021	Lab ID:	062104164-0013	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.7 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2120	Collected:	3/5/2021	Lab ID:	062104164-0014	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-2121	Collected:	3/5/2021	Lab ID:	062104164-0015	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.8 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2122	Collected:	3/5/2021	Lab ID:	062104164-0016	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2123	Collected:	3/5/2021	Lab ID:	062104164-0017	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2124	Collected:	3/5/2021	Lab ID:	062104164-0018	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2125	Collected:	3/5/2021	Lab ID:	062104164-0019	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2126	Collected:	3/5/2021	Lab ID:	062104164-0020	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	66	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2127	Collected:	3/5/2021	Lab ID:	062104164-0021	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.0	3.0 µg/L	3/10/2021	AM	3/16/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2128				3/5/2021		062104164-0022		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	3.9	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2129				3/5/2021		062104164-0023		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2130				3/5/2021		062104164-0024		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	770 D	30 µg/L	3/10/2021	AM	3/16/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2132				3/5/2021		062104164-0025		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	7.7	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2135				3/5/2021		062104164-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	1.3 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	
Lead MDL: 1.0µg/L								
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2137				3/5/2021		062104164-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	2.0 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	
Lead MDL: 1.0µg/L								
<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
LVT-2139				3/5/2021		062104164-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2140		3/5/2021		062104164-0029			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2142		3/5/2021		062104164-0030			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.5	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2143		3/5/2021		062104164-0031			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2144		3/5/2021		062104164-0032			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.1 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2145		3/5/2021		062104164-0033			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2147		3/5/2021		062104164-0034			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	150	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2148		3/5/2021		062104164-0035			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.2	3.0 µg/L	3/10/2021	AM	3/16/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2150		3/5/2021		062104164-0036			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2151		3/5/2021		062104164-0037			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2153		3/5/2021		062104164-0038			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	13	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2154		3/5/2021		062104164-0039			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.1	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2156		3/5/2021		062104164-0040			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/10/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2157		3/5/2021		062104164-0041			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.3	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2159		3/5/2021		062104164-0042			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Lab ID:</i>			
LVT-2160		3/5/2021		062104164-0043			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

Client Sample Description		LVT-2160	Collected:	3/5/2021	Lab ID:	062104164-0043	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	40	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2161	Collected:	3/5/2021	Lab ID:	062104164-0044	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	470 D	30 µg/L	3/11/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2162	Collected:	3/5/2021	Lab ID:	062104164-0045	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.5	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2163	Collected:	3/5/2021	Lab ID:	062104164-0046	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-2164	Collected:	3/5/2021	Lab ID:	062104164-0047	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2165	Collected:	3/5/2021	Lab ID:	062104164-0048	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Client Sample Description		LVT-2166	Collected:	3/5/2021	Lab ID:	062104164-0049	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>LVT-2168</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0050</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.0 J	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>LVT-2170</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0051</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2171</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0052</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2172</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0053</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2173</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0054</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2174</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0055</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2175</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0056</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.5	3.0 µg/L	3/11/2021	AM	3/16/2021	AL
<i>Client Sample Description</i>		<i>LVT-2176</i>	<i>Collected:</i>	<i>3/5/2021</i>	<i>Lab ID:</i>	<i>062104164-0057</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-2176		3/5/2021			062104164-0057	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021
LVT-2177		3/5/2021			062104164-0058	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	2.9 J	3.0 µg/L	3/11/2021	AM	3/16/2021
Lead MDL: 1.0µg/L						
LVT-2178		3/5/2021			062104164-0059	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021
LVT-2180		3/5/2021			062104164-0060	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/11/2021	AM	3/16/2021
LVT-2181		3/5/2021			062104164-0061	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	1.5 J	3.0 µg/L	3/9/2021	AM	3/11/2021
Lead MDL: 1.0µg/L						
LVT-2185		3/5/2021			062104164-0062	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	2.2 J	3.0 µg/L	3/9/2021	AM	3/11/2021
Lead MDL: 1.0µg/L						
LVT-2187		3/5/2021			062104164-0063	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>
200.5	Lead	3.5	3.0 µg/L	3/9/2021	AM	3/11/2021

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062104164
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/5/2021 02:01 PM
 Collected: 3/5/2021

Project: 19-45328, Seaman Neck Middle School, Levittown Union Free School District, 1100 Crestline Place, Seaford, NY 11783

Analytical Results

Client Sample Description LVT-2189 **Collected:** 3/5/2021 **Lab ID:** 062104164-0064

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/11/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School

062103866

Client:
Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

SLE

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0496	SP	0001	Basement Break Room	KC	3/2/2021	6:13:00 AM
LVT-0498	BR	1001	Men's Bathroom	BF	3/2/2021	6:15:00 AM
LVT-0500	BR	1003	Women's Bathroom	BF	3/2/2021	6:16:00 AM
LVT-0502	BR	1004A	Unisex Bathroom Between Library & Media Center	BF	3/2/2021	6:18:00 AM
LVT-0504	BR	1006	Bathroom	BF	3/2/2021	6:19:00 AM
LVT-0506	CR	1011	Room 301	CF	3/2/2021	6:21:00 AM
LVT-0508	CR	1013	Room 303	CF	3/2/2021	6:23:00 AM
LVT-0509	BR	1014	Boys Bathroom	BF	3/2/2021	6:24:00 AM
LVT-0511	BR	1014	Boys Bathroom	BF	3/2/2021	6:24:00 AM
LVT-0513	BR	1014	Boys Bathroom	BF	3/2/2021	6:25:00 AM
LVT-0519	BR	1016	Girls Bathroom	BF	3/2/2021	6:25:00 AM
LVT-0521	BR	1016	Girls Bathroom	BF	3/2/2021	6:26:00 AM
LVT-0523	BR	1016	Girls Bathroom	BF	3/2/2021	6:26:00 AM
LVT-0525	CR	1018	Room 305	CF	3/2/2021	6:27:00 AM
LVT-0526	CR	1020	Room 307	CF	3/2/2021	6:28:00 AM
LVT-0527	CR	1022	Room 309	CF	3/2/2021	6:29:00 AM
LVT-0529	CR	1019	Room 308	CF	3/2/2021	6:31:00 AM
LVT-0530	CR	1017	Room 306	CF	3/2/2021	6:32:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb206.5
A. Lunny 03/09/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Handwritten signatures]

Samplers Name: Michael Bowen

Samplers Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

CLIENT: Levittown Union Free School District
Retest/New Install | |
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0531	CR	1012	Room 304	CF	3/2/2021	6:33:00 AM
LVT-0532	CR	1010	Room 302	CF	3/2/2021	6:34:00 AM
LVT-0533	CR	1008	Room 300	CF	3/2/2021	6:35:00 AM
LVT-0534	BR	1026C2A	Boys Physical Education Office Locker Room Area Bathroom	BF	3/2/2021	6:36:00 AM
LVT-0536	BR	1026C1	Boys Physical Education Office/Tool Storage Bathroom	BF	3/2/2021	6:37:00 AM
LVT-0538	KI	1024	Kitchen	SA	3/2/2021	6:38:00 AM
LVT-0539	KI	1024	Kitchen	KN	3/2/2021	6:39:00 AM
LVT-0540	KI	1024	Kitchen	KC	3/2/2021	6:40:00 AM
LVT-0541	KI	1024	Kitchen	KC	3/2/2021	6:41:00 AM
LVT-0542	BR	1024A	Kitchen Bathroom	BF	3/2/2021	6:42:00 AM
LVT-0546	CA	1025	Cafeteria	WF	3/2/2021	6:43:00 AM
LVT-0547	CA	1025	Cafeteria	HW	3/2/2021	6:44:00 AM
LVT-0549	BR	1033	Girls Bathroom	BF	3/2/2021	6:45:00 AM
LVT-0551	BR	1033	Girls Bathroom	BF	3/2/2021	6:45:00 AM
LVT-0553	BR	1033	Girls Bathroom	BF	3/2/2021	6:46:00 AM
LVT-0558	BR	1035	Boys Bathroom	BF	3/2/2021	6:46:00 AM
LVT-0560	BR	1035	Boys Bathroom	BF	3/2/2021	6:47:00 AM
LVT-0562	BR	1035	Boys Bathroom	BF	3/2/2021	6:47:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756
Pg 206.5 -
A. Jany 03/09/21

Analysis Type: ELAP 200.5
Lab Received: *[Signature]*
Signature: *[Signature]*

Samplers Name: Michael Bowen
Samplers Signature: *[Signature]*
JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0564	CR	1037	Room 207 (Interior Walls Removed)	CF	3/2/2021	6:48:00 AM
LVT-0565	CR	1039	Room 205	CF	3/2/2021	6:49:00 AM
LVT-0566	CR	1041	Room 203	CF	3/2/2021	6:50:00 AM
LVT-0567	CR	1045	Room 201	CF	3/2/2021	6:51:00 AM
LVT-0568	CR	1045	Room 201	CF	3/2/2021	6:52:00 AM
LVT-0569	BR	1045B	Room 201 Bathroom	BF	3/2/2021	6:53:00 AM
LVT-0571	BR	N/A New Construction	Room 199 Bathroom	BF	3/2/2021	6:54:00 AM
LVT-0573	CR	N/A New Construction	Room 199	CF	3/2/2021	6:55:00 AM
LVT-0574	BR	N/A New Construction	Room 200 Bathroom	BF	3/2/2021	6:57:00 AM
LVT-0575	CR	N/A New Construction	Room 200	CF	3/2/2021	6:58:00 AM
LVT-0577	CR	1046	Room 202	CF	3/2/2021	6:59:00 AM
LVT-0578	BR	1046A	Room 202 Bathroom	BF	3/2/2021	7:00:00 AM
LVT-0579	CR	1042	Room 204	CF	3/2/2021	7:04:00 AM
LVT-0580	CR	1040	Room 206	CF	3/2/2021	7:05:00 AM
LVT-0582	CR	1038	Room 208	CF	3/2/2021	7:06:00 AM
LVT-0583	CR	1036	Room 210	CF	3/2/2021	7:07:00 AM
LVT-0584	BR	1032C1	Psychologist Office Bathroom	BF	3/2/2021	7:08:00 AM
LVT-0586	HA	1031	Corridor Outside Gym	WF	3/2/2021	7:09:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Jany 03/09/21

Analysis Type: ELAP 200.5 ^{AD}

Lab Received: *Chaele*

Signature: *[Signature]*

Samplers Name: Michael Bowen

Samplers Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

062103866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: ~~Normal 1 wk~~ Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0587	BR	1032B1	Social Worker Copy Room Bathroom	BF	3/2/2021	7:10:00 AM
LVT-0589	BR	1028	Men's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0591	BR	1027	Women's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0593	BR	1027	Women's Bathroom	BF	3/2/2021	7:11:00 AM
LVT-0596	BR	1049B	Room 115 Bathroom	BF	3/2/2021	7:13:00 AM
LVT-0597	CA	1048	Room 117	HW	3/2/2021	7:13:00 AM
LVT-0598	BR	1026B2	Gym Music Room 116 Bathroom	BF	3/2/2021	7:14:00 AM
LVT-0600	BR	1026B1A	Gym Music Room 116 Office Bathroom (Former Locker Room Office Bathroom)	BF	3/2/2021	7:14:00 AM
LVT-0602	BR	1054	Women's Bathroom	BF	3/2/2021	7:12:00 AM
LVT-0605	BR	1055	Women's Bathroom	BF	3/2/2021	7:19:00 AM
LVT-0607	FL	1056	Faculty Room	KC	3/2/2021	7:20:00 AM
LVT-0609	BR	1058A	Room 108 Bathroom	BF	3/2/2021	7:21:00 AM
LVT-0611	CR	1060	Room 106	CF	3/2/2021	7:22:00 AM
LVT-0612	BR	1060A	Room 106 Bathroom	BF	3/2/2021	7:23:00 AM
LVT-0614	CR	1062	Room 104	CF	3/2/2021	7:24:00 AM
LVT-0615	BR	1062A	Room 104 Bathroom	BF	3/2/2021	7:24:00 AM
LVT-0617	CR	1064	Room 102	CF	3/2/2021	7:25:00 AM
LVT-0618	BR	1064A	Room 102 Bathroom	BF	3/2/2021	7:26:00 AM

Building Address
4 Summit Lane
Levittown, NY 11756

Pb200.5-
A. Luning 03/09/21

Analysis Type: ELAP 200.5 ^{AD}

Lab Received: *Chelle*

Signature: *[Signature]*

Samplers Name: Michael Bowen

Samplers Signature: *[Signature]*

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

062103866

Client: Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0620	BR	1066A	Room 100 Bathroom	BF	3/2/2021	7:28:00 AM
LVT-0622	CR	N/A New Construction	Room 98	CF	3/2/2021	7:29:00 AM
LVT-0624	BR	N/A New Construction	Room 98 Bathroom	BF	3/2/2021	7:30:00 AM
LVT-0625	BR	N/A New Construction	Room 96 Bathroom	BF	3/2/2021	7:31:00 AM
LVT-0626	CR	N/A New Construction	Room 96	CF	3/2/2021	7:32:00 AM
LVT-0629	CR	N/A New Construction	Room 97	CF	3/2/2021	7:33:00 AM
LVT-0630	BR	N/A New Construction	Room 97 Bathroom	BF	3/2/2021	7:34:00 AM
LVT-0631	BR	N/A New Construction	Faculty Bathroom	BF	3/2/2021	7:35:00 AM
LVT-0632	CR	N/A New Construction	Room 99	CF	3/2/2021	7:36:00 AM
LVT-0634	BR	N/A New Construction	Room 99 Bathroom	BF	3/2/2021	7:38:00 AM
LVT-0635	BR	1067A	Room 101 Bathroom	BF	3/2/2021	7:39:00 AM
LVT-0636	CR	1067	Room 101	CF	3/2/2021	7:40:00 AM
LVT-0637	CR	1065	Room 103	CF	3/2/2021	7:41:00 AM
LVT-0638	BR	1065A	Room 103 Bathroom	BF	3/2/2021	7:42:00 AM
LVT-0640	CR	1063	Room 105	CF	3/2/2021	7:43:00 AM
LVT-0641	BR	1063A	Room 105 Bathroom	BF	3/2/2021	7:44:00 AM
LVT-0643	CR	1061	Room 107	CF	3/2/2021	7:45:00 AM
LVT-0644	BR	1061A	Room 107 Bathroom	BF	3/2/2021	7:45:00 AM

Building Address

4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Loney 03/09/21

Analysis Type: ELAP 200.5 ^{AO}

Lab Releaved: *Chelle*

Signature: *[Signature]*

Samplers Name: *Michael Bowen*

Samplers Signature: *[Signature]*

JCB Project Manager: *Anthony Lombardo*



Lead in Water: Chain of Custody for

062103866

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Summit Lane Elementary School
SLE

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0646	CR	1059	Room 109	CF	3/2/2021	7:46:00 AM
LVT-0647	BR	1059A	Room 109 Bathroom	BF	3/2/2021	7:47:00 AM
LVT-0649	NO	1057A	Nurses Office	NS	3/2/2021	7:48:00 AM
LVT-0650	BR	1057A1	Nurses Office Bathroom	BF	3/2/2021	7:49:00 AM
LVT-0652	KI	1053C	Main Office Corridor Closet	KC	3/2/2021	7:50:00 AM
LVT-0653	BR	1053B	Main Office Side Corridor Bathroom	BF	3/2/2021	7:51:00 AM
LVT-2265	HA	1023	Corridor Library To Room 309	BW	3/2/2021	6:21:00 AM
LVT-2266	HA	1047	Corridor 200 Wing	BW	3/2/2021	6:56:00 AM
LVT-2267	NO	1057C	Large Sick Room	BW	3/2/2021	7:48:00 AM

Samples Submitted 99

LABORATORY
CAFELPLACE, NY
21 MAR - 2 PM 3:05

Building Address
4 Summit Lane
Levittown, NY 11756

Pb 200.5 -
A. Juncy 03/09/21

Analysis Type: ELAP 200.5 ⁴⁰
Lab Received: *Charles*
Signature: *Charles*

Samplers Name: Michael Bowen
Samplers Signature: *Michael Bowen*
JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Anthony Lombardo
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45328, Summit Lane Elementary School, Levittown Union
Free School District, 4 Summit Lane, Levittown, NY 11756

The reference number for these samples is EMSL Order #062103866. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0496		3/2/2021	062103866-0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0498		3/2/2021	062103866-0002				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.2 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0500		3/2/2021	062103866-0003				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.2	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0502		3/2/2021	062103866-0004				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.8	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0504		3/2/2021	062103866-0005				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.8 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0506		3/2/2021	062103866-0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.8 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0508		3/2/2021	062103866-0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	48	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
<i>Client Sample Description</i> LVT-0509				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0008		
200.5	Lead	19	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0511				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0009		
200.5	Lead	10	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0513				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0010		
200.5	Lead	6.3	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0519				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0011		
200.5	Lead	10	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0521				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0012		
200.5	Lead	4.5	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0523				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0013		
200.5	Lead	8.8	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0525				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0014		
200.5	Lead	8.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	
<i>Client Sample Description</i> LVT-0526				<i>Collected:</i> 3/2/2021		<i>Lab ID:</i> 062103866-0015		
200.5	Lead	8.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0015</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.9	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0016</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	60	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0017</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	5.9	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0018</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0019</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.2	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0020</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.2	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0021</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.0	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0022</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.0	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0534	Collected:	3/2/2021	Lab ID:	062103866-0022	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.0	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0536	Collected:	3/2/2021	Lab ID:	062103866-0023	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	62	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0538	Collected:	3/2/2021	Lab ID:	062103866-0024	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0539	Collected:	3/2/2021	Lab ID:	062103866-0025	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0540	Collected:	3/2/2021	Lab ID:	062103866-0026	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.3	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0541	Collected:	3/2/2021	Lab ID:	062103866-0027	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0542	Collected:	3/2/2021	Lab ID:	062103866-0028	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	110	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description		LVT-0546	Collected:	3/2/2021	Lab ID:	062103866-0029	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0546		3/2/2021	062103866-0029				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0547		3/2/2021	062103866-0030				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0549		3/2/2021	062103866-0031				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.3 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0551		3/2/2021	062103866-0032				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0553		3/2/2021	062103866-0033				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.7	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0558		3/2/2021	062103866-0034				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0560		3/2/2021	062103866-0035				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.3	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0562 **Collected:** 3/2/2021 **Lab ID:** 062103866-0036

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.2	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0564 **Collected:** 3/2/2021 **Lab ID:** 062103866-0037

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.4	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0565 **Collected:** 3/2/2021 **Lab ID:** 062103866-0038

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.0	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0566 **Collected:** 3/2/2021 **Lab ID:** 062103866-0039

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.3	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0567 **Collected:** 3/2/2021 **Lab ID:** 062103866-0040

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.1	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0568 **Collected:** 3/2/2021 **Lab ID:** 062103866-0041

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0569 **Collected:** 3/2/2021 **Lab ID:** 062103866-0042

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Lead MDL: 1.0µg/L

Client Sample Description LVT-0571 **Collected:** 3/2/2021 **Lab ID:** 062103866-0043

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
--------	-----------	--------	----------	-----------	---------	---------------	---------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0571		3/2/2021	062103866-0043				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0573		3/2/2021	062103866-0044				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.9 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0574		3/2/2021	062103866-0045				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.1	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0575		3/2/2021	062103866-0046				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0577		3/2/2021	062103866-0047				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.6	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0578		3/2/2021	062103866-0048				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0579		3/2/2021	062103866-0049				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.3 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0580		Collected: 3/2/2021	Lab ID: 062103866-0050				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.8	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description LVT-0582		Collected: 3/2/2021	Lab ID: 062103866-0051				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.7	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description LVT-0583		Collected: 3/2/2021	Lab ID: 062103866-0052				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description LVT-0584		Collected: 3/2/2021	Lab ID: 062103866-0053				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	16	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description LVT-0586		Collected: 3/2/2021	Lab ID: 062103866-0054				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Client Sample Description LVT-0587		Collected: 3/2/2021	Lab ID: 062103866-0055				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description LVT-0589		Collected: 3/2/2021	Lab ID: 062103866-0056				
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-0591 **Collected:** 3/2/2021 **Lab ID:** 062103866-0057

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.3	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0593 **Collected:** 3/2/2021 **Lab ID:** 062103866-0058

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.9	3.0 µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description LVT-0596 **Collected:** 3/2/2021 **Lab ID:** 062103866-0059

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	26	3.0 µg/L	3/8/2021	AM	3/15/2021	AL

Client Sample Description LVT-0597 **Collected:** 3/2/2021 **Lab ID:** 062103866-0060

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.6 J	3.0 µg/L	3/8/2021	AM	3/15/2021	AL

Lead MDL: 1.0µg/L

Client Sample Description LVT-0598 **Collected:** 3/2/2021 **Lab ID:** 062103866-0061

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.6	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

Client Sample Description LVT-0600 **Collected:** 3/2/2021 **Lab ID:** 062103866-0062

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	25	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

Client Sample Description LVT-0602 **Collected:** 3/2/2021 **Lab ID:** 062103866-0063

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	13	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

Client Sample Description LVT-0605 **Collected:** 3/2/2021 **Lab ID:** 062103866-0064

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
--------	-----------	--------	----------	-----------	---------	---------------	---------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0605		3/2/2021	062103866-0064				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	9.3	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0607		3/2/2021	062103866-0065				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.0 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0609		3/2/2021	062103866-0066				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.9	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0611		3/2/2021	062103866-0067				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.4	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0612		3/2/2021	062103866-0068				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	120	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0614		3/2/2021	062103866-0069				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.1 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0615		3/2/2021	062103866-0070				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0071</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	14	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0072</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0073</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.9	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0074</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.1	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0075</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.5	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0076</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.6 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0077</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.1	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0078</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.1	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0629		3/2/2021	062103866-0078				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.5	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0630		3/2/2021	062103866-0079				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.1	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0631		3/2/2021	062103866-0080				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0632		3/2/2021	062103866-0081				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.4 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0634		3/2/2021	062103866-0082				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.2 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0635		3/2/2021	062103866-0083				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0636		3/2/2021	062103866-0084				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	13	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0085</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	12	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0086</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.6	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0087</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	7.9	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0088</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.2	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0089</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	4.4	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0090</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.9 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0091</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.2	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
<i>Client Sample Description</i>				<i>Collected:</i>	<i>3/2/2021</i>	<i>Lab ID:</i>	<i>062103866-0092</i>
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.2	3.0 µg/L	3/8/2021	AM	3/11/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0647				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	7.7	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0649				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	5.2	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0650				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	55	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0652				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	21	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-0653				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	1.7 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
Lead MDL: 1.0µg/L								
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-2265				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-2266				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
LVT-2267				3/2/2021				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.5	Lead	<3.0 ND	3.0 µg/L	3/8/2021	AM	3/11/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103866
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Anthony Lombardo**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/2/2021 03:04 PM
 Collected: 3/2/2021

Project: 19-45328, Summit Lane Elementary School, Levittown Union Free School District, 4 Summit Lane, Levittown, NY 11756

Analytical Results

Client Sample Description LVT-2267 **Collected:** 3/2/2021 **Lab ID:** 062103866-0099

Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.6 J	3.0 µg/L	3/8/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted



Lead in Water: Chain of Custody for

062103995

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Wisdom Lane Middle School
WLM

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0810	CR	1003A	Room 103A Office 1	CF	3/3/2021	5:14:00 AM
LVT-0812	BR	1007	Boys Room	BF	3/3/2021	5:15:00 AM
LVT-0814	BR	1007	Boys Room	BF	3/3/2021	5:15:00 AM
LVT-0816	BR	1007	Boys Room	BF	3/3/2021	5:16:00 AM
LVT-0818	BR	1007	Boys Room	BF	3/3/2021	5:16:00 AM
LVT-0823	BR	1009	Girls Room	BF	3/3/2021	5:17:00 AM
LVT-0825	BR	1009	Girls Room	BF	3/3/2021	5:17:00 AM
LVT-0827	BR	1009	Girls Room	BF	3/3/2021	5:18:00 AM
LVT-0829	BR	1009	Girls Room	BF	3/3/2021	5:18:00 AM
LVT-0833	BR	1027	Boys Room	BF	3/3/2021	5:19:00 AM
LVT-0835	BR	1027	Boys Room	BF	3/3/2021	5:20:00 AM
LVT-0837	BR	1027	Boys Room	BF	3/3/2021	5:20:00 AM
LVT-0842	BR	1029	Girls Room	BF	3/3/2021	5:21:00 AM
LVT-0844	BR	1029	Girls Room	BF	3/3/2021	5:21:00 AM
LVT-0846	BR	1029	Girls Room	BF	3/3/2021	5:22:00 AM
LVT-0848	BR	1029	Girls Room	BF	3/3/2021	5:22:00 AM
LVT-0850	CR	1032	Room 121	CF	3/3/2021	5:23:00 AM
LVT-0851	CR	1033	Room 122	CF	3/3/2021	5:24:00 AM

Building Address Pb 200.5 -
120 Center Lane
Levittown, NY 11756

A. J. [Signature] 03/11/21

Analysis Type: ELAP 200.5

Lab Received: [Signature]

Signature: [Signature]

Samplers Name: Alina Castelluzzo
Samplers Signature: Alina Castelluzzo
JCB Project Manager: Meghan Gwynn

Order ID: 062103995

Page 1 of 5



Lead in Water: Chain of Custody for

062103995

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Wisdom Lane Middle School
WLM

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0852	SP	N/A New Construction	Instrument Storage Room Right	HW	3/3/2021	6:35:00 AM
LVT-0854	BR	N/A New Construction	Girls Room	BF	3/3/2021	5:30:00 AM
LVT-0855	BR	N/A New Construction	Girls Room	BF	3/3/2021	5:30:00 AM
LVT-0857	BR	N/A New Construction	Boys Room	BF	3/3/2021	5:31:00 AM
LVT-0858	BR	N/A New Construction	Boys Room	BF	3/3/2021	5:31:00 AM
LVT-0860	HE	0016	Basement B17	EC	3/3/2021	6:11:00 AM
LVT-0861	HE	0016	Basement B17	EC	3/3/2021	6:12:00 AM
LVT-0862	HE	0016	Basement B17	EC	3/3/2021	6:12:00 AM
LVT-0863	HE	0015	Basement Room B15	EC	3/3/2021	6:09:00 AM
LVT-0864	HE	0015	Basement Room B15	EC	3/3/2021	6:09:00 AM
LVT-0865	HE	0015	Basement Room B15	EC	3/3/2021	6:10:00 AM
LVT-0866	HE	0015	Basement Room B15	EC	3/3/2021	6:10:00 AM
LVT-0867	HE	0015	Basement Room B15	EC	3/3/2021	6:11:00 AM
LVT-0871	CR	0013	Basement Shop Room B13	CF	3/3/2021	6:07:00 AM
LVT-0875	BR	1048A	Boiler Room Bathroom	BF	3/3/2021	5:50:00 AM
LVT-0878	HA	N/A New Construction	Corridor	WF	3/3/2021	5:33:00 AM
LVT-0885	SP	N/A New Construction	Library	HW	3/3/2021	6:34:00 AM
LVT-0899	CR	N/A New Construction	Room 332	CF	3/3/2021	5:33:00 AM

Building Address Pb 206.5 -
120 Center Lane
Levittown, NY 11756

[Signature] 03/11/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Signature]

Samplers Name: Alina Castelli

Samplers Signature: *[Signature]*

JCB Project Manager: Meghan Gwynn

OrderID: 062103995

Page 2 of 5



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Wisdom Lane Middle School
WLM

062103995

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0900	CR	N/A New Construction	Room 332	CF	3/3/2021	5:34:00 AM
LVT-0901	CR	1086	Room 330	CF	3/3/2021	5:34:00 AM
LVT-0902	CR	1086	Room 330	CF	3/3/2021	5:35:00 AM
LVT-0903	CR	1086	Room 330	CF	3/3/2021	5:35:00 AM
LVT-0907	CR	1079	Room 321	CF	3/3/2021	5:36:00 AM
LVT-0914	BR	1075	Girls Bathroom	BF	3/3/2021	6:32:00 AM
LVT-0916	BR	1075	Girls Bathroom	BF	3/3/2021	6:32:00 AM
LVT-0918	BR	1075	Girls Bathroom	BF	3/3/2021	6:33:00 AM
LVT-0920	BR	1073	Boys Bathroom	BF	3/3/2021	5:43:00 AM
LVT-0922	BR	1073	Boys Bathroom	BF	3/3/2021	5:43:00 AM
LVT-0924	BR	1073	Boys Bathroom	BF	3/3/2021	5:44:00 AM
LVT-0926	BR	1073	Boys Bathroom	BF	3/3/2021	5:44:00 AM
LVT-0930	BR	1088A	Girls Coach Office Bathroom	BF	3/3/2021	6:31:00 AM
LVT-0932	CR	1072	Room 317	CF	3/3/2021	5:45:00 AM
LVT-0933	CR	1072	Room 317	CF	3/3/2021	5:46:00 AM
LVT-0934	LR	1089	Girls Locker Room	BF	3/3/2021	6:36:00 AM
LVT-0935	LR	1089	Girls Locker Room	BF	3/3/2021	6:36:00 AM
LVT-0936	LR	1089	Girls Locker Room	WC	3/3/2021	6:27:00 AM

Building Address
120 Center Lane
Levittown, NY 11756

Pb 200.5-
A. Lunny 03/11/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Signature]

Samplers Name: Ajika Caste
Samplers Signature: [Signature]
JCB Project Manager: Meghan Swann



Lead in Water: Chain of Custody for

062103995

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Wisdom Lane Middle School
WLM

Client: Levittown Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0940	LR	1091	Boys Locker Room	BF	3/3/2021	6:25:00 AM
LVT-0942	LR	1091	Boys Locker Room	BF	3/3/2021	6:26:00 AM
LVT-0944	KI	1047B1	Conference Room Closet	KC	3/3/2021	5:48:00 AM
LVT-0949	BR	1052	Men's Bathroom	BF	3/3/2021	5:47:00 AM
LVT-0951	BR	1056	Ladies Faculty Bathroom	BF	3/3/2021	5:55:00 AM
LVT-0953	BR	1056	Ladies Faculty Bathroom	BF	3/3/2021	5:55:00 AM
LVT-0955	BR	1056	Ladies Faculty Bathroom	BF	3/3/2021	5:56:00 AM
LVT-0957	BR	1056	Ladies Faculty Bathroom	BF	3/3/2021	5:56:00 AM
LVT-0962	BR	1058	Boys Room	BF	3/3/2021	6:21:00 AM
LVT-0964	BR	1058	Boys Room	BF	3/3/2021	6:21:00 AM
LVT-0966	BR	1058	Boys Room	BF	3/3/2021	6:22:00 AM
LVT-0968	OF	1070	Room 310	HW	3/3/2021	6:20:00 AM
LVT-0971	CR	1065	Room 302	CF	3/3/2021	5:57:00 AM
LVT-0972	CR	1064	Room 300	CF	3/3/2021	5:58:00 AM
LVT-0974	HA	1049	Corridor Boiler Room To Room 200	WF	3/3/2021	5:08:00 AM
LVT-0975	BR	1044A	Room 208 Bathroom	BF	3/3/2021	5:10:00 AM
LVT-0978	CA	N/A New Construction	Cafeteria Add On	WF	3/3/2021	5:09:00 AM
LVT-0979	BR	N/A New Construction	Girls Room	BF	3/3/2021	6:16:00 AM

Building Address
120 Center Lane
Levittown, NY 11756

Pb 200.5 -
A. L... 03/11/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

aele

Samplers Name: *Alicia Castelluzzo*

Samplers Signature: *alicia castelluzzo*

JCB Project Manager: *Meghan Gwynn*



Lead in Water: Chain of Custody for

062103995

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45328
Building: Wisdom Lane Middle School
WLM

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AMERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0983	BR	N/A New Construction	Boys Room	BF	3/3/2021	6:17:00 AM
LVT-0988	FL	1041	Faculty Room 204	KC	3/3/2021	6:42:00 AM
LVT-0989	KI	1046	Kitchen/Room 209	KC	3/3/2021	6:43:00 AM
LVT-0990	KI	1046	Kitchen/Room 209	KC	3/3/2021	6:43:00 AM
LVT-0991	KI	1046	Kitchen/Room 209	KN	3/3/2021	6:44:00 AM
LVT-0992	KI	1046	Kitchen/Room 209	KC	3/3/2021	6:44:00 AM
LVT-0993	KI	1046	Kitchen/Room 209	KC	3/3/2021	6:45:00 AM
LVT-0994	BR	1046C1	Kitchen Closet Bathroom	BF	3/3/2021	6:46:00 AM
LVT-0998	KI	1046F	Kitchen Serving Area	KN	3/3/2021	6:46:00 AM
LVT-0999	NO	1039	Nurses Office	NS	3/3/2021	6:40:00 AM
LVT-1001	BR	1039A	Nurses Office Bathroom	BF	3/3/2021	6:41:00 AM
LVT-1004	BR	1037	Ladies Room	BF	3/3/2021	6:50:00 AM
LVT-1006	BR	1037	Ladies Room	BF	3/3/2021	6:51:00 AM
LVT-1008	BR	1036	Men's Bathroom	BF	3/3/2021	6:52:00 AM
LVT-2268	FL	1041	Faculty Room 204	BW	3/3/2021	6:43:00 AM

Samples Submitted 87

RECEIVED
ANALYTICAL, INC.
100 STATE PLACE, NY
3/3/21
3:19 PM

Building Address Fb 200.5 -
120 Center Lane
Levittown, NY 11756

[Signature]
03/11/21

Analysis Type: ELAP 200.5

Lab Received:

Signature:

[Signature]

Samplers Name: Aina Castelluzzo

Samplers Signature: *[Signature]*

JCB Project Manager: Meghan Gwynn



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn:

Meghan Gwynn
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

4/7/2021

Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

**19-45328, Wisdom Lane Middle School, Levittown Union Free
School District, 120 Center Lane, Levittown, NY 11756**

The reference number for these samples is EMSL Order #062103995. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

Client Sample Description				Collected:	Lab ID:		
LVT-0810				3/3/2021	062103995-0001		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.5	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-0812				3/3/2021	062103995-0002		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-0814				3/3/2021	062103995-0003		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description				Collected:	Lab ID:		
LVT-0816				3/3/2021	062103995-0004		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description				Collected:	Lab ID:		
LVT-0818				3/3/2021	062103995-0005		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description				Collected:	Lab ID:		
LVT-0823				3/3/2021	062103995-0006		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description				Collected:	Lab ID:		
LVT-0825				3/3/2021	062103995-0007		
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0827				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0008		
200.5	Lead	5.3	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0829				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0009		
200.5	Lead	4.8	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0833				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0010		
200.5	Lead	5.2	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0835				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0011		
200.5	Lead	5.5	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0837				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0012		
200.5	Lead	5.2	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0842				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0013		
200.5	Lead	9.7	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0844				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0014		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0846				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0015		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0846				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0015		
200.5	Lead	5.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0848				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0016		
200.5	Lead	6.2	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0850				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0017		
200.5	Lead	190	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0851				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0018		
200.5	Lead	24	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0852				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0019		
200.5	Lead	5.5	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0854				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0020		
200.5	Lead	15	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0855				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0021		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0857				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0022		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
<i>Client Sample Description</i> LVT-0857				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0022		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0858				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0023		
200.5	Lead	8.8	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0860				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0024		
200.5	Lead	49	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0861				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0025		
200.5	Lead	18	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0862				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0026		
200.5	Lead	26	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0863				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0027		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0864				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0028		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0865				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0029		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0865		3/3/2021	062103995-0029				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0866		3/3/2021	062103995-0030				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.9 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0867		3/3/2021	062103995-0031				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	6.5	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0871		3/3/2021	062103995-0032				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	11	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0875		3/3/2021	062103995-0033				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0878		3/3/2021	062103995-0034				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0885		3/3/2021	062103995-0035				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.3 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0899				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0036		
200.5	Lead	18	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0900				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0037		
200.5	Lead	30	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0901				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0038		
200.5	Lead	110	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0902				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0039		
200.5	Lead	13	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0903				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0040		
200.5	Lead	54	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0907				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0041		
200.5	Lead	4.5	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0914				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0042		
200.5	Lead	3.7	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0916				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0043		
200.5	Lead	3.7	3.0 µg/L	3/9/2021	AM	3/12/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
<i>Client Sample Description</i> LVT-0916				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0043		
200.5	Lead	4.3	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0918				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0044		
200.5	Lead	4.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0920				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0045		
200.5	Lead	7.7	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0922				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0046		
200.5	Lead	3.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0924				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0047		
200.5	Lead	3.4	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0926				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0048		
200.5	Lead	3.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0930				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0049		
200.5	Lead	8.0	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i> LVT-0932				<i>Collected:</i> 3/3/2021	<i>Lab ID:</i> 062103995-0050		
200.5	Lead	8.0	3.0 µg/L	3/9/2021	AM	3/12/2021	AL



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0932	Collected:	3/3/2021	Lab ID:	062103995-0050	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	39	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0933	Collected:	3/3/2021	Lab ID:	062103995-0051	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	33	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0934	Collected:	3/3/2021	Lab ID:	062103995-0052	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0935	Collected:	3/3/2021	Lab ID:	062103995-0053	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.6	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0936	Collected:	3/3/2021	Lab ID:	062103995-0054	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0940	Collected:	3/3/2021	Lab ID:	062103995-0055	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0942	Collected:	3/3/2021	Lab ID:	062103995-0056	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.4 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0944		3/3/2021	062103995-0057				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.3 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0949		3/3/2021	062103995-0058				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.0 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0951		3/3/2021	062103995-0059				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.1	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0953		3/3/2021	062103995-0060				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	8.8	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0955		3/3/2021	062103995-0061				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.6 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0957		3/3/2021	062103995-0062				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	3.2	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-0962		3/3/2021	062103995-0063				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	18	3.0 µg/L	3/9/2021	AM	3/12/2021	AL

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
<i>Client Sample Description</i> LVT-0964				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0064		
200.5	Lead	10	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0966				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0065		
200.5	Lead	13	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0968				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0066		
200.5	Lead	3.4	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0971				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0067		
200.5	Lead	11	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0972				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0068		
200.5	Lead	56	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0974				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0069		
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0975				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0070		
200.5	Lead	70	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	
<i>Client Sample Description</i> LVT-0978				<i>Collected:</i> 3/3/2021		<i>Lab ID:</i> 062103995-0071		
200.5	Lead	70	3.0 µg/L	3/9/2021	AM	3/12/2021	AL	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0978	Collected:	3/3/2021	Lab ID:	062103995-0071	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0979	Collected:	3/3/2021	Lab ID:	062103995-0072	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0983	Collected:	3/3/2021	Lab ID:	062103995-0073	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0988	Collected:	3/3/2021	Lab ID:	062103995-0074	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0989	Collected:	3/3/2021	Lab ID:	062103995-0075	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.9 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0990	Collected:	3/3/2021	Lab ID:	062103995-0076	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0991	Collected:	3/3/2021	Lab ID:	062103995-0077	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.0 J	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results

Client Sample Description		LVT-0992	Collected:	3/3/2021	Lab ID:	062103995-0078	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0993	Collected:	3/3/2021	Lab ID:	062103995-0079	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0994	Collected:	3/3/2021	Lab ID:	062103995-0080	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	13	3.0 µg/L	3/9/2021	AM	3/12/2021	AL
Client Sample Description		LVT-0998	Collected:	3/3/2021	Lab ID:	062103995-0081	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-0999	Collected:	3/3/2021	Lab ID:	062103995-0082	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.5	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Client Sample Description		LVT-1001	Collected:	3/3/2021	Lab ID:	062103995-0083	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.2 J	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
Client Sample Description		LVT-1004	Collected:	3/3/2021	Lab ID:	062103995-0084	
Method	Parameter	Result	RL Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY 11514
 Phone/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> carleplacelab@emsl.com

EMSL Order: 062103995
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Meghan Gwynn**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 3/4/2021 03:19 PM
 Collected: 3/3/2021

Project: 19-45328, Wisdom Lane Middle School, Levittown Union Free School District, 120 Center Lane, Levittown, NY 11756

Analytical Results


<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1006		3/3/2021	062103995-0085				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	1.7 J	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-1008		3/3/2021	062103995-0086				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	2.4 J	3.0 µg/L	3/9/2021	AM	3/11/2021	AL
Lead MDL: 1.0µg/L							
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
LVT-2268		3/3/2021	062103995-0087				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.5	Lead	<3.0 ND	3.0 µg/L	3/9/2021	AM	3/11/2021	AL

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - Result was below the MDL.
- RL = Reporting Limit (the value below which is not defensibly quantifiable)
- D = Sample was diluted

Attachment 3:

Laboratory Certifications



J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Enterococci	SM 20, 23 9230C (Budnick 1996)
Heterotrophic Plate Count	SimPlate SM 20, 21-23 9215B (-04)

Metals I

Lead, Total	EPA 200.5
-------------	-----------

Miscellaneous

Asbestos	EPA 100.2
----------	-----------

NEW YORK
STATE OF
OPPORTUNITY

Department
of Health

Serial No.: 62991

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

